

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: June/2024

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 91044 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	0.08	0.08	-	0.08
2	0.08	-	-	-	.1	-	.1
3	-	-	-	0.12	-	-	0.12
4	-	-	-	.15	-	0.05	0.15
5	-	-	-	0.06	0.06	-	0.06
6	-	-	-	0.06	0.06	-	0.06
7	-	-	0.05	0.04	0.04	-	0.05
8	-	-	0.04	0.05	0.05	-	0.05
9	0.06	0.05	-	0.04	0.04	-	0.06
10	-	-	-	0.05	0.04	-	0.05
11	-	-	0.04	-	-	0.05	0.05
12	0.04	-	-	0.05	0.05	-	0.05
13	-	-	0.06	0.06	-	-	0.06
14	-	0.08	-	-	0.02	0.02	0.08
15	-	-	0.02	0.01	0.01	-	0.02
16	0.01	0.01	-	.02	.02	-	.02
17	-	-	.02	.02	.02	0	.02
18	-	0.02	.02	-	-	0.02	0.02
19	0.02	-	-	0.02	0.02	0.02	0.02
20	-	-	-	0.02	0.02	0.02	0.02
21	-	-	-	0.02	0.02	0.02	0.02
22	-	-	-	0.02	0.02	0.02	0.02
23	0.02	-	-	0.02	.02	.02	.02
24	-	-	-	0.02	0.02	0.02	0.02
25	-	-	-	0.02	.02	-	.02
26	-	.02	.02	.02	-	0.02	0.02
27	0.02	-	-	0.02	0.02	-	0.02
28	-	-	0.02	0.02	-	0.03	0.03
29	0.03	-	-	0.035	0.03	0.03	0.035
30	0.03	-	-	0.02	0.02	0.02	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: Kati Baker	DATE: 7/2/2024
		SIGNATURE: [Signature]	CERT #:
		PHONE #: (541) 997 3857	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park

ID#: 41

91044

Month/Year: June 2014

Disinfection Giardia Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
MM 1 4:54	0.54	400	259.2	16.1	7.31	26	yes	98
MM 2 11:38	0.61		292.8	14.4	6.74	36	yes	
PD 3 4:42	.71		340.8	15.6	6.31	20	yes	
PD 4 4:11	.52		249.6	14.4	6.39	30	yes	
MM 5 4:10	0.56		268.8	13.9	6.28	29	yes	
MM 6 11:05	0.57		273.6	15.6	6.26	20	yes	
MM 7 11:23	0.58		278.4	16.1	6.20	20	yes	
MM 8 11:17	0.68		326.4	16.1	6.20	20	yes	
NM 9 11:11	0.82		393.6	15.0	6.22	20	yes	
KB 10 11:26	0.76		364.8	16.1	6.19	20	yes	
KB 11 14:00	0.75		360	16.1	6.21	20	yes	
KB 12 10:48	0.72		345.6	14.4	6.24	31	yes	
MM 13 10:44	0.70		336	16.1	6.24	20	yes	
MM 14 12:06	0.68		326.4	14.4	6.27	30	yes	
MM 15 11:14	0.68		326.4	16.7	6.20	20	yes	
MM 16 11:45	0.61		292.8	16.1	6.18	20	yes	
RW 17 12:05	.67		321.6	16.1	6.25	20	yes	
DC 18 17:58	.63		302.4	15.6	6.18	20	yes	
MM 19 14:08	0.74		355.2	17.2	6.10	20	yes	
MM 20 12:00	0.61		292.8	16.7	6.05	20	yes	
MM 21 15:36	0.71		340.8	18.3	6.12	20	yes	
MM 22 12:00	0.70		336	17.2	6.10	20	yes	
MM 23 13:15	0.71		340.8	18.3	6.12	20	yes	
RW 24 10:46	.71		340.8	17.2	6.32	20	yes	
KB 25 13:00	0.58		278.4	17.8	5.96	17	yes	
RW 26 12:30	.63		302.4	17.8	6.20	20	yes	
MM 27 11:10	0.82		393.6	18.3	6.18	20	yes	
MM 28 11:11	0.61		292.8	17.8	6.20	20	yes	
MM 29 11:50	0.67		321.6	17.8	6.18	20	yes	
KB 30 08:57	0.59		283.2	16.7	6.09	20	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Raw Turbidity Month/Year June 2024

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.81	x	
2	0.98		x
3	.81		x
4	.93		x
5	0.09		x
6	0.72	x	
7	0.68	x	
8	0.63	x	
9	0.93		x
10	0.70	x	
11	0.70		x
12	0.77		x
13	0.54	x	
14	0.62		x
15	0.61	x	
16	0.62		x
17	.60		✓
18	.69		x
19	0.58	x	
20	0.48	x	
21	0.42	x	
22	0.50	x	
23	0.66	x	
24	.63	✓	
25	0.55	x	
26	.56	✓	
27	0.53	x	
28	0.61		x
29	0.55	x	
30	0.58		x
31			

Heceta Head State Park Monthly Turbidity Report, Public Water Supplies

PWS ID # 4191048A
SYSTEM NAME: Heceta Head State Park
SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N
Florence, OR 97439 MONTH/YEAR
PHONE: 541-547-3416 2024 June

DATE/TIME	INITIALS	C/2 RESIDUAL	COMMENTS	METER READING
1				
2				
3				
4	BE	0.2	1.8 cl ₂	40667
5	RM	.5	1.8 cl ₂	40692
6				
7				
8	RM/CM	1.0	1.75 cl ₂	40704
9	CM/SD	.1	1.75 cl ₂	40710
10	CM/SD	1.005	1.75 cl ₂	40713
11				40718
12	BE	.1	1.75 cl ₂	
13	RM/CC	.7	1.5 cl ₂	40724
14	SD	.5	1.5 cl ₂	40727
15	CM	.7	1.5 cl ₂	40735
16	SD	.5	1.5 cl ₂	40740
17	CM	.5	1.5 cl ₂ ↑ 2 added	40746
18	RM/CC	.1	2	40749
19	CC	.1	2	40761
20	CC	.1	2	40765
21	SD	.5	2	40768
22				40780
23	CM	.5	1.90 cl ₂	40780
24		.5		40782
25				
26				
27	CMC	.1	1.5 cl ₂	40837
28	CMC	.1	1.5 cl ₂	40855
29	RM	.1	1.5 cl ₂	40861
30				
31				

Total: _____
Write off when not producing water.

Total -- # days=monthly average

----- =

WELL LOG: MONTHLY WATER REPORT

MONTH: June 148185 13.03 YEAR: 2024

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	BC	430p			3 up	148251		13.28				
2	JT	1pm	1	shop		148251	45 [?]	12.07				Shower stuck on
3	Deb	925				148311	45 ⁺	13.01				
4	Deb	9	1	15		148319 ⁶⁰	45	12.12				Running
5	BC	1019				148379	45	12.57				
6												
7												4.5
8	Deb	230	1	shop		148508	40	12.03				4
9	JT	5pm				148578	40	12.10				5
10	Deb	10:09A				148646	35 ³	12.94				4.5
11	Deb	1157				148708	35 ²	13.25				4.5
12												
13	bc	1200	1	02		148772	35 ¹	12.57				
14	RM	1000	1	Pump works		148834	35	13.07				
15	RM	1030	1	"		14890.2	30 ⁺³	13.46				
16	JT	9am				14890.2	30 ⁺³	12.04				
17	JT	11am	1	D.U.		148975	30 ⁺²	12.09				
18	RM	7:30	1.3	PH		14903.9	30 ⁺¹	12.76				
19	RM	730	1.4	PH		14910.8	30	13.04				
20	RM	7:30	1.2	PH		14917.6	25 ⁺³	13.20				
21	RM	730	1.0	PH		14923.4	25 ⁺²	13.33				3.5
22	RM	7-30	1.0	PH		14929.5	25 ^H	13.35				
23	Deb	921				149357	25 ⁺	13.34				3.5
24	Deb	845	1	shop		149377	25	12.39				5 shower stuck shut. time
25	RM	830	1.2	PH		14943.3	20 ⁺³	12.37				
26	RM	800	1	PH		14949.2	20 ⁺²	12.30				4.5
27	RM	730	1	PH		14956.6	20 ⁺¹	13.19				
28	Deb	910				149627	20 ⁺	13.27				3.5
29	Deb					61						
30	Deb	1015	1	sp		149754	15 ³⁻	13.21				
31												

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.