

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: Oct 2024

System Name:	OPRD JM Honeyman Memorial State Park ID#: 41 : 91044						WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	0.02	0.33	0.02	0.33
2	-	-	-	0.03	0.03	-	0.03
3	-	-	-	0.02	0.02	-	0.02
4	-	-	0.02	-	0.04	0.1	0.1
5	0.02	-	0.02	0.14	0.02	-	0.14
6	-	-	0.12	0.02	0.02	-	0.12
7	-	-	0.02	0.02	-	-	0.02
8	-	-	0.02	0.03	-	-	0.03
9	-	-	0.03	0.03	0.05	-	0.05
10	-	-	0.04	0.21	0.24	-	0.24
11	-	-	-	0.26	-	-	0.26
12	-	-	0.28	0.09	0.03	0.14	0.14
13	0.12	0.14	0.29	0.05	-	-	0.29
14	-	-	0.20	0.20	0.15	-	0.20
15	-	-	-	-	-	-	-
16	-	-	-	-	0.02	0.02	0.02
17	0.02	-	-	0.02	0.02	-	0.02
18	-	-	-	0.02	0.02	0.03	0.03
19	0.04	0.08	0.10	0.02	0.02	0.03	0.10
20	0.04	0.08	0.09	0.02	0.02	-	0.09
21	-	-	0.02	-	0.03	0.03	0.03
22	0.04	0.04	0.12	-	0.03	0.03	0.12
23	-	-	-	0.05	0.06	-	0.06
24	-	-	-	0.03	0.05	-	0.05
25	-	-	-	0.07	-	-	0.07
26	-	-	-	0.07	0.07	-	0.07
27	-	-	-	0.02	0.02	-	0.02
28	-	-	-	0.03	0.03	-	0.03
29	-	-	-	0.06	0.07	-	0.07
30	-	-	-	-	-	-	-
31	-	-	-	0.06	0.08	-	0.08

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Nathan Micha

SIGNATURE: Nathan Micha

PHONE #: (541) 994-5615

DATE: 11-1-24

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Oct 2024

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
HE 1 1450	0.55	480	268.8	17.8	6.12	20	yes	98
DC 2 1205	0.55	}	268.8	17.2	6.35	20	yes	}
Mm 3 940	0.55		264	15.6	6.20	20	yes	
MB 4 14:30	0.50		240	16.1	6.27	20	yes	
LB 5 1530	0.62		297.6	17.8	5.95	17	yes	
MS 6 12:00	0.60		288	17.2	6.15	20	yes	
Mm 7 9:44	0.57		273.6	17.2	6.03	20	yes	
Mm 8 9:41	0.49		235.2	17.2	6.02	20	yes	
Mm 9 9:42	0.59		283.2	17.2	6.07	20	yes	
Nm 10 9:51	0.65		312	16.1	6.04	20	yes	
Mm 11 10:09	0.40		192	16.7	6.10	20	yes	
HE 12 1209	0.66		316.8	17.2	6.06	20	yes	
DC 13 929	0.69		331.2	17.2	6.05	20	yes	
Mm 14 1218	0.84		403.2	17.8	6.13	20	yes	
Mm 15 3:00	0.71		340.8	17.2	6.11	20	yes	
Mm 16 10:07	0.65		312	16.7	6.15	20	yes	
Mm 17 9:41	0.45		216	15.0	6.11	20	yes	
Mm 18 9:43	0.44		211.2	15.6	6.05	20	yes	
DC 19 1140	0.70		336.0	16.1	5.93	17	yes	
DC 20 951	0.68		326.4	16.1	5.97	17	yes	
Mm 21 9:47	0.73		350.4	15.6	5.45	17	yes	
PP 22 12:34	0.87		417.6	14.4	4.87	26	yes	
Mm 23 9:40	0.90		432	13.9	5.32	26	yes	
Mm 24 9:38	0.90		432	13.9	4.96	26	yes	
Mm 25 9:47	0.97		465.6	13.3	5.25	26	yes	
HE 26 1010	0.87		417.6	14.4	4.74	26	yes	
HE 27 10:07	0.90	432	13.9	4.69	26	yes		
Mm 28 10:10	0.84	403.2	13.9	4.09	26	yes		
Mm 29 9:42	0.61	297.6	16.1	4.41	17	yes		
Mm 30 9:41	0.72	348.3	16.1	5.12	17	yes		
Mm 31 9:37	0.70	336	13.9	4.40	25	yes		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of October, 2024

Date	Initial	Time	Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
			Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	x Gallons Used	Alum Pounds	Chlorine Gallons
			815894	67987							
						897042					
1	HB	14:50		68789	80200	89784	14900	20867	748	0	1
2	DC	12:05		69352	57800	897963	12200	20869	1496	3-12	2
3	MM	9:32		69964	60200	898074	11100	20869	0	1-4	0
4	MB	14:19		70832	86200	898225	18200	20872	2244 348	3-12	2
5	LB	15:30		71505	67300	898426	17000	20874	1496	0	1
6	NB	12:00		72131	62600	898576	15000	20879	3740	3-12	2
7	NM	9:26	815894	72717	58600	898707	13100	20882	2244	0	0
8	MM	9:28	816527		63300	898846	13900	20884	1496	3-12	2
9	MM	9:30	817137		61000	898997	15100	20885	748	1-4	1
10	MM	9:57	817775		63800	899135	13800	20887	1496	2-8	1
11	MM	10:08	818408		63300	899279	14400	20889	1496	2-8	2
12	HE	12:09	819156		74800	899456	17700	20892	2,244	0	2
13	DC	9:29	819713		55700	899591	13500	20894	1496	0	2
14	MM	12:13	820401	72718	68800	899754	16300	20896	1496	2-8	2
15	MM	3:00		73304	58600	899875	12100	20896	0	0	1
16	MM	10:01		73842	53800	900016	14100	20898	1496	0	1
17	MM	4:49		74679	63700	900139	12700	20898	0	6-4	1
18	MM	9:34		75312	63300	900272	13300	20899	748	3-12	1
19	DC	11:48		76035	72300	900415	14300	20899	0	5	2
20	DC	9:51		76687	65200	900594	17900	20899	0	3-12	1
21	MM	9:31		77441	75400	900758	16400	20901	1496	3-12	2
22	DC	12:35	821090		68900	900900	14200	20901	0	3-12	2
23	MM	9:43	821676		58600	901003	10300	20901	0	3-12	2
24	MM	9:37	822277		60100	901122	11900	20901	0	2-8	2
25	MM	9:52	822907		63000	901252	13000	20903	1496	3-12	1
26	HE	10:10	823550		64300	901373	12100	20903	0	3-12	1
27	LE	10:07	824183		63300	901510	13700	20903	0	7-8	1
28	MM	9:57	824808	77414	62500	901637	12700	20903	0	3-12	2
29	MM	9:39		78073	65900	901754	11700	20905	1496	2-8	1
30	MM	9:41		78747	67400	901864	11000	20905	0	2-8	1
31	MM	9:50		79384	63700	901968	10400	20905	0	2-8	1

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of October, 2024

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	-	-	-	0.6	0.9	-	0.55	0.54	0.45
2	-	-	-	0.89	0.97	-	0.56	0.55	0.49
3	-	-	-	1.05	1	-	0.55	0.47	0.45
4	-	-	0.90	-	0	0	0.50	0.50	0.43
5	1.1	-	0	0	1.1	-	0.62	0.53	0.40
6	-	-	0	0.95	0.83	-	0.60	0.61	0.43
7	-	-	0.86	0.98	-	-	0.57	0.55	0.44
8	-	-	1.04	1.09	-	-	0.49	0.51	0.38
9	-	-	0.80	0.94	0.71	-	0.59	0.57	0.38
10	-	-	0.56	0.68	0.62	-	0.65	0.49	0.37
11	-	-	-	1.01	-	-	0.66	0.53	0.38
12	-	-	1.1	1.22	-	-	0.69	0.57	0.35
13	-	-	1.19	1.24	-	-	0.84	0.78	0.38
14	-	-	1.08	1.11	1.03	-	0.71	0.60	0.36
15	-	-	-	-	-	-	0.65	0.83	0.37
16	-	-	-	-	0.74	0.51	0.45	0.69	0.31
17	0.41	-	-	0.43	0.39	-	0.44	0.59	0.41
18	-	-	-	0.50	-	-	0.70	0.49	0.58
19	-	-	-	0.49	-	-	0.68	0.45	0.49
20	-	-	-	0.70	0.57	-	0.73	0.69	0.50
21	-	-	0.71	1.3	1.2	-	0.87	0.60	0.44
22	-	-	-	-	1.2	1.15	0.90	0.61	0.52
23	-	-	-	1.50	1.27	-	0.90	0.49	0.50
24	-	-	-	1.40	1.21	-	0.97	0.65	0.53
25	-	-	-	0.92	-	-	0.87	0.82	0.60
26	-	-	-	0.93	0.8	-	0.90	0.73	0.65
27	-	-	-	1.01	0.96	-	0.84	0.70	0.63
28	-	-	-	0.61	0.49	-	0.61	0.78	0.72
29	-	-	-	0.49	0.45	-	0.72	0.73	0.72
30	-	-	-	-	-	-	0.70	0.68	0.60
31	-	-	-	0.87	0.78	-	0.64	0.62	0.60

WELL LOG: MONTHLY WATER REPORT

MONTH: Oct 156191 YEAR: 24

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	Deb	11:12	1	3	/	156191	20	11.71				Reset PLC
2	Deb	9:49			/	156261	153	12.61				
3	Deb				/	156324	152	13.14				
4	Bc	11	1	46	/	156392 ⁶³	15'	13.46				
5	RM	10:10			/	156392	15'	12.32				
6	RM	9:30			/	156458	15 ⁺	12.78				
7	Deb	8:53	1	sp	/	156521	10 ³	13.17				
8	Deb	10:44			/	156588 ⁹	10 ²⁺	13.58				
9	Deb	3:21			/	156598 ⁸	10 ²	11.87	cleaned		1st gate value	
10	Deb	9	1	sp	/	156661	10'	12.88				
11	Deb	9			/	156738 ²	10'	13 ³⁵				
12	RM	9:10			/	156776	10'	13.17				(ON)
13	Deb	3:42			/	156861	5 ²	13.15				
14	Deb	9:18	1	3	/	156861	5 ²	12.58				
15	Bc	12:00			/	156927	5	12.68				
16	Deb	9:44			sp/3	156990	48	13.40	35	63		
17	Deb	9:46	1	Du	/	156998 ⁸	48	12.15	32	67		4hr
18	Deb	8:57			/	157055	46 ⁺	12.73				
19	Deb	9			/	157025 ⁹	45	12.8				
20	RM	8:30			/	157180	40 ³⁺	13.44	31.5			(ON)
21	Deb	10:30	1	sp	/	157183 ³	40 ³	12.04				
22	Deb	9:36			/	157245 ⁹	40 ²	12.63	30.5	66	4	
23	Bc	11:15	1	16	/	157314	40'	12.81		65	4 1/2	
24	Deb	9:03			/	157377	40 ⁺	13.41		63	4	
25	Deb	8:48	1	sp	/	157377	40 ⁺	12.21			4	
26	Deb	8:42			/	157437	40'	12.45				
27	Deb	8:30			/	157497	35 ³	13.20				4/5
28	Deb	10:02	1	sp	/	157525	35 ²	12.37				Du
29	Deb	9:16			/	157575	35 ²⁺	12.58				
30	Deb	9:06			/	157639	35 ¹⁻	13.11		64		
31	Deb	9:35	1	sp	/	157644	35'	12.11				ON

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

MONTH/YEAR

SOURCE NAME: WELL

PHONE: 541-547-3416

2024

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS					METER READING X10
		CONTACT TANK	CXT	BUCKET LEVEL	MIXED CL2	CLEANED BUCKET	FLUSHED LINE	OTHER	
1	RM		1.0	1.9	/				41878
2	BJ		0.4	1.9	/				41881
3 10:15	HF	1.2	0.7	1.9	/				41888
4 9:00	HF		0.5	1.8	/				41889
5 8:05	HF		0.6	1.8	/				41893
6 11am	JT	.8		1.8	/				41895
7 8:30	HF		0.4	1.8	/				41900
8 9:30	HF		0.4	1.8	/				41904
9 9:15	Deb	2.	.2-1.	1gallon	Strait cl2			changed. cl2 please monitor	41919
10 11:5	Deb	3.5	.5	7 to 5				Recd feet through cap tight lens	41926
11 8:15	OC	3.5	1.0	5 to 3				@ 4:52 at cxt @ 1:30 turned down side 3.5 at pump	41936
12 9:15	BC	3.5	3.5		/				41945
13 9:15	RM	3.5	3.5	3 to 1	/				41954
14 9:45	HF	0	2.5	1 to 3	/			✓	41995
15 10:45	HF	0	3	(3)2	/				42007
16 11am	JT	3	1		/			ran at cxt	42011
17 7:30A	BC	2	3.5→2		/				42021
18 7:30A	BC	2	2		/				42035
19 7:40a	HF	2	1.5		/				42042
20 9am	JT	●	3		/			✓ @ cxt	42047
21 9am	JT	—	3	2→1.5	/			✓ ✓	42049
22 9am	JT	—	3		/			✓ ✓	42051
23 8:50	HF	0	1.3	1.5→2	/				42055
24 10:30	HF	1.1	.1	2	/				42064
25 9:30	RM	1.5	.5		/				42067
26 9am	HL		.2		/				42080
27 9am	JT		3		/			✓ ✓	42086
28 9am	JT		3		/			✓ ✓	42090
29 8:40	HF		1.1		/				42091
30 9am	JT		3		/			✓ ✓	42093
31 9	RM		1.0		/				42098