

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: 11/2024

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	.02	-	-	.02
2	-	-	.15	.02	.02	.02	.15
3	.02	.02	.14	0.03	0.03	-	0.03
4	-	-	-	0.03	0.03	-	0.03
5	-	-	-	0.04	0.04	-	0.04
6	-	-	-	0.04	0.04	-	0.04
7	-	-	-	0.04	0.04	-	0.04
8	-	-	-	0.04	0.04	0.06	0.06
9	0.05 m	0.08 m	0.14 m	0.04	0.04	0.06	0.14
10	0.07 m	0.08 m	0.14 m	0.06	0.08	-	0.08
11	-	-	-	0.08	0.09	-	0.09
12	-	-	-	0.04	0.05	-	0.05
13	-	-	-	0.04	0.05	-	0.05
14	-	-	-	0.06	0.07	-	0.07
15	-	-	-	.02	.04	-	.04
16	.04 m	.18 m	.12 m	.04	.02	0.03 m	0.18
17	0.04 m	.11 m	.12 m	0.02	0.02	-	0.02
18	-	-	-	0.03	0.04	-	0.04
19	-	-	-	-	-	-	-
20	-	-	-	-	-	-	-
21	-	-	-	-	-	-	-
22	-	-	-	-	0.03	0.03	0.03
23	0.03	0.03	-	-	-	-	0.03
24	-	0.4	0.4	-	-	-	0.4
25	-	0.4	0.4	0.08	0.08	0.08	0.4
26	-	-	-	0.02	0.03	0.04	0.03
27	0.04	0.06	0.12	-	-	-	-
28	-	-	-	-	-	-	-
29	-	-	-	-	.07	.07	.07
30	.08	.09	.12	.09	.06	.07	.12
31	-	-	-	-	-	-	-

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: Kate Baker

SIGNATURE: [Signature] DATE: 12/2/24

PHONE #: (541) 997 3857 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: 11/2024

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
NM 19:50	0.65	460	312	13.3	4.82	25	YES	98
DC 2 10:50	0.42	↓	201.6	13.9	4.61	24	YES	↓
DC 3 10:51	0.34		163.2	13.9	4.64	24	YES	
NM 4 9:45	0.54		259.2	12.8	4.71	24	YES	
NM 5 9:31	0.49		235.2	12.8	5.00	24	YES	
NM 6 9:57	0.52		249.6	12.2	6.21	24	YES	
NM 7 9:25	0.52		249.6	12.2	5.16	24	YES	
NM 8 9:31	0.45		216	11.7	5.45	24	YES	
DC 9 9:14	0.52		249.6	12.2	4.81	24	YES	
DC 10 9:27	0.62		297.6	12.2	4.69	25	YES	
NM 11 9:36	0.49		235.2	12.8	7.08	42	YES	
NM 12 9:40	0.62		297.6	12.2	6.87	36	YES	
NM 13 9:32	0.68		326.4	12.2	7.35	43	YES	
NM 14 9:20	0.67		321.6	12.2	7.11	43	YES	
NM 15 9:11	0.62		297.6	11.1	7.77	51	YES	
DC 16 10:09	0.49		235.2	11.7	5.14	25	YES	
DC 17 10:11	0.64		307.2	11.7	8.24	61	YES	
NM 18	0.71		340.8	11.1	8.28	61	YES	
NM 19	0.74		355.2	10.6	7.13	43	YES	
NM 20	0.66		316.8	12.8	6.79	36	YES	
NM 21 9:39	0.62		297.6	11.7	7.90	51	YES	
NM 22 9:20	0.61		292.8	12.8	7.35	43	YES	
HE 23 10:20	0.61		292.8	20.0	7.35	22	YES	
HE 24 10:10	0.60		288	16.7	8.16	41	YES	
NM 25 9:46	0.38		182.4	12.8	8.27	59	YES	
NM 26 9:49	0.55		264	10.6	7.73	50	YES	
LB 27 10:09	0.49		235.2	10.6	7.44	43	YES	
JB 28 11:55	0.30		144	9.4	7.53	66	YES	
HE 29 10:00	0.59		283.2	8.9	6.25	81	YES	
DC 30 10:01	0.48		230.4	8.3	8.36	79	YES	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

LIFT STATION

November 2024

	PUMP 1 GALLONS	PUMP 1 HOURS	PUMP 2 GALLONS	PUMP 2 HOURS	LP %	GEN HRS	Alarm Light Test
1	15776253	4058.2	13829138	3799.7	78	426.3	OK
2	15782786	4059.9	13831742	3800.4	79	426.3	-
3	15786327	4060.9	13837356	3801.8	79	426.3	-
4	15789326	4061.7	13841465	3802.9	79	426.3	-
5	15793172	4062.7	13843259	3803.4	79	426.4	-
6	15794854	4063.2	13846529	3804.2	79	426.8	-
7	15797354	4063.8	13847912	3804.5	79	426.8	-
8	15799924	4064.5	13850124	3805.2	79	426.8	-
9	15802503	4065.2	13851935	3805.6	79	426.8	-
10	15806323	4066.2	13853773	3806.1	79	426.8	-
11	15809536	4067.1	13857488	3807.1	79	426.8	-
12	15815079	4068.7	13861801	3808.2	78	427.2	-
13	15818593	4069.7	13865745	3809.2	78	427.3	-
14	15824545	4071.4	13869344	3810.1	78	427.3	-
15	15831905	4073.3	13870813	3810.5	78	427.3	-
16	15837676	4074.4	13874003	3811.6	78	427.3	-
17	15838559	4075.1	13879293	3812.7	78	427.3	-
18	15844714	4076.8	13882532	3813.5	78	427.3	-
19	15848078	4077.8	13886172	3814.5	78	427.5	-
20	15853359	4079.3	13889857	3815.5	73	438.7	-
21	15856744	4080.2	13891960	3816.1	72	439.6	-
22	15860294	4081.1	13895379	3816.7	72	439.6	OK
23	15865391	4082.5	13899012	3817.9	72	439.6	-
24	15867992	4083.2	13903370	3819.0	72	439.6	-
25	15870826	4083.9	13906973	3819.9	72	439.6	-
26	15874022	4084.8	13909327	3820.6	72	439.7	-
27	15876459	4085.5	13912905	3821.5	72	440.1	-
28	15880309	4086.6	13914354	3821.9	72	440.1	-
29					73	440.1	-
30	15886078	4088.2	13918440	3822.9	73	440.1	-
31							
1							

Test the alarm light on the 1st and 15th of every month.

Raw Turbidity

Month/Year

November

2024

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.84		X
2	0.71	X	
3	0.66	X	
4	0.91		X
5	0.95		X
6	0.90		X
7	0.61		X
8	0.95		X
9	0.91		X
10	0.86		X
11	1.11		X
12	0.98		X
13	0.88		X
14	0.93		X
15	0.79		X
16	0.84	X	
17	0.85		X
18	0.96		X
19	0.62		X
20	10.5		X
21	—		X
22	off		X
23	1.45		X
24	0.62		X
25	1.10		X
26	0.85		X
27	0.81		✓
28	0.85		✓
29	0.82		X
30	0.78		X
31			

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

MONTH/YEAR

SOURCE NAME: WELL

PHONE: 541-547-3416

2024

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS					METER READING X10
		CONTACT TANK	CXT	BUCKET LEVEL	MIXED CL2	CLEANED BUCKET	FLUSHED LINE	OTHER	
1 11/1	RM		0.5		/				42104
2 11/2	RM		0.5		/				42111
3 11/3	JT	—	2.0		/		✓ cxt		42113
4 11/4	Be	2.0	1.0		/		✓ cxt		42118
5 11/5	Deb		1		/				42119
6 11/6	HZ		0.75		/				42120
7 8:55	HF	0	.5		/				42121
8 7:15	RM		0.5		/				42130
9 3:30	HZ	0.1			/				42134
10 8:30	HZ		0.3		/				42141
11 9am	JT	1.0	.5	gasket replace on end of			ilost hose	hose was pulled out	42169
12 9:20a	HF	0	.5		/				42171
13	Be	0.3	0.3		/				42177
14	BP	0.2	0.1		/				42184
15	Be	"	0		/				42199
16	RM		0		/				42207
17 9:30am	JT	3	3	Full			✓	Hot shot system + flushed at cxt	42228
18 8:55a	HF	1.5	.8		/				42240
19	Be	1.9	.7		/				42245
20	RM	2.5			/				
21	Be	1.5	1.5		/				42257
22	RM	1.5			/				42259
23 8:30	HZ		.5		/				42263
24 9:00am	JT	2.0	2.0		/		✓ cxt	10 mins	42266
25 8:15a	HF		1.5		/				42269
26	RM		2.0		/				42295
27 8:45	HZ		1.0		/				42299
28 8:45	HZ		1.0		/				42299
29 8:30	HZ		1.0		/				42306
30 8:40	HZ		1.5		/				42311
31					/				



WELL LOG: MONTHLY WATER REPORT

MONTH: Nov

157639

YEAR: 24

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	Db	9:06	1	SP	/	57704	35	12.61		65	4	
2					/							
3	RM	2:30			/	157824	30 ²⁺	13.29				(ON)
4	Deb	10:06	1	SP	/	157834	30 ²	12.61		13000 3-day	4	
5	Deb	9:42			/	157899	30'	13.18		63	4 1/2	
6	RM	1:30			/	157954	30 ⁺	13.30				(ON)
7	Deb	9:51	1	DU	/	157963	30 ⁺	12.89		66	4	
8	Deb	9:40			/	158029	30 ⁻	12.90		66	3.5	Hose left on at DU
9	RM	10:35			/	158092	29 ³⁺	13.40		63		
10	RM	9:00			/	158092	25 ³⁺	12.25				
11	Deb	10:40	1	SP	/	158157	25 ²⁻	12.83		65		
12	Deb	10:05			/	158219	25 ¹	13.44		62	4	
13	Deb	11:05			/	158219	25 ¹	12.34			4	
14	Deb	11:48	1	SP	/	158284	25 ⁺	12.95		65		
15	Deb	1:34			/	158311	25 ⁻	12.63		0		ON
16	Be	8:40	1	2	/	158351	20 ³	12.60		67		
17	RM	3:30			/	158414				63	4	
18	Deb	10:03	1	DU	/	158428	20 ²	12:32		0	4.5	ON
19	Deb	12:02			/	158480	20 ¹	12.56		66	4	
20	Deb	10:56			/	158542	20 ⁺	13.20		62		
21	RM	3:00			/	158542	20 ⁺	12.04		0		
22	Be	10:30	1	2	/	158605	15 ³	12.86		63	4	
23	RM	11:12			/		15 ³⁻	12.60				(ON)
24	RM	11:00			/	158669	15 ²⁺	12.45		64	4	
25	Deb	10:26	1	DU	/	158732	15 ¹⁺	13.17		63	4	
26	Deb	10:49			/	158732	15 ¹⁺	12.10			4	
27	Deb	10:18	1	D2	/	158795	15 ¹⁻	12.71		63	4	
28	HZ	10			/		15	12.92				
29	HZ	1:00			/	158908	14.5	13.01				
30	HF	8:40			/	158931	15 ¹⁻	12.05		23	3	
31					/							

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.