

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: 12/2024

System Name: OPRD JM Honeymen Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	<del>0.03</del>	<del>0.06</del>	<del>0.10</del>	0.01	0.03	-	0.1
2	-	-	-	0.03	0.04	-	0.04
3	-	-	-	0.01	0.02	-	0.02
4	-	-	-	0.01	0.01	-	0.01
5	-	-	-	-	0.01	0.01	0.01
6	-	-	-	0.02	0.02	0.02	0.02
7	<del>0.03</del>	<del>0.03</del>	<del>0.04</del>	0.02	0.02	0.02	0.04
8	<del>0.02</del>	<del>0.03</del>	<del>0.04</del>	0.02	0.02	-	0.02
9	-	-	-	0.03	-	-	0.03
10	-	-	-	0.05	.04	-	0.05
11	-	-	-	0.02	0.01	-	0.02
12	-	-	-	0.05	0.04	-	0.05
13	-	-	-	-	-	-	0
14	-	-	-	-	-	-	0
15	-	-	-	-	-	-	-
16	-	-	-	-	-	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	-	0.01
18	-	-	-	-	-	-	-
19	-	-	-	-	0.19	0.16	0.19
20	0.18	0.18	-	.04	0.01	0.02	0.18
21	0.03	0.11	0.06	.04	<del>0.01</del>	<del>0.02</del>	0.11
22	<del>0.03</del>	<del>0.09</del>	<del>0.06</del>	-	-	-	0.09
23	-	-	-	0.04	0.06	0.07	0.07
24	0.08	0.07	0.09	0.08	-	-	0.09
25	-	-	-	0.09	0.10	-	0.10
26	-	-	-	-	<del>0.09</del> 0.09 <sup>HE</sup>	-	<del>0.09</del> 0.09
27	-	-	-	0.15	0.1	-	0.15
28	-	-	-	0.15	0.1	-	0.15
29	-	-	-	-	-	-	-
30	-	-	-	.4	-	-	-
31	-	.2	.2	0.01	0.01	-	-

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: Nathan Micha SIGNATURE: Nathan Micha DATE: 1-1-25 PHONE #: (541) 999-5615 CERT #:	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: 12/2024

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
DC 1 1002	0.61	480	292.8	8.3	8.68	97	YES	98
M 2 936	0.64		307.2	8.3	8.49	81	yes	
M 3 1025	0.63		302.4	8.9	8.47	81	yes	
M 4 1030	0.66		316.8	8.9	8.25	81	yes	
M 5 1041	0.66		316.8	9.4	8.35	81	yes	
LB 6 952	0.61		292.8	10.6	8.03	63	yes	
DC 7 957	0.70		336.0	11.1	8.41	61	YES	
DC 8 944	0.48		230.4	11.1	8.59	70	YES	
M 9 950	0.80		384	10.6	8.22	63	yes	
HE 10 1000	0.83		399.6	8.3	8.19	87	YES	
LB 11 930	0.72		345.6	8.9	8.20	84	yes	
LB 12 1005	0.79		379.2	8.9	8.26	84	yes	
M 13 1040	0.73		350.4	9.4	8.25	81	yes	
HE 14 1015	0.76		364.8	8.9	8.4	84	yes	
HE 15 1030	0.63		302.4	8.9	8.27	84	yes	
M 16 930	0.54		259.2	9.4	8.65	93	yes	
M 17 937	0.68		326.4	10.6	8.39	61	yes	
M 18 1020	0.63		302.4	10.6	8.34	81	yes	
M 19 933	0.67		321.6	10.0	8.25	81	yes	
LB 20 1045	0.58		278.4	9.4	7.90	68	yes	
DC 21 1022	0.67		321.6	9.4	8.35	81	YES	
DC 22 1007	0.85		408.0	9.4	8.72	100	YES	
LB 23 1010	0.57		273.6	9.4	8.42	81	yes	
M 24 1050	0.66		316.8	12.2	8.78	73	yes	
M 25 1013	0.77		369.6	10.0	8.25	61	yes	
M 26 927	0.62		297.6	11.7	8.62	73	yes	
M 27 949	0.72		345.6	11.7	8.57	73	yes	
HC 28 1050	0.72		345.6	12.2	8.69	75	YES	
HE 29 1038	0.66		316.8	11.7	8.36	63	YES	
HE 30 1050	0.42		201.6	11.7	8.20	61	YES	
PD 3 1102	0.64		307.2	12.8	7.42	43	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

# Raw Turbidity

Month/Year

DECEMBER 2024

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.86		X
2	0.91		X
3	1.01		X
4	0.84		X
5	0.80		X
6	0.48		X
7	1.06		X
8	1.14		X
9	1.00		X
10	0.77		X
11	0.78		X
12	0.71		X
13	intake off		X
14	intake off		X
15	intake off		X
16	intake off		X
17	0.37	X	
18	0.90		X
19	intake off		X
20	0.50		X
21	0.84		X
22	INTAKE OFF		X
23	intake off		
24	<del>intake off 0.36</del> CB		X
25	0.50	X	
26	0.62		X
27	0.74		X
28	0.60		X
29	0.55		X
30	0.46		X
31	0.94		X



# Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of DECEMBER, 2024

			Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	x 748 Gallons Used	Alum Pounds	Chlorine Gallons
1	DC	10:02	833890	91469	77,700	905319	10,300	20910	Ø	2-8	2
2	MM	9:42	833891	92237	76900	905412	9300	20910	Ø	3-12	1
3	MM	10:28	834629		73800	905497	8500	20910	Ø	2-8	1
4	MM	10:23	835343		71400	905583	8600	20910	Ø	2-8	2
5	MM	10:46	836064	72100	<del>152100</del>	905665	8200	20910	Ø	2-8	2
6	LB	9:52	836757		<del>1267300</del>	905757	9200	20910	Ø	Ø	1
7	DC	9:57	837471		73,400	905860	10,300	20912	1496	6-4	3
8	DC	9:44	838188		71,700	905950	9000	20912	Ø	2-8	1
9	MM	9:22	838898		71,000	906036	8600	20912	Ø	2-8	2
10	HE	10:22		93033	79,600	906112	4,600	20912	Ø	Ø	Ø
11	LB	9:30		93791	75,800	906207	8500	20912	Ø	2-8	2
12	LB	10:05		94657	86,600	906300	9,300	20912	Ø	2-8	1
13	MM	10:38		95422	76,500	906386	8600	20912	Ø	2-8	Ø
14	HE	10:15	water off			906473	8,700	20912	Ø	Ø	Ø
15	HE	10:50				906558	8,500	20912	Ø	Ø	Ø
16	MM	9:28				906636	7800	20912	Ø	Ø	Ø
17	MM	9:35		96224	80,200	906717	8100	20912	Ø	7-8	3
18	MM	10:16		97107	88,300	906805	8,800	20912	Ø	2-8	2
19	MM	9:37				906882	7,700	20912	Ø	Ø	Ø
20	LB	10:45		98060	95,300	907059	1,770	20914	1496	11-4	1
21	DC	10:22		98949	88,900	907148	8,900	20914	Ø	Ø	2
22	DC	10:13		99204	25,500	907236	8,800	20914	Ø	Ø	Ø
23	LB	10:40		99300		907332	9,600	20914	Ø	3-12	Ø
24	MM	10:37	838900	99300	9800	907428	9,600	20914	Ø		Ø
25	MM	10:12	839816		91,600	907515	8,700	20914	Ø	7-8	1
26	MM	9:24	840613		79,700	907596	8,100	20914	Ø	3-12	2
27	MM	9:35	841446		83,300	907680	8,400	20914	Ø	3-12	1
28	HE	10:30	842280		83,400	907778	9,800	20914	Ø	Ø	1
29	HE	10:58		100188	88,800	907877	9,900	20914	Ø	5	2
30	HE	10:50	843111		83,100	907974	9,700	20914	Ø	5	2
31	PD	11:02		101059	87,000	908059	10,700	20914	Ø	1-4	2



# Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of DECEMBER, 20 24

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	—	—	—	1.17	1.19	—	.61	.40	.31
2	—	—	—	1.38	1.26	—	0.64	0.33	0.40
3	—	—	—	1.11	1.19	—	0.63	0.31	0.36
4	—	—	—	1.09	1.35	—	0.66	0.31	0.40
5	—	—	—	—	1.39	1.35	0.66	0.22	0.21
6	—	—	—	1.33	1.38	—	0.61	0.26	0.41
7	—	—	—	1.32	1.35	—	0.70	0.56	0.39
8	—	—	—	1.19	1.20	—	0.48	0.54	0.47
9	—	—	—	1.12	—	—	0.83	0.47	0.45
10	—	—	—	1.01	1.12	—	0.72	0.49	0.45
11	—	—	—	1.16	1.12	—	0.79	0.43	0.44
12	—	—	—	1.09	1.11	—	0.73	0.42	0.60
13	—	—	—	—	—	—	0.76 <sup>0.70</sup>	0.40 <sup>0.40</sup>	0.64 <sup>0.50</sup>
14	—	—	—	—	—	—	0.76	0.40	0.64
15	—	—	—	—	—	—	0.63	0.37	0.55
16	—	—	—	—	—	1.35	0.54	0.32	0.62
17	1.15	1.07	1.00	1.01	1.01	—	0.68	0.33	0.70
18	—	—	—	—	—	—	0.63	0.34	0.69
19	—	—	—	—	1.00	1.5	0.57	0.33	0.55
20	1.7	1.7	—	1.50	1.65	—	0.58	0.66	0.60
21	—	—	—	1.52	—	—	0.67	0.59	0.52
22	—	—	—	—	—	—	0.85	0.38	0.59
23	—	—	—	1.58 <sup>mm</sup>	1.25 <sup>mm</sup>	0.89 <sup>mm</sup>	0.57	0.56	0.57
24	0.65 <sup>mm</sup>	—	—	1.58	1.23	0.89	0.78	0.77	0.44
25	0.65	0.55	0.50	1.13	—	—	0.62	0.69	0.44
26	—	—	—	1.16	0.91	—	0.72	0.54	0.49
27	—	—	—	—	0.6	—	0.72	0.36	0.46
28	—	—	—	0.52	0.35	—	0.66	0.37	0.46
29	—	—	—	0.52	0.35	—	0.42	0.36	0.47
30	—	—	—	.30	.70	—	.64	.46	.51
31	—	—	—	0.85	0.88	—	0.64	0.40	0.42



WELL LOG: MONTHLY WATER REPORT

MONTH: Dec YEAR: 2024

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	RM	11				158993	10 <sup>2+</sup>	12.85			4	
2	Deb	1010	1	D2		1589052	10'	13.35			4	ON
3	Deb	1022				159058	10'	12.28			4	
4	bc	900	.5	10		159123	10	12.86				
5		bc 900				159186	5 <sup>3</sup>	13.35			4	
6	Deb	957	.5	D2		1591820	5 <sup>3+</sup>	12.10			4	
7	RM	1026				159251	5 <sup>3+</sup>	12.40			3 1/2	
8	RM	900				159315	5 <sup>2-</sup>	13.08			4	
9	Deb	1102	.8 <sup>+</sup>	15		159352	5 <sup>1+</sup>	12.86				ON
10	HF	9:32				159380	5 <sup>1+</sup>	12.44		65	4	
11	Deb	952				159444	5	13.06		64	3.5	
12	Deb	1018A	.8	22	45/3	159476	4	12.74			3.5	oil in water
13	Deb	1105				159509	4 <sup>3+</sup>	12.35		85	3.5	
14	RM	1106				159574	4 <sup>3+</sup>	12.00		65		
15	RM	12:50	.5	spot		159637	40 <sup>3</sup>	13.24			3	
16	Deb	9:58	.5	25	32.02	159637	40 <sup>3</sup>	12.23		63	3.5	
17	Deb	1014	.5	47		159701	40 <sup>2</sup>	12.83		64	3.5	
18	Deb	1008	.5	47		159765	40'	13.44		64	3.5	
19	RM	1209				159765	40 <sup>1</sup>	12.25				NOT READING??
20	Deb	1122				159831	40 <sup>+</sup>	12.88	PLC reset	66	4	Potential
21	RM	157				159895	40 <sup>-</sup>	13.36		64		Communication
22	HF	8:10a				159895	40 <sup>-</sup>	12.98		1	4	Loss
23	Deb	952	.7			159959	35 <sup>2+</sup>	12.98			4	Alarm was
24	HF	8:20				160013	35 <sup>+</sup>	13.26			4	silenced
25	RM	1100				160024	35 <sup>1+</sup>	12.27		11	3.5	
26	Deb	930				160087	35 <sup>+</sup>	13	Power out	25-125 P on tank		read tank
27	Deb	9143	.7			160097	35 <sup>-</sup>	12.70				ON
28	RM	1000				160152	35 <sup>-</sup>				3.5	
29	RM	1100				160218	35					
30	Deb	1245	1.0			160281	30 <sup>2-</sup>	13.18	1300		4	
31	Deb	1029				160287	30 <sup>-</sup>	12.01			3.5	

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

Heceta Head State Park  
 Monthly Turbidity Report,  
 Public Water Supplies

PWS ID # 4191048A  
 SYSTEM NAME: Heceta Head State Park  
 SOURCE NAME: Well

ADDRESS: 93111 Highway 101 N  
 Florence, OR 97439 MONTH/YEAR  
 PHONE: 541-547-3416 2024

DATE/TIME	INITIALS	C/2 RESIDUAL	CXT / Pump House	COMMENTS	METER READING
1	KM	2.0			42319
8:25 2	HF	1.7	1.3		42320
3					
9:00 4	RM	1.1	2.0		42324
9:00 5	RM	2.0	X		42342
9:15 6	HF	1.6			42343
9:00 7	BC	1.0			42344
9 am 8	JT	2.0		cxt	42346
11 9	"	2.0		cxt	42347
9 am 10	JT	2.0		cxt	42350
10:30 11	Deb	1.0	.7		42350
9 12	RM	1.0			42360
12:00 13	BC	0.6			42361
9:00 14	BC	1			42369
9 am 15	JT	2		@cxt	42371
7:30 am 16	JT	2		@cxt	42375
9:30 17	BC	1.5			42382
18	BC	1.0			42383
19	BC	1.0			42385
9:30 20	Deb	1.3	.5		42393
9:00 21	HF	.7			42394
9 am 22	JT	1		@cxt	42398
8:20 23	HF	.8			42398
9 am 24	JT	1		@cxt	42399
12:30 25	RM	1		@cxt	42407
10:30 26	Deb	1.2			42402
27					
9:15 28	HC	1.0		@cxt	42411
9 am 29	JT	1.0		@cxt	42413
9 am 30	JT	1.0		"	42418
9 am 31	HF	1.1		@cxt	42418

Total -- # days=monthly average

when not producing water.