

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: Feb 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
NM 110:50	0.01	—	—	—	0.01	—	0.01
NM 210:56	—	—	—	—	0.01	—	0.01
HE 310:05	—	—	—	0.01	0.01	—	0.01
HE 411:42	—	—	—	0.05	—	—	0.05
PD 510:40	—	0.01	0.03	0.01	—	—	0.03
NM 69:30	—	—	0.01	0.01	—	—	0.01
NM 79:33	—	—	0.01	0.01	—	—	0.01
NM 810:40	—	—	0.01	0.01	—	—	0.01
NM 910:25	—	—	0.01	—	—	0.01	0.01
KB 1009:52	—	—	—	—	0.01	0.01	0.01
RW 1110:00	—	—	—	0.01	0.01	—	0.01
NM 129:52	—	—	0.01	—	—	0.01	0.01
NM 139:27	—	—	—	0.01	—	—	0.01
NM 149:40	—	—	0.01	—	—	0.01	0.01
NM 1510:20	—	—	—	0.01	0.01	—	0.01
16	—	0.01	0.01	0.06 NM	0.06 NM	0.01 NM	0.01
17	0.02 NM	0.02 NM	0.05 NM	0.06 NM	0.01 NM	0.01 NM	0.01
18	—	—	—	—	—	0.01	0.01
19	—	—	—	0.03	0.05	—	0.05
20	—	—	0.02	—	—	—	0.02
21	—	0.01	—	—	—	0.04	0.04
22	—	—	—	0.04	0.07	—	0.07
23	—	—	—	—	—	—	0.06
24	—	—	—	0.04	0.02	—	0.04
25	—	—	—	0.02	—	—	0.02
26	0.05	—	—	—	—	—	0.05
27	—	—	0.04	—	—	0.04	0.04
28	—	—	—	0.09	—	—	0.09
29	—	—	—	—	—	—	—
30	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes / No

All 4-hour turbidity readings \leq 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

Yes / No

Notes: operator error taking readings when
plant was off. NM
2/16 - 2/18

PRINTED NAME: Nathan Micha

SIGNATURE: Nathan Micha

PHONE #: (541) 999-5615

DATE: 3/6/25

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Feb 2025

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
MM 1 10:54	1.11	480	532.8	8.9	8.63	104	yes	90
MM 2 11:20	1.09		523.2	8.9	8.57	104	yes	
HE 3 10:55	1.15		552	8.9	8.18	89	yes	
HE 4 11:32	1.09		523.2	8.3	8.16	89	yes	
PD 5 10:38	.88		422.4	7.8	7.74	72	yes	
MM 6 9:39	1.00		480	7.2	7.87	72	yes	
MM 7 9:27	0.96		460.8	7.2	7.63	70	yes	
MM 8 10:40	0.93		446.4	7.6	8.27	84	yes	
MM 9 10:26	0.90		432	8.3	8.70	100	yes	
MB 10 09:52	0.83		398.4	7.2	7.89	72	yes	
PL 11	.67		321.6	7.2	8.77	100	yes	
MM 12 9:51	0.79		371.2	8.3	8.66	97	yes	
MM 13 9:30	0.77		369.6	7.2	8.29	81	yes	
MM 14 9:44	0.76		364.8	7.2	8.22	81	yes	
MM 15 10:10	0.63		302.4	7.8	8.38	81	yes	
MM 16 10:26	0.64		307.2	8.3	8.30	81	yes	
PD 17 11:10	.67		321.6	5.6	7.96	70	yes	
PD 18 11:09	.59		283.2	10.0	7.94	51	yes	
MM 19 10:13	0.54		259.2	9.4	8.32	79	yes	
MM 20 9:12	0.56		260.8	9.4	8.13	79	yes	
MB 21 3:31	0.55		264	10.6	7.73	50	yes	
PD 22 11:06	.79		139.2	9.4	7.50	55	yes	
MB 23 10:35	0.65		312	10.6	7.63	51	yes	
PD 24 12:16	.62		297.6	10.8	7.81	51	yes	
LB 25 13:01	.59		283.2	10.6	7.94	51	yes	
MM 26 9:15	0.53		254.4	10.6	7.91	51	yes	
MB 27 11:35	0.51		244.8	11.1	7.71	50	yes	
MM 28 9:30	0.45		216	10.6	7.79	50	yes	
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Raw Turbidity

Month/Year February 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.01		X
2	0.07		X
3	0.88		X
4	0.36	X	
5	.55	X	
6	0.30	X	
7	0.37	X	
8	0.43	X	
9	0.60		X
10	0.64		X
11	.64		X
12	0.37		X
13	0.46		X
14	0.36		X
15	0.71		X
16	0.37		X
17	.41	X	
18	.50		X
19	0.61		X
20	0.61	X	
21	0.52		X
22	.39	X	
23	0.45		X
24	.66	X	
25	.66		X
26	0.49		X
27	0.68		X
28	0.76		X
29			
30			
31			

[illegible]

Free Chlorine Residual in P.P.M. for the Month of February, 2025

[illegible]

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

SOURCE NAME: WELL

PHONE: 541-547-3416

MONTH/YEAR

FEB 2025

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 8:40am	HZ		1.0		/			42528
2 8:46	HZ		1.0		/			42533
3 11:20	HF		1.1		/			42533
4 8:30	HF		1.0		/			42533
5 9:30	RM		.8		/			42541
6 9:30	Be		.7		/			42546
7 10:10	HF		.5		/			42547
8 8:45	HZ		.5		/			42547
9 9am	JT		1	1/3 left	/	✓ ext		42551
10 9am	JT				/			
11					/			
12 9am	JT		1		/	✓ ext		42556
13 10:45	Be		0.6		/			42558
14					/			
15 8:40	HZ		1.5		/	✓ ext		42617
16					/	✓ ext		
17 9am	JT		2.5		/	✓ ext		42622
18 9:00	HF		2.0		/			42623
19 9:30	Be		1.1		/			42628
20 9:00a	HF		2.3		/		Cl ₂ pump → 2.0 from 2.5	42629
21 10:00	Be		2.0		/			42633
22 8:30	HZ		.5		/	✓ ext		42640
23 8:40	HZ		.2		/	✓ ext		42640
24 10:00a	HF		.5		/			42654
25					/			
26 11 A	Deb	1.5		Filled	/	✓		42675
27					/			4
28 9:15a	HF		.8		/			42678
29					/			
30					/			
31					/			

WELL LOG: MONTHLY WATER REPORT

MONTH: Feb

A

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	HF	8:40a	1.0	9		16153	5 ⁺ 1	13.26	35.5		4	
2	HF	8:20a	0.8	shop		161819	5 ⁺					plant on
3	Deb	1041				161819	5 ⁺	12.50			3.5	
4	Deb	1021	1	46	40 ³	161882	45 ²	12.95	6.300		3.5	
5	Deb	1002				161936	45 ¹	13.24			3.5	on
6						162					3.5	
7	Deb	1133	1 ⁺	D2		162058	45	12.61			3.5	on
8	gc	900	1	2		162098	2 ²	12.58				
9	HF	8:20				162161	40 ²	13.15	35.5		3	
10	JT	8:30	1	shop		162165	40 ²	12.10				running
11	Deb	1110				162226	40 ¹	12.59		61		
12	gc	900	1	2		162288	40	13.21				
13	Deb	130				162288	40 ⁺	12.9				line broke
14	Deb	9				162291	40 ⁺	11.10		23		130pm when turned on
15	HF	11:30a				162291	40 ⁺	11.10				make valve to pump off
16	9am	JT				162310	40	9.27				running
17	9am	JT	1	20		162444	35 ⁺ 1	13.11				
18	9	gc	1	2		162530	35 ¹¹	12.22				running
19	1130	Deb				162559	35 ⁺	12.53	38.68	4		checked line 25 gallons
20	1051	Deb	1	D2		162623	35 ⁻	13.11	35.64	3.5		
21	1112	Deb				162638	30 ³	12.34			4	on
22	10	Deb	1	2		162692	30 ³ -	12.59		69	3.5	
23	9am	JT				162754	30 ⁺ 2	13.09				
24	9a	JT	1	shop		162762	30 ⁺ 2	12.19				running
25	830	Deb				162819	30 ¹	13.17	From TANK marks	65		Power 6pm out Am 11:40am
26	10	Deb				162882	30 ⁻	13.21		63	4	Restart on
27	1232	Deb	1	sh		162905	25 ³ +	12.49			4	on
28	1102	Deb				162948	25 ³	12.55		66	4	
29												
30												
31												

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.