

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

LANE

Conventional or Direct Filtration

Month/Year:

4/25

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
MA 1 9:20	—	—	—	0.02	—	—	0.02
PL 2	—	0.02	—	—	0.04	—	0.04
MA 3	—	—	—	0.07	—	—	0.07
4	—	0.08	—	—	0.01	—	0.08
5	—	—	0.01	—	—	0.01	0.01
6	—	—	0.01	0.01	—	—	0.01
7	—	0.01	—	—	0.01	—	0.01
8	—	—	0.01	—	—	0.01	0.01
9	—	—	—	0.02	—	—	0.02
10	0.03	—	—	0.04	—	—	0.04
11	—	0.04	—	—	0.02	—	0.04
12	—	0.03	—	—	0.05	—	0.05
13	—	0.05	—	—	0.01	—	0.05
14	—	0.01	—	—	0.12	—	0.12
15	—	—	0.14	—	—	0.03	0.14
16	—	—	—	0.03	0.03	—	0.03
17	—	—	0.03	—	—	0.03	0.03
18	—	—	—	0.03	—	—	0.03
19	—	0.03	—	—	0.01	—	0.03
20	—	—	0.01	—	0.04	—	0.04
21	—	—	0.03	0.02	—	—	0.03
22	—	0.02	—	—	—	—	0.02
23	—	—	—	0.01	—	—	0.01
24	—	0.01	—	—	0.01	—	0.01
25	—	0.01	—	—	0.09	—	0.09
26	—	0.09	—	—	—	—	0.09
27	—	—	—	—	—	—	—
28	—	0.07	0.07	0.12	0.04	—	0.12
29	—	—	0.09	0.15	0.09	—	0.15
30	—	—	0.05	0.04	—	—	0.05
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes/No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings < IFE² triggers

Yes/No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes/No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes/No

Notes: Datachart paperless data recorder failure
on 4/27/2025 - moved to manual operation & 4
hour readings on 4/28/2025.

PRINTED NAME: Kati Baker

SIGNATURE: *Kati Baker*

DATE: 5/2/25

PHONE #: (541) 997-3057

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: April 2025

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
MM 1 9:24	0.40	480	192	10.6	7.73	50	yes	98
DC 2 10:56	0.39		187.2	11.1	7.96	50	yes	
MM 3 9:09	0.49		235.2	11.1	7.83	50	yes	
MM 4 9:08	0.45		216	11.1	7.94	50	yes	
PD 5 12:00	.48		230.4	11.9	7.21	43	yes	
DC 6 9:12	0.50		240	11.9	7.68	50	yes	
MM 7 10:47	0.81		300.8	11.7	7.52	53	yes	
MM 8 9:19	0.89		427.2	11.7	7.47	44	yes	
MM 9 9:10	0.85		408	12.2	7.55	53	yes	
MM 10 8:58	0.81		308.8	12.8	7.38	44	yes	
MM 11 9:02	0.74		355.2	12.5	7.35	43	yes	
MS 12 9:30	0.74		355.2	12.8	7.41	43	yes	
MS 13 9:25	0.79		379.2	12.2	7.46	43	yes	
HB 14 09:50	0.75		360	12.8	7.74	51	yes	
LB 15 11:35	0.83		398.4	13.3	7.44	44	yes	
MM 16 11:42	0.87		417.6	12.9	7.16	53	yes	
MM 17 9:01	0.87		417.6	12.8	7.63	53	yes	
MM 18 9:07	0.86		412.8	12.8	7.95	57	yes	
DC 19 10:11	0.81		388.8	13.3	7.35	44	yes	
PD 20 10:39	.74		355.2	12.8	7.42	44	yes	
MM 21 10:00	0.72		345.6	12.6	7.55	51	yes	
LB 22 10:04	0.68		326.4	12.8	7.28	44	yes	
DC 23 10:20	0.51		244.8	12.8	7.79	51	yes	
DC 24 9:07	0.54		259.2	13.3	7.61	51	yes	
DC 25 9:32	0.47		225.6	13.3	7.68	51	yes	
HE 26 09:49	0.39		187.2	13.3	7.59	50	yes	
HE 27 09:45	0.37		177.6	13.3	7.70	50	yes	
LB 28 09:05	0.30		144	12.8	6.63	29	yes	
PD 29 12:02	.37		177.6	13.3	6.49	29	yes	
LB 30 09:10	.58		278.4	13.3	6.58	29	yes	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmcce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of

April

20 25

[illegible]

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of

April

20 25

[illegible]

Raw Turbidity

Month/Year

April 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.95		X
2	1.24		X
3	1.14		X
4	1.01		X
5	.94		X
6	1.14	X	
7	0.87		X
8	1.06	X	
9	1.26		X
10	1.31		X
11	1.34		X
12	0.92		X
13	0.80		X
14	1.20		X
15	1.15		X
16	0.99	X	
17	0.79		X
18	1.19		X
19	1.26		X
20	1.49		X
21	1.47	X	
22	0.88		X
23	0.99		X
24	1.02		X
25	1.45		X
26	1.85		X
27	0.89		X
28	1.17 1.05 ⁹²	✓	
29	1.85	✓	
30	1.25	✓	
31			

WELL LOG: MONTHLY WATER REPORT

MONTH: APRIL

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	LL	8:45	1			164540	40 ¹	12.09		45	2.5	
2	Be	9:15	1	53		164611	40	12.39				
3	Be	8:40	1	2		164678	35 ¹³	12.78				
4	Be	10:15	1	D1		164744	35 ¹²	12.92		46		
5	Be	10:30	1	7		164809	35 ¹¹	13.17			3	
6	LL	11:22	1	2		164876	35 ¹	13.19	26	67	2.5	
7	LL	12:05				164910	35	12.77		34	3	
8	CM	10:25	1	76		164944	30 ¹³	12.52				
9	CM	10:10	.5	8		165009	30 ¹²	12:89				
10	Be	10:00	.8	58		165074	30 ¹²	13.08				On 3/6/25 4:20pm
11	Be	3:30 pm	.9	2		165142	30 ¹¹	13.15				On 3/6/25 8:45Am
12	CM	10:45AM	1.5	2		165142	30 ¹¹	12.11				
13	LL	10:06am				165210	30	12.5		68	3	
14	LL	11:18am	.7	D2		165277	30 ¹	12.65		67	3	
15	Be	10:00A	1.0	71		165342	25 ²	12.90				
16	CM	9:47AM	.5	D2		165404	25 ¹	13.17				
17	CM	10AM	.75	07		165421	25 ¹	12.35			4	
18	Be	11:20am	.05	2		165472	25	12.28			4	
19	Be	9am				165538	20 ¹³	12.94				
20	LL	11:16am	.7	D2		165601	20 ¹²	13.08		63	3.5	
21	LL	9:37a				165623	20 ²	12.48			3.5	
22	CM	10:20	1.0	58		165670	20 ¹¹	12.49			3.5	
23	Be	9:30A	1.0	2		165737	20	12.93				
24	Be	8:45	1	Be		165801	15 ¹³	13.39				
25	LL	10:35A	.6	D2		165801	15 ¹³	12.06		64		
26	CM	12:05	.5	07		165866	15 ¹²	12.44				
27	LL	11:29A				165931	15 ¹¹	12.77			4	
28	ST	9am	1	20		165994	15	13.28				
29	CM	12pm	1	20		166043	15 ¹²	13.02				
30	CM	10:45	.05	01		166064	15 ¹	12.39				
31												

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

SOURCE NAME: WELL

PHONE: 541-547-3416

April

MONTH/YEAR
2025

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 9:55	BC		1.1	6.11	/	✓		42819
2 9:00a	HF		1.1		/			42824
3 9:05a	HF		.5		/			42824
4 8:50a	HF	1.2	.4		/			42831
5 8:50a	LC		.3		/			42836
6					/	✓		
7					/	✓		
8 9am	JT		1.0	7/8	/	✓		42845
9					/			
10 BC	1045		1		/			42860
11 BC	10		1		/			42862
12 10:00am	LC		.9		/			42866
13 11am	JT		1	7/8	/	✓		42872
14					/	✓		
15 9am	JT		1	~7/8	/	✓		42881
16 1000	BC		0.8		/	✓		42895
17					/			
18 8:45	HF		1.2		/			42905
19 945	BC		1.0		/			42907
20 9am	JT		1		/	✓		42911
21 9:15	BC		+		/			
22 945	DR		1		/			42920
23 9:19	CM		1.2		/			42920
24 8:35	HF	.8			/	✓		42921
25 950	BC	.6			/	✓		42931
26 1130	BC				/			42932
27 9am	JT	1	~	7/8	/	✓		42939
28					/			
29 945	BC	1			/			42952
30 1000	BC	.8			/			42955
31					/			