

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

LANE

Conventional or Direct Filtration

Month/Year:

May 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.012	—	—	—	.015	—	0.01
2	—	.01	—	—	.005	—	0.01
3	—	—	.01	.01	—	.01	0.01
4	—	—	—	.015	.015	—	0.015
5	—	0.012	—	—	0.015	—	0.015
6	—	—	—	0.015	—	—	0.015
7	0.015	—	—	0.01	—	—	0.015
8	0.01	—	—	0.01	—	0.015	0.015
9	—	—	—	0.01	—	—	0.01
10	.01	—	—	0.01	—	—	0.01
11	.01	—	—	0.01	—	—	0.01
12	0.01	—	—	0.01	—	—	0.01
13	—	0.01	—	—	0.01	0.01	0.01
14	—	—	—	0.01	—	—	0.01
15	0.01	—	—	0.02	—	—	0.02
16	—	0.02	—	—	.002	—	0.02
17	—	.02	—	—	.015	.015	0.015
18	—	—	—	.015	—	0.01	0.015
19	—	—	—	0.01	—	—	0.01
20	—	0.01	—	—	0.01	—	0.01
21	—	0.01	—	—	0.015	—	0.015
22	—	0.015	—	—	0.015	—	0.015
23	—	0.015	—	—	0.01	—	0.015
24	0.015	—	—	0.015	—	0.01	0.015
25	—	—	—	0.01	0.01	—	0.01
26	0.01	—	—	0.01	—	—	0.01
27	—	0.01	—	0.01	0.01	—	0.01
28	0.01	0.01	—	—	0.01	—	0.01
29	—	0.01	—	—	0.01	—	0.01
30	—	0.01	—	—	0.01	—	0.01
31	—	—	—	—	0.01	—	0.01

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes / No

All 4-hour turbidity readings \leq 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME:

Nathan Michy

SIGNATURE:

Nathan Michy

DATE:

PHONE #: (541) 444-5615

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: May 2015

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T) *	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
LB 1 0945	0.57	480	273.6	13.3	6.60	36	yes	98
LB 2 0916	0.52		249.6	13.9	6.46	30	yes	
MB 3 9:20	0.64		307.2	13.9	6.37	31	yes	
MB 4 1030	0.57		273.6	13.3	6.41	30	yes	
MM 5 3:30	0.57		273.6	13.9	6.36	36	yes	
MM 6 9:16	0.50		240	13.9	6.36	36	yes	
MM 7 9:25	0.50		240	13.3	6.41	36	yes	
MM 8 9:59	0.51		244.8	13.9	6.36	30	yes	
MM 9 9:15	0.64		307.2	14.1	6.39	30	yes	
DC 10 8:58	0.49		235.2	12.8	6.40	30	yes	
DC 11 9:07	0.42		201.6	13.3	6.39	30	yes	
MM 12 9:05	0.63		302.4	14.4	6.36	30	yes	
MM 13 8:51	0.60		288	15.0	6.35	20	yes	
MM 14 8:47	0.64		307.2	14.4	6.41	30	yes	
MM 15 9:04	0.55		264	15.6	6.37	20	yes	
MM 16 8:50	0.61		292.8	14.4	6.33	30	yes	
PD 17 14:14	0.60		288	13.3	6.27	30	yes	
PD 18 15:48	0.47		225.6	14.4	6.27	30	yes	
MM 19 9:01	0.58		278.4	13.9	6.30	30	yes	
MM 20 9:01	0.58		278.4	13.3	6.35	30	yes	
MM 21 9:37	0.42		201.6	14.4	6.41	24	yes	
MB 22 10:15	0.41		196.8	13.9	6.31	29	yes	
MB 23 11:50	0.43		206.4	13.3	6.30	30	yes	
MB 24 9:20	0.49		235.2	13.3	6.36	30	yes	
MB 25 10:17	0.42		201.6	15.6	6.38	20	yes	
MM 26 9:19	0.41		196.8	16.7	6.32	20	yes	
MM 27 9:21	0.49		235.2	16.1	6.31	20	yes	
RW 28 8:32	0.65		312	15.0	6.39	20	yes	
RW 29 9:00	0.78		374.4	15.0	6.68	24	yes	
MM 30 9:09	0.83		398.4	15.6	6.45	20	yes	
ME 31 10:08	0.97		465.6	16.1	6.24	21	yes	

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmcce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of May, 2025

			Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	Gallons Used	Alum Pounds	Chlorine Gallons
1	LB	0945	122243	860317	32,000	921630	15,500	20975	3,740	5	0
2	LB	0916		860866	22,900	921776	14,600	20983	2,244	2-8	1
3	MB	0920		861058	19,200	921912	13,600	20985	1,496	2-8	1
4	KB	1030		861295	22,700	922093	18,100	20990	3,740	2-8	0
5	MM	3:28	122375	861554	40,100	922257	16,400	20992	1,496	2-8	0
6	MM	8:58	122538		16,300	922360	10,300	20993	748	2-8	1
7	MM	9:20	122827		28,900	922522	16,200	20998	3,740	2-8	1
8	MM	8:55	123085		25,800	922673	15,100	21001	2,244	2-8	0
9	MM	9:11	123350		26,500	922866	19,300	21004	2,244	2-8	1
10	DC	8:59	123634		28,400	923026	16,000	21007	2,244	1-4	1
11	DC	9:07	123898		26,400	923195	16,900	21009	1,496	1-4	0
12	NM	9:00	124168		27,000	923349	15,400	21011	1,496	1-4	0
13	MM	8:46		861779	22,500	923462	11,300	21011	0	1-4	0
14	MM	8:43		861918	13,900	923589	12,700	21014	2,244	1-4	1
15	MM	8:55		862171	25,300	923728	13,900	21016	1,496	0	0
16	MM	8:42		862404	23,300	923868	14,000	21017	748	2-8	1
17	DD	14:15		862673	23,900	924073	20,500	21019	1,496	2-8	1
18	DD	15:48		862948	31,500	924262	18,900	21022	2,244	2-8	0
19	MM	9:54		863079	12,100	924375	11,300	21025	2,244	2-8	0
20	MM	8:52	124467		29,900	924513	13,800	21026	748	1-4	1
21	MM	9:31	124712		24,500	924669	15,600	21028	1,496	1-4	0
22	MB	10:15	124959		24,700	924814	14,500	21030	1,496	1-4	1
23	MB	11:50	125200		24,100	924992	17,800	21032	1,496	1-4	0
24	MB	9:20	125495		28,500	925199	20,700	21034	1,496	2-8	0
25	MB	10:17	125891		40,600	925344	34,500	21038	2,992	3-12	1
26	NM	9:08	126341		45,000	925849	30,500	21041	2,992	3-12	0
27	MM	9:16		863388	30,900	926032	18,300	21043	1,496	1-4	1
28	RW	9:35		863628	24,000	926205	21,800	21046	2,244	2-8	1
29	RW	9:00		863860	23,200	926357	15,200	21048	1,496	2-8	1
30	MM	9:01		864092	23,200	926507	15,000	21050	1,496	1-4	0
31	RG	1008		864378	28,600	926735	22,800	21052	1,496	0	0

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of May, 2025

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H'Sec	Cleawox	E Woahink
1	1.1	—	—	—	1.16	—	0.57	0.43	0.26
2	—	1.24	—	—	1.35	—	0.52	0.42	0.38
3	—	—	1.12	1.12	—	1.15	0.64	0.50	0.35
4	—	—	—	1.10	1.24	—	0.57	0.53	0.36
5	—	1.24	—	—	1.24	—	0.50	0.51	0.42
6	—	—	—	1.24	—	—	0.52	0.47	0.39
7	1.20	—	—	1.32	—	—	0.50	0.43	0.32
8	1.36	—	—	1.36	—	1.40	0.51	0.35	0.38
9	—	—	—	1.40	—	—	0.64	0.62	0.29
10	1.21	—	—	1.35	—	—	0.49	0.40	0.26
11	1.34	—	—	1.32	—	—	0.42	0.42	0.28
12	1.28	—	—	1.36	—	—	0.63	0.44	0.25
13	—	1.20	—	—	1.20	1.24	0.60	0.46	0.29
14	—	—	—	1.32	—	—	0.64	0.49	0.31
15	1.16	—	—	1.28	—	—	0.55	0.47	0.34
16	—	1.24	—	—	1.30	—	0.61	0.44	0.31
17	—	1.32	—	—	1.29	1.24	0.60	0.44	0.37
18	—	—	—	1.35	—	1.28	0.47	0.58	0.49
19	—	—	—	1.24	—	—	0.58	0.54	0.34
20	—	1.2	—	—	1.48	—	0.58	0.50	0.37
21	—	1.4	—	—	1.36	—	0.42	0.47	0.37
22	—	1.2	—	—	1.44	—	0.41	0.40	0.52
23	—	1.4	—	—	1.4	—	0.43	0.41	0.38
24	1.4	—	—	1.44	—	1.32	0.49	0.38	0.28
25	—	—	—	1.48	1.28	—	0.48	0.39	0.32
26	1.2	—	—	1.40	—	—	0.41	0.34	0.27
27	—	1.6	—	1.90	1.90	—	0.49	0.32	0.19
28	—	1.90	—	—	1.90	—	0.65	0.36	0.23
29	—	1.90	—	—	1.90	—	0.78	0.56	0.33
30	—	1.60	—	—	1.98	—	0.83	0.53	0.37
31	—	—	—	—	1.9	—	0.97	0.50	0.50

0.68

Raw Turbidity

Month/Year May 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.93		✓
2	1.29		✓
3	1.99	✓	
4	1.24	✓	
5	1.31		+
6	1.13		X
7	1.22		+
8	1.26		+
9	1.23		+
10	1.66		X
11	1.21		X
12	1.24		+
13	1.03		+
14	1.40		+
15	1.08		+
16	1.21		X
17	1.39		X
18	1.15		X
19	0.99		X
20	0.91		+
21	1.03		X
22	0.85		X
23	0.85		X
24	1.03		X
25	0.99	✓	
26	0.90		X
27	1.23		+
28	.95		✓
29	.98		✓
30	0.97		+
31	0.95		✓

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

SYSTEM NAME: HECETA HEAD STATE PARK

SOURCE NAME: WELL

ADDRESS: 93111 HWY 101 N

FLORENCE, OR 97439

PHONE: 541-547-3416

Man

MONTH/YEAR
2025

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1								
2								
3 1010	Be		1	6/8		✓		42970
4 10am	JT		1			✓		42975
5								
6 925	Be		1.5			✓		4330700
7	Be		1.5			✓		43014
8								
9 1000	CM		1.75			✓		43116
10								
11 10am	JT		1	2/3		✓		43026
12 430a	LL		.8			✓		43039
13 Be	930		.7					43036
14 935	Be		.8					43038
15 915	Be		.9			✓		43042
16 910 ^{AM}	CM		1.5	0.50		✓	0	04346
17								
18 9am	JT		2	.5		✓	Hot shot tank	43054
19 9:30	HF		1.7			✓		43068
20 1000	Be		1.0					43069
21 945	Be		1.0					43077
22 8:45	HF		1.6			✓		43095
23 1030	Be		1.0					43096
24								
25 10am	JT		.75	~ 1/2		✓		43100
26 9:45	HF		.9					43103
27								
28 10am	JT		.8	~ 1/2		✓		43110
29 10030 ^{AM}	Or		1.5	1/4				43111
30								
31 10a	LL		.7					43126

6/1 JT .5 1/3 ✓

43131

WELL LOG: MONTHLY WATER REPORT

MONTH: May

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	DL	9:00	1	2		166130	10 ¹²	12.96	31.5		4.5	
2	HF	8:25	1	2		166195	10 ⁺¹	13.46	30.5	65	4	
3	BE	9:38				166270	10	12.88				
4	LL	12pm	1	D2		166335	10 ⁻¹	12.81	24.5	65	3.5	ADA shower on over 1st night
5	HF	11:19	1.2	C11		166398	10 ⁻²	13.06	23.5	63	3.5	
6	CM	1008pm	.5	08		166427	5 ⁺²	12.61		39	3.5	
7	DL	9:45	1.3	54		166468	5 ⁺¹	12.37				
8	HF	10:20	1.1	D2		166534	5	12.81	31	66	4	
9	DL	9:26			40	166598	43	13.11				
10					3							
11	LL	10:50A	1	D2		166666	40 ⁺¹	12.37				Not filled cut
12	HF	10:26am	.8	C		166738	40	12.99	29	62	4	
13	LL	9:51a	.7	D1		166804	40 ⁻¹	13.01	32.5	66	4	
14	CM	11:10AM	.5	D2		166879	4-1/2	13.35		75	4	
15	HF	9:41a	.9	C		167003	35	12.19	15.5	124	1	
16	CM	10:10	1	D2		167068	30 ⁺⁴	12.70	16	65		
17	DL	12:19pm	.9	D2		167132	30 ⁺²	12.86	32.5	64	4	
18	LL	9:22a				167200	30 ⁺¹	13.47	31	68	3.5	
19	LL	1201p	.7	D2		167225	30 ⁻¹	12.53		29		
20	DL	1030	.8	71		167267	30	12.48				
21	DL	11	1	53		167332	25 ⁺³	12.92				
22	DL	11	1	46		167378	25 ⁺²	13.37				
23	DL	1030	1	2		167398	25 ⁺²	12.79				
24	DL	11				167464	25 ¹	12.47				
25	LL	10:03am	.7	D2		167535	25 ¹	12.79	21.5	61	3.5	
26	JT	9am	1	shop		167605	20 ⁺³	13.00				
27	CM	10AM	.5	76		167669	20 ⁺³	12.98	23	64	3.5	
28	CM	9:30pm	.1	26		167732	20 ⁺¹	13.17	27	63	3.5	
29	JT	9am	1	30		167753	20 ⁺¹	12.46				
30	HF	9:40	.6	C		167804	20	12.43	31.5	51	4	running
31	CM	11:30	1	D1		167872	15 ⁺³	12.51	17	68	3.5	

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

Updated: December 2023

Carl G Washburne MU\Washburne MU Operations\water info\W