

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: June 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	0.01	—	—	0.01	—	0.01
2	—	—	0.01	—	—	0.01	0.01
3	—	—	—	0.01	—	0.01	0.01
4	—	—	—	0.01	—	0.01	0.01
5	—	—	—	0.015	—	0.015	0.015
6	—	—	—	0.01	—	0.01	0.01
7	—	—	0.01	0.01	—	0.01	0.01
8	—	—	0.015	0.015	0.015	0.015	0.015
9	—	—	—	0.015	—	0.02	0.02
10	—	—	—	0.01	0.01	—	0.01
11	0.01	—	—	0.01	0.01	—	0.01
12	—	—	0.015	—	0.01	0.01	0.015
13	—	—	0.01	0.015	—	0.01	0.015
14	0.01	—	—	—	0.01	—	0.01
15	—	0.01	—	0.01	0.01	—	0.01
16	—	—	0.01	—	0.01	0.01	0.01
17	—	—	0.01	—	0.01	—	0.01
18	—	—	0.01	—	0.01	—	0.01
19	—	—	0.01	0.01	—	0.015	0.015
20	—	—	—	0.01	0.01	—	0.01
21	—	0.01 ^{MB}	—	0.01	0.01	—	0.01
22	0.01	—	—	0.01	0.01	—	0.01
23	—	0.01	0.01	—	0.01	0.015	0.015
24	0.02	—	—	0.01	0.015	—	0.015
25	—	—	0.01	—	0.015	0.02	0.02
26	—	—	—	0.01	—	—	0.01
27	0.01	—	—	0.01	0.01	0.01	0.01
28	—	—	—	0.01	0.01	0.01	0.01
29	—	—	0.01	0.01	0.015	—	0.015
30	0.015	—	—	0.01	0.01	—	0.01

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes / No

All 4-hour turbidity readings \leq 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

PHONE #:

DATE: 7-1-25

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: June 2025

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
HE ₁ 14:44	0.87	480	417.6	16.7	6.24	21	yes	98
PD ₂ 16:13	0.93		446.4	17.2	6.30	21	yes	
HE ₃ 18:38	0.93		446.4	16.1	6.32	21	yes	
NM ₄ 10:21	0.91		436.8	16.7	6.35	21	yes	
NM ₅ 9:15	0.61		292.8	16.7	6.37	20	yes	
NM ₆ 8:51	0.47		225.6	16.1	6.40	20	yes	
NM ₇ 9:30	0.45		216	16.7	6.36	20	yes	
QW ₈ 10:00	.46		220.8	16.7	6.41	20	yes	
VB ₉ 14:31	0.33		158.4	17.2	6.37	20	yes	
VB ₁₀ 10:10	0.39		187.2	16.1	6.32	20	yes	
NM ₁₁ 11:33	0.55		264	17.2	6.36	20	yes	
NM ₁₂ 10:30	1.03		444.4	17.2	6.33	20	yes	
NM ₁₃ 11:57	1.17		561.6	17.2	6.35	21	yes	
NM ₁₄ 11:32	1.08		518.4	17.8	6.36	21	yes	
VB ₁₅ 12:00	1.05		504	16.1	6.28	21	yes	
VB ₁₆ 12:44	1.04		499.2	16.1	6.28	21	yes	
QW ₁₇ 9:15	1.0		480.0	16.1	6.36	21	yes	
NM ₁₈ 1:10	0.83		398.4	15.6	6.33	20	yes	
NM ₁₉ 11:07	0.77		369.6	16.7	6.31	20	yes	
NM ₂₀ 12:30	0.72		345.6	17.8	6.36	20	yes	
MB ₂₁ 10:20	0.56		268.8	15.6	6.38	20	yes	
MB ₂₂ 10:15	0.61		268.8	15.6	6.38	20	yes	
VB ₂₃ 15:00	0.48		230.4	16.1	6.24	20	yes	
VB ₂₄ 11:55	0.54		259.2	17.2	6.21	20	yes	
NM ₂₅ 10:40	0.44		211.2	17.8	6.33	20	yes	
NM ₂₆ 11:38	0.72		345.6	16.3	6.32	20	yes	
MB ₂₇ 10:30	0.81		388.8	16.7	6.33	20	yes	
MB ₂₈ 9:30	0.95		456	17.2	6.28	21	yes	
MB ₂₉ 10:05	1.05		504	17.8	6.27	21	yes	
VB ₃₀ 14:20	1.21		580.8	18.3	6.33	22	yes	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov, 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of June, 2025

Date	Initial	Time	Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
			126,341 Meter Reading	864,378 Meter Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	21052 Meter Cubic Ft	x748 Gallons Used	Alum Pounds	Chlorine Gallons
1	HE	1444		864,687	309,000	927,022	28,700	21052	1496	5	0
2	PD	16:13	126341	864990	30,300	927211	18,900	21056	1496	3-12	2
3	HE	1638	126497		15,600	927,451	24,000	21059	2,244	0	0
4	NM	10:16	126795		29,800	927,542	9,100	21063	2,992	3-12	0
5	NM	9:05	127089		29,400	927721	17,900	21067	2,992	2-8	0
6	NM	8:43	127375		28,600	927908	18,700	21071	2,992	2-8	1
7	NM	9:25	127713		33,800	928168	26,000	21075	2,992	2-8	0
8	RW	1000	128155		44,200	928497	32,900	21078	2,244	1-4	1
9	VB	1431	128555		40,000	928801	30,400	21082	2,992	3-12	0
10	VB	1040		865193	20,300	928967	16,600	21083	748	0	1
11	NM	11:24		865500	30,700	929171	20,400	21085	1496	5	1
12	NM	10:34		865785	28,500	929340	16,900	21087	1496	3-12	1
13	NM	11:30		865990	20,500	929552	21,200	21089	1496	3-12	1
14	NM	11:21		866325	33,500	929816	26,400	21091	1496	2-8	0
15	VB	1220		866704	37,900	930140	32,400	21094	2,244	3-12	2
16	VB	1214		867060	35,600	930372	23,200	21096	1,496	3-12	0
17	RW	9:15	128847		29,200	930563	19,100	21098	1,496	1-4	1
18	NM	12:57	129193		34,600	930833	27,000	21102	2,992	2-8	0
19	NM	11:05	129476		28,300	931018	18,500	21104	1,496	3-12	1
20	NM	12:24	129725		24,900	931276	25,800	21107	2,244	3-12	0
21	MB	10:20	130069		34,400	931473	19,700	21109	1496	2-8	1
22	MB	10:15	130362		29,300	931698	22,500	21111	1496	2-8	0
23	VB	1500	130728		36,600	931992	29,400	21115	2,992	3-12	0
24	VB	1155		867308	24,800	932216	22,400	21119	2,992	2-8	1
25	NM	10:30		867665	35,700	932433	21,700	21122	2,244	3-12	1
26	NM	11:27		867943	27,800	932700	26,700	21126	2,992	3-12	1
27	MB	10:30		868252	30,900	932942	24,200	21130	2,992	1-4	1
28	MB	9:40		868594	34,200	933241	29,900	21136	4,488	2-8	0
29	MB	10:05		868905	39,100	933575	33,400	21138	1496	3-12	1
30	VB	1420		869347	36,200	933888	31,300	21142	2,992	5	1
31											

T=67,320

Free Chlorine Residual in P.P.M. for the Month of June, 20 25

[illegible]

Raw Turbidity

Month/Year June 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.91	X	
2	1.01		X
3	1.06	X	
4	1.07	X	
5	0.97		X
6	1.04		X
7	0.77	X	
8	0.80	✓	
9	1.01		✓
10	0.79	✓	
11	1.22		X
12	0.77		X
13	0.75	X	
14	0.81	X	
15	0.78	X	
16	1.40		✓
17	1.30	✓	
18	0.64		X
19	0.58	X	
20	0.59	X	
21	0.73		X
22	0.64		X
23	1.01	X	
24	0.50	X	
25	0.70		X
26	0.46	X	
27	0.44	X	
28	0.42	X	
29	0.48	X	
30	0.44	X	
31			

WELL LOG: MONTHLY WATER REPORT

MONTH: JUNE

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	W	10:51a	.7	D2		167943	15+2	12.5	25.5	61	4	
2	JT	9am				168007	15+1	13.12		61		
3	W	10:20a				168077	15+1/2	13.47	33	70		
4	HF	9:25	.7	D2		168077	15	12.14			4	
5	HF	10:20	.9	D2		168144	10+3	12.42		67	4	
6	CM	1030	.5	53		168211	10+3	12.86		57	3.5	
7	LL	11				168265	10+1	12.68		59	?	nothing in chest
8	LL	10:39	.6	D2		168338	10+1	13.04		73		started was still on 6/5
9	W	11am				168401	5+3	12.20		63		
10	CM	11:15	.5	D2		168464	5+2	12.95	23	63	3 1/2	
11	CM	10AM	.5	D1		168528	5+1	13.11	36	36	3.5	
12	Be	1120	.8	3		168592	5	13.05				
13	CM	1015	.8	74		168654	45+2	13.18	62	4		
14	Be	1012	.9	19		168669	45+1	12.08				
15	JT	11am	1	shop		168745	45	12.08				
16	JT	10:30				168816	40+3	12.40				
17												
18	CM	9AM	.7	A Bathroom		168959	40	12.69		143		
19	Be	1038	1.0	21		169031	35+3	12.64				
20	W	9:54a				169103	35+2	12.9		72		
21	Be	12:00	1.0	21		169169	35+1	12.74		66		
22	W	10:29a				169235	35	12.91		66	3.5	
23	W	9:59a	.7	D1		169302	35+1	13.01		67	4	
24	CM	1155	.5	D1		169369	30+2	12.76		67	3.5	
25	Be	1039	.8	71		169435	30+1	12.93				
26	Be	1148	1	2		169499	30	12.87				
27	JW	9:20	.5	D1		169563	25+3	13.11		64	4	
28	CM	10:45	.5	D1		169629	25+3	12.82		66	4	
29	W	9:59a				169695	25+1	12.94		69	4	
30	LL	10:09a	.3	D1		169766	25+1	12.93		68	4	
31	W	11:19a				169835	25	12.78		69	4	

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

Updated: December 2023

Carl G Washburne MU\Washburne MU Operations\water info\W

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

SOURCE NAME: WELL

PHONE: 541-547-3416

MONTH/YEAR
2025

June

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1	JT		.5	1/3				43131
2 9:30	HF		.9					
3 9:30	JT	2	2	1/3		✓	Hot shot tank	43142
4 9 am	JT		1	1/3		✓		43154
5 9:20 am	SD			0				
6 9:15 a	HF	1.2	.5	1/3				43159
7 9:30	CM		.5	1/3				43159
8 9:30 am	JT		.75	1/3		✓		43166
9 9:55 am	CMC		.5	1/3				43172
10 3:52 am	CMC		.3	1/3				43196
11								43197
12								
13 10:03	CM		.7	1/3		✓		43197
14 11:30	CM		.5	1/8		✓		43201
15 9:35	SD		.5	1/8		✓		4321
16 10:04	CM		.5	1/8				43215
17 11	LL		1	1/9		✓		43218
18 10:55	Be		.7					43228
19 9:10	SD		.5	1/9		✓		43236
20 9:30	TM		.6	1/8		✓		43236
21 11:15 a	CM		.4	1/9		✓		43242
22 9:20	SD		0	1/9		✓		43247
23 9:05	CMC		0	1/9				43251
24 9:10	SD		0	1/9		✓		43263
25 10 am	SD		0	1/9		✓		43270
26 9:30 am	CM		0	1/9		✓		43270
27 10:30	SD		1.0	1/9		✓		43282
28								43311
29 SD 11:30			1.0	1/9		✓		43325
30 9 am	SD		1.0	1/9		✓		
31								