

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: July 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	0.02	—	—	0.015	0.02
2	0.015	—	—	0.015	0.01	0.01	0.015
3	—	—	0.01	0.01	—	0.015	0.015
4	0.02	—	—	0.015	0.015	—	0.02
5	—	0.015	—	0.015	0.01	0.01	0.015
6	—	—	0.01	0.01	—	0.01	0.01
7	0.01	—	—	0.01	0.015	0.015	0.015
8	—	—	0.01	0.01	—	0.01	0.01
9	0.01	—	—	0.01	0.01	0.01	0.01
10	—	—	0.01	0.01	—	0.01	0.01
11	0.01	—	—	0.01	0.01	0.01	0.01
12	—	—	0.01	0.01	0.01	0.01	0.01
13	—	—	—	0.01	0.01	0.015	0.015
14	—	—	—	0.015	—	0.02	0.02
15	0.02	—	—	0.01	0.01	0.01	0.02
16	0.01	—	—	0.01	0.01	0.01	0.01
17	0.01	—	—	0.01	0.015	—	0.015
18	0.01	—	—	0.01	0.01	0.01	0.01
19	—	—	0.01	—	0.01	0.01	0.01
20	—	—	0.01	0.01	—	0.01	0.01
21	—	—	—	0.01	0.01	0.01	0.01
22	—	—	—	—	—	—	—
23	0.01	—	0.02	—	0.02	0.02	0.02
24	—	—	—	0.015	0.015	0.01	0.015
25	—	—	—	0.015	0.015	0.015	0.015
26	—	—	0.015	0.01	0.01	0.01	0.015
27	—	—	—	—	0.01	0.015	0.015
28	0.015	—	—	0.01	0.01	0.01	0.015
29	0.01	—	—	0.01	—	0.015	0.015
30	0.015	—	—	—	—	—	0.015
31	0.02	—	—	0.01	—	0.01	0.02

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

(Yes/No)

All 4-hour turbidity readings \leq 1 NTU?

(Yes/No)

All turbidity readings < IFE² triggers

(Yes/No)

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

(Yes/No)

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

(Yes/No)

Notes:

PRINTED NAME:

SIGNATURE:

PHONE #:

DATE: 8/1/25

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: July 2025

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.16	480	556.8	17.8	6.29	21	yes	98
2	0.99		475.2	18.9	6.31	21	yes	
3	0.83		398.4	18.3	6.38	20	yes	
4	0.76		364.8	18.9	6.28	20	yes	
5	0.60		288	18.9	6.35	20	yes	
6	0.50		240	19.4	6.36	20	yes	
CB 7 0919	0.51		244.8	17.2	6.39	20	yes	
CB 8 0929	0.53		254.4	18.3	6.37	20	yes	
MM 9 1214	0.75		260	18.9	6.33	20	yes	
MM 10 11:00	0.82		393.6	18.9	6.29	20	yes	
MM 11 11:40	1.07		513.6	18.9	6.33	20 ^{mm} 21	yes	
MB 12 9:50	1.10		528	18.3	6.33	21	yes	
MM 13 11:41	1.11		532.8	19.4	6.31	21	yes	
E 14	—		—	17.2 (10 ²)	6.25 (CB)	—	—	
CB 15 1057	0.92		441.6	17.2	6.28	21	yes	
MM 16 1:11	0.67		321.6	18.9	6.34	20	yes	
MM 17 1:56	0.60		288	19.4	6.33	20	yes	
MM 18 12:36	0.56		268.8	19.4	6.35	20	yes	
MM 19 12:30	0.48		230.4	19.4	6.33	20	yes	
MM 20 1:34	0.59		283.2	19.4	6.26	20	yes	
RW 21 1230	0.75		360	18.9	6.38	20	yes	
PD 22 6:54	0.78		374.4	18.3	6.32	20	yes	
RW 23 11:00	1.08		518.4	18.3	6.38	20	yes	
RW 24 11:00	1.26		604.8	18.3	6.44	20	yes	
VS 25 10:22	1.09		523.2	18.9	6.35	21	yes	
LB 26 11:05	1.16		556.8	19.4	6.21	21	yes	
MM 27 9:38	1.04		499.2	19.4	6.54	21	yes	
CB 28 11:38	1.22		585.6	19.4	6.22	22	yes	
RW 29 107	1.17		561.6	18.9	6.35	21	yes	
DC 30 1638	0.95		456	19.4	6.22	21	yes	
RW 31 1070	0.94		451.2	18.9	6.38	21	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of July, 20 25

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	—	—	.84	—	0.80	0.80	1.16	.82	1.02
2	0.78	—	—	0.80	0.80	0.78	0.99	0.90	0.95
3	—	—	6.74	0.80	—	0.74	0.83	0.79	0.75
4	0.68	—	—	0.74	0.66	—	0.76	0.71	0.72
5	—	0.66	—	0.68	0.68	0.64	0.60	0.63	0.69
6	—	—	0.68	0.68	—	0.68	0.50	0.47	0.41
7	0.64	—	—	0.76	0.72	0.68	0.51	0.36	0.39
8	—	—	0.72	1.36	—	1.44	0.53	0.33	0.34
9	1.36	—	—	1.48	1.6	1.48	0.75	0.42	0.31
10	—	—	1.48	1.44	—	1.52	0.82	0.56	0.42
11	1.40	—	—	1.44	1.32	1.28	1.07	0.57	0.47
12	—	—	1.20	1.44	1.28	1.28	1.10	0.83	0.50
13	—	—	—	1.36	1.28	1.24	1.11	0.93	0.76
14	—	—	—	1.36	—	1.32	1.08	—	—
15	1.28	—	—	1.24	1.16	1.16	0.92	0.82	0.76
16	1.12	—	—	1.20	1.12	1.12	0.67	0.90	0.20
17	1.08	—	—	1.20	1.12	—	0.60	0.62	0.23
18	1.12	—	—	1.16	1.08	1.04	0.56	0.48	0.23
19	—	—	1.08	—	1.40	1.32	0.48	0.38	0.63
20	—	—	1.36	1.08	—	1.40	0.59	0.27	0.54
21	—	—	—	1.52	1.41	1.37	.75	1.56	.36
22	—	—	—	—	—	—	.78	.55	.29
23	1.44	—	1.48	1.48	1.44	1.44	1.08	.63	.29
24	—	—	—	1.50	1.40	1.33	1.26	.79	.24
25	—	—	—	1.5	1.45	1.4	1.09	0.91	0.48
26	—	—	1.2	1.4	1.44	1.36	1.16	0.96	0.52
27	—	—	1.5	1.53	1.54	1.4	1.04	0.97	0.76
28	1.37	—	1.48	1.40	1.40	1.28	1.22	1.01	0.75
29	1.24	—	—	1.39	1.12	1.20	1.17	.89	.81
30	1.22	—	—	1.25	—	1.36	0.95	0.95	0.75
31	—	—	—	1.36	0.96	0.94	.94	.65	.74

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of July, 20 25

			Water System Meter Readings 932888				Girl Scout Water Usage 21142		Water Plant Chemical Usage		
Date	Initial	Time	130728 Meter 2 Reading	869347 Meter 4 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	X748 Gallons Used	Alum Pounds	Chlorine Gallons
1	RW			869627	28,000	934110	22,200	21146	1,496	0	1
2	MM	1:18		870004	37700	934392	28200	21152	4,488	2-8	1
3	MM	10:32		870274	27000	934639	24700	21158	4,488	2-8	1
4	MM	11:22	131028		30000	934968	32900	21162	2,992	1-4	0
5	MM	11:58	131473		44500	935345	37700	21165	2,244	2-8	1
6	MM	12:01	131909		51600	935706	36100	21168	2,244	2-8	1
7	VB	0919	132253		26,400	935935	22,900	21171	2,244	0	0
8	VB	0929		870777	50,300	936209	27,480	21173	1,496	3-12	1
9	MM	12:03		871113	33600	936555	34600	21177	2,992	2-8	1
10	MM	10:52		871457	34400	936832	27700	21181	2,992	2-8	1
11	MM	11:37		871777	32000	937144	31200	21186	3,740	2-8	1
12	MB	9:50		872143	36,600	937433	28,900	21191	3,740	1-4	1
13	MM	11:24		872554	41100	937820	38700	21197	4,488	2-8	1
14											
15	VB	1007		873307	75300	938435	61,500	21213	11,968	3-12	2
16	MM	1:06	132642		38900	938797	36200	21221	5,984	2-8	1
17	MM	12:07	133021		37900	939080	28300	21227	4,488	2-8	1
18	MM	12:39	133407		38600	939376	29600	21231	2,992	3-12	0
19	MM	12:11	133900		49300	939697	32100	21236	3,740	2-8	1
20	MM	11:30	1341291		39100	940028	33100	21240	2,992	2-8	1
21	RW	12:30	134603		31,200	940329	30,100	21244	2,992	0	1
22	PD	6:53PM		873762	45,500	940761	43,200	21251	5,236	5	0
23	RW	1106am		874046	28,400	940937	17,600	21256	3,740	2-8	1
24	RW	1000am		874388	34,200	941215	27,800	21263	5,236	2-8	1
25	VB	1012		874756	36,800	941543	32,800	21267	2,992	2-8	2
26	VB	1105		875148	39,200	941877	33400	21273	4,488	2-8	0
27	MM	9:30		875491	34300	942166	28,900	21276	2,244	3-12	1
28	VB	1158		875871	38,000	942514	34,800	21286	7,480	2-8	1
29			135021		38,000	942794	28,000	21290	2,992	2-8	1
30	DC	1638	135596		57,500	943210	41,600	21296	4,488	3-12	1
31			135792		19,600	943424	21,400	21300	2,992	0	0

WELL LOG: MONTHLY WATER REPORT

MONTH: July 2025

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	JW	8:59	20+3			169907		13.01		8		
2	JW	8:59	20+3			169907	20+3	13.01	24			
3	JW	9:22	20+2			169974	20+2	13.04	25.5	67		
4	BC	10:15				170041		12.84				
5	LL	11:09a	20+2 D2			170111	20	12.84	24	63		3 hour bars?
6	LL	9:59a				170147	15+2	12.74	21	76		3 hour bars?
7	HF	9:35a	.9	C		170256	15+1	12.91	24	79	4	
8	BC	11:22	.7	46		170325	15	12.68	26	69	4	
9	BC	12:00p	.8	28		170350	10+1	12.53	24		3.5	
10	JW	10:03				170459	10+2	12.86	23	69	3	
11	CM	9:32	.4	D2		170527	10+1	12.93	24	68	3.5	
12	CM	10:16a		D2		170668	9+	12.62	21	80	5	
13	JT	8pm				170688	9	12.44				pump running
14	LL	10:20a				170736	5+2	12.92	24.5	50	4	pressure washing
15	LL	9:39a	.7	D2		170803	5+1	12.97	25	67		
16	JW	9:06a	.5	D2		170873	5	12.98	23.5	70	3.5	
17	CMC	8:51a	.3	D2		170941	5	13.00	24.5	68	4	
18	CMC	9:15a	.3	46	40	171009	3	12.98	24	68	3.5	mix new ch
19	CM	9:27a	.6	bath		171079	40+1	12.96	25	70	4	
20	LL	9:49a				171169	40	12.78		90	3.5	dry left on
21	CM	9:27a	.7	2		171239	39	12.79	23	70	2.5	
22	CM	9:08a	.3	D1		171314	37	12.93	24	75	3.5	
23	BC	10:47	1.0	shop		171386	35+1	12.73	25	72	4	
24	JW	10:00a	1.0	D2		171452	35	12.91	25	66	3	
25	CM	8:44a	.6	58		171523	34	12.99	23	71	4	
26	LL	9:40a				171593	30+2	12.93	24	70	4.5	
27	CM	8:46	.3	D2		171667	30+1	13.01	23	74	3.5	
28	CM	8:59	.4	71		171739	30	12.88	22.5	72	2.5	small length bath
29	LL	10:13a	.4	D2		171812	25+3	12.91	25.5	73	3.5	
30	JW	9:44a	.4	D2		171885	25+2	12.93	25.5	73	3.5	
31	CMC	9:08	.8	19		171953	25+1	12.95	25	68	4	

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

SYSTEM NAME: HECETA HEAD STATE PARK

SOURCE NAME: WELL

ADDRESS: 93111 HWY 101 N

FLORENCE, OR 97439

PHONE: 541-547-3416

July

MONTH/YEAR

2025

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1								
2								
3 10:30	HF		.4	1/3		✓		43340
4 8:00	CME		.3	1/3				43347
5 9:15	BE		.7					43355
6 9:52	JW		1	1/3				43369
7 10:20	SD		.8	1/3				43374
8 10:44	SD		0	1/3				43383
9 9:15	SD		1	1/3				43391
10 9:20	BE		1					43392
11 9:25	BE		0.8					43398
12 9:55	JW		0.4	1/4		✓		43405
13 8:33a	LL		0.4	1/4		✓		43408
14 8:35	HF		.5	1/5				43410
15 9:15	SD		.5	1/5				43418
16 9:20	BE		.8					43422
17 9:10	SD		.7	1/5				43430
18 9:02a	JW		1	1/5		✓		43440
19 9:02a	JW		1	1/5		✓		43450
20 9:15a	CME		.5	1/5		✓		43453
21 9:45	SD		.8	1/5		✓		43460
22 9:30	SD		.6	1/5		✓		43469
23 9:45	SD		1.2	1/6		✓		43480
24 9:40	SD		1	1/6		✓		43489
25 8:27a	JW		0.5	1/6		✓		43494
26 9:00a	CME		.9	1/2		✓		43500
27 9:45	SD		.5	1/2		✓		43511
28 9:40	SD		1	1/2		✓		43534
9:44	SD		.8	1/2		✓		43541
10 8:20	BE		1	1/2		✓		43568