

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **LANE**

Conventional or Direct Filtration

Month/Year: **August 2025**

System Name: **OPRD JM Honeyman Memorial State Park** ID#: **41 : 91044**

WTP: **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.01	—	—	0.01	—	0.02	0.02
2	0.03	0.02	0.02	0.015	—	0.02	0.02
3	—	—	0.02	0.015	0.015	—	0.02
4	—	0.02 0.01	—	0.015	0.015	0.015	0.02
5	—	—	0.01	—	—	0.01	0.01
6	—	—	—	0.01	—	0.015	0.015
7	—	—	—	—	—	0.01	0.01
8	0.015	0.015	—	0.01	0.01	0.015	0.015
9	—	—	—	—	0.02	—	0.02
10	—	0.025	—	0.01	0.01	0.01	0.02
11	—	—	0.015	0.01	—	0.01	0.015
12	—	—	—	0.01	—	0.01	0.01
13	—	—	—	0.01	—	0.01	0.01
14	—	—	—	0.01	—	0.01	0.01
15	—	—	—	0.01	—	0.01	0.01
16	—	—	—	0.01	—	0.01	0.01
17	—	—	—	0.01	—	0.01	0.01
18	—	—	—	0.01	—	0.01	0.01
19	—	—	—	0.01	0.01	0.01	0.01
20	—	—	—	0.01	—	0.01	0.01
21	—	—	—	0.01	0.015	0.01	0.01
22	—	—	—	0.01	—	—	0.01
23	—	—	—	—	0.01	0.01	0.01
24	—	—	—	0.01	0.01	0.01	0.01
25	0.01	0.01	—	0.015	0.01	0.02	0.02
26	—	—	—	0.02	—	0.02	0.02
27	—	—	—	0.02	—	—	0.02
28	0.02	—	—	0.01	—	—	0.02
29	0.01	—	—	—	0.01	—	0.01
30	0.01	—	—	0.01	—	0.01	0.01
31	—	—	—	0.01	—	0.01	0.01

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes: 8/23/25 processing pump switch failure, plant stopped processing until brought back online @ 1pm 8/23/25		PRINTED NAME: Kati Baker	DATE: 9/1/25
		SIGNATURE: <i>[Signature]</i>	CERT #: 11/9
		PHONE #: (541) 997 3651	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Aug 2025

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
MM 1 11:27	0.47	480	225.6	18.9	6.34	20	yes	98
MM 2 11:30	0.56		240	20.6	6.33	15	yes	
MM 3 11:27	0.57		254.4	21.1	6.36	15	yes	
VB 4 12:41	0.54		259.2	18.9	6.31	20	yes	
VB 5 14:30	0.62		297.6	18.9	6.30	20	yes	
RU 6 10:00	.85		408	18.9	6.40	21	yes	
MM 7 10:45	0.87		417.6	19.4	6.38	20	yes	
MM 8 11:40	0.91		436.8	18.9	6.41	21	yes	
MM 9 11:52	0.82		393.6	20.6	6.28	15	yes	
VB 10 10:29	0.77		369.6	18.3	6.20	20	yes	
VB 11 11:42	0.69		331.2	20.6	6.14	15	yes	
VB 12 10:50	0.56		268.8	19.4	6.16	20	yes	
MM 13 12:32	0.52		249.6	20.0	6.21	15	yes	
MM 14 12:41	0.58		278.4	21.1	6.27	15	yes	
MM 15 10:45	0.64		307.4	19.4	6.30	20	yes	
MM 16 10:53	0.64		307.4	20.0	6.24	15	yes	
MM 17 11:48	0.57		273.6	21.1	6.32	15	yes	
VB 18 11:05	0.55		264	20.0	6.21	15	yes	
PD 19 5:15	.60		288	21.1	6.22	15	yes	
DC 20 17:50	0.56		268.8	20.6	6.25	15	yes	
HC 21 5:04 pm	0.59		293.2	20.6	6.16	15	yes	
VB 22 13:45	0.57		273.6	20.6	6.16	15	yes	
VB 23 12:13	0.49		235.2	20.6	6.20	15	yes	
VB 24 13:00	1.66		796.8	20.6	6.17	17	yes	
VB 25 09:07	1.23		590.4	19.4	6.17	16	yes	
VB 26 09:27	0.72		345.6	19.4	6.31	20	yes	
MM 27 12:40	0.56		268.8	18.3	6.24	20	yes	
MM 28 11:03	0.45		216.0	17.8	6.28	20	yes	
VB 29 12:20	0.48		230.4	17.8	6.36	20	yes	
VB 30 09:41	0.50		240	17.8	6.31	20	yes	
VB 31 09:24	0.49		235.2	18.9	6.31	20	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of August, 2025

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	0.74	-	-	0.80	-	0.84	0.47	0.72	0.92
2	0.78	1.04	0.96	0.92	-	1.04	0.50	0.50	0.76
3	-	-	1.0	-	1.28	-	0.53	0.49	0.64
4	-	1.11	-	-	1.35	1.3	0.54	0.31	0.53
5	-	-	1.3	-	-	1.28	0.62	0.38	0.383
6	-	-	-	1.36	-	1.24	0.87	0.63	0.43
7	-	-	-	-	-	1.20	0.85	0.51	0.47
8	1.28	1.24	-	1.20	1.16	1.20	0.91	0.71	0.30
9	1.16	-	-	-	1.12	-	0.82	0.83	0.45
10	-	1.2	-	1.16	1.17	1.04	0.77	0.71	0.49
11	-	-	1.04	0.6	-	0.64	0.69	0.61	0.61
12	-	-	-	0.8	-	0.8	0.56	0.51	0.51
13	-	-	-	0.9	-	0.92	0.52	0.56	0.53
14	-	-	-	0.88	-	0.84	0.58	0.13	0.47
15	-	-	-	0.88	-	0.84	0.64	0.42	0.30
16	-	-	-	0.84	-	0.88	0.64	0.45	0.41
17	-	-	-	0.84	-	0.88	0.57	0.45	0.40
18	-	-	-	0.88	-	0.84	0.55	0.45	0.43
19	0.79	-	-	0.80	0.82	0.79	0.60	0.54	0.40
20	0.74	-	-	0.82	-	0.8	0.56	0.55	0.34
21	-	-	-	0.8	-	0.76	0.59	0.44	0.38
22	-	-	-	0.82	-	-	0.57	0.52	0.34
23	-	-	-	-	1.72	1.68	0.49	0.43	0.48
24	-	-	-	1.07	0.99	0.96	1.66	0.99	0.41
25	0.92	0.88	-	0.88	-	0.92	1.23	1.52	0.29
26	-	-	-	0.48	-	0.42	0.72	1.05	0.29
27	-	-	-	0.42	-	-	0.56	0.64	0.31
28	0.42	-	-	0.42	-	-	0.45	0.46	1.06
29	0.42	-	-	-	0.48	-	0.48	0.38	1.08
30	0.56	-	-	0.54	-	0.52	0.50	0.42	0.79
31	-	-	-	1.25	-	1.26	0.49	0.41	0.40

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of August, 2025

			Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	Gallons Used	Alum Pounds	Chlorine Gallons
			875871			943424		21300			
			8778	135792					x748		
1	NM	10:47		136196	40600	943738	31400	21307	5,236	2-8	1
2	NM	11:46		137119	92100	944122	38400	21315	5,984	3-12	1
3	NM	11:45		137646	52100	944500	37800	21323	5,984	1-4	1
4	VB	12:41		137972	32,600	944770	27,000	21327	2,992	0	1
5	VB	14:30	876197		32,600	945068	29,800	21333	4,488	3-12	0
6	Dev	1:00	876489		29,200	945281	21,300	21338	3740	0	1
7	NM	10:53	876834		34500	945570	28900	21345	5,236	2-8	1
8	NM	11:37	877226		39200	945859	28900	21349	2,992	2-8	0
9	NM	11:53	877626		40000	946187	32800	21353	2,992	3-12	1
10	VB	10:29	878006		38,000	946496	30,900	21357	2,992	2-8	0
11	VB	11:42	878347		34,100	946827	33,100	21364	5,236	3-12	1
12	VB	10:57		138347	37,500	947128	30,100	21372	5,984	0	0
13	NM	12:26		138728	36100	947478	35000	21383	8,228	2-8	1
14	NM	12:38		139074	34600	947793	31,500	21391	5,984	2-8	1
15	NM	10:42		139397	32300	948053	26000	21396	3,740	2-8	0
16	NM	10:47		139765	36000	948350	29700	21402	4,488	2-8	1
17	NM	11:48		140176	41100	948680	33,000	21406	2,992	2-8	0
18	VB	11:00		140479	30,300	948978	29,800	21414	5,984	0	1
19	VB	5:15 PM	878865		51,800	949377	39,500	21423	6,732	5	0
20	DC	17:50	879188		32,300	949706	33,300	21429	4,488	2-8	1
21	HE	5:09 PM	879480		29,200	949976	27,000	21430	748	0	0
22	VB	13:45	879639		15,900	950205	22,900	21432	1,496	2-8	1
23	VB	12:13	880403		76,400	950509	30,400	21434	1,496	5	0
24	VB	13:00	880827		42,400	950888	37,900	21437	2,244	3-12	1
25	VB	09:07	881358		53,100	951128	24,000	21443	4,488	0	1
26	VB	09:22		140781	30,200	951447	31,900	21449	4,488	2-8	0
27	NM	12:37		141108	32700	951757	31,000	21451	1,496	3-12	1
28	NM	11:01		141379	27100	951950	19300	21453	1,496	1-4	0
29	VB	11:26		141637	25,800	952177	22,700	21455	1,496	0	0
30	VB	09:41		141895	25,800	952424	24,700	21456	748	0	0
31	VB	09:24		142251	35,600	952763	33,900	21460	2,992	2-8	1

Raw Turbidity

Month/Year Aug 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.41	X	
2	0.64	X	
3	0.64		X
4	0.41	φ	
5	0.52		X
6	0.63	X	
7	0.46	X	
8	0.58	X	
9	0.48	X	
10	0.58		φ
11	0.46	X	
12	0.43	φ	
13	0.48	X	
14	0.46	X	
15	0.47	X	
16	0.45	X	
17	0.47	X	
18	0.47	φ	
19	0.67		X
20	0.73		X
21	0.57		X
22	0.46	φ	
23	0.51	φ	
24	0.52	φ	
25	0.53		φ
26	0.51	X	
27	0.55	X	
28	0.72		X
29	0.60		X
30	0.53		φ
31	0.49	φ	

WELL LOG: MONTHLY WATER REPORT

MONTH:

AUG

YEAR: 2025

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	Be	9:00	1	77		172024	25	13.02	24.5		4.5	
2	CM	8:44	.4	Restroom		172091	24	12.94	24	67	3.5	
3	LL	8:52a	1	3		172165	20 ⁺²	12.90	22	64	3.5	
4	LL	4:59a				172240	20	12.90	24	75	3.5	
5	Be	10:15	1	Shop		172315	15 ⁺³	12.58	22.5	75	4	
6	CMC	11:44	.5	DZ		172438	15 ⁺²	12.71	22.5	123	3	HOSE LEFT ON @ DU
7	HF	8:29	.9	D1		172506	15 ⁺¹	13.02	22.5	68	4	
8	CM	8:51	.25	10		172574	15	13.04	25	68	4	
9	CM	8:38	.9	16		172645	14	12.95	23	71	3.5	
10	CM	9:36	1.0	17		172718	15	12.65	22	73	3	
11	CM	8:45a	.5	DZ		172791	12 ⁺⁶	12.76	23	73	2.5	
12	LL	9:05a	.8	15		172863	10	12.76	23.3	72	3	
13	SM	9 AM	.8	46		172935	5 ⁺³	12.84	23	72	3.5	
14	SM	8:40 AM	.5	71		173002	5 ⁺²	13.03	27	68	3.5	
15	CM	9:20a	.7	20		173067	5 ⁺¹	13.07	25	65	4	
16	CM	9:30a	.7	14		173129	5 ⁺	13.20	28.5	62	3	
17	CM	8:27a	.6	15		173195	4	13.15	20	66	4	
18	CM	8:39a	.8	71		173265	3	12.97	21	70	3	
19	LL	11:38	.3	3	40/3	173334	45	12.06	27	69	4.5	mixes chlorine
20	JT	2 pm	1	H/B		173406	44 [?]	12.46				
21	HF	9 am	.2	D2		173473	43	13.03	24	67	4	
22	CM	9:04a	.4	chase		173536	41	13.12	25	66	4	
23	CM	8:24a	.5	5 ⁺		173599	40 ⁺	13.13	25.5	63	3	
24	CM	10:50a	.6	3		173673	39	12.51	20.5	74	3.5	
25	CM	10:27a	.6	D1		173745	37	12.50	20.5	78	2.5	
26	Be	9:30	.7	DZ		173814	35 ⁺¹	12.76	25	69	3.5	
27	Be	10:00	.6	Shop		173883	35	12.91	26.5	69	3.5	
28	Be	10:20	1.0	74		173948	30 ⁺¹	12.90	25.5	65	3.5	
29	L	9:09a	.8	DZ		174015	30 ⁺²	12.93	23	67	3.5	
30	Be	10:00				174081	30 ⁺¹	12.80	24.5	66	4	
31	CM	10:22	.6	chase		174152	30 ⁺	12.64	23	71	4	

between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4
SYSTEM N
SOURCE N

CETA HEAD STATE PARK
L

ADDRESS: 93111 HWY 101 N
FLORENCE, OR 97439
PHONE: 541-547-3416

i&t
\$!! MONTH YEAR
August 2025

DATE/TIME	IN	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 9:00a	HF		2.3	1/2	/	✓		43582
2 9:30	BE		1.0	Full	/	✓		43589
3 9:17a	CM		2.2	Full	/	✓		43600
4 9:20	SD		1.0	4/5	/	✓		43611
5 10:16a	CM		1.5	3/4	/	✓		43615
6 9:10	BE		1.5		/			43621
7 9:45	SD		1.3	2/3	/	✓		43639
8 8:50	HF		2		/			43640
9 9:50a	S		1.5		/	✓		43650
10 8:50a	LL		.3		/	✓		43656
11 9:40	SD		1.5	3/4	/	✓		43683
12	BE		1.0		/			43685
13 9:25	SD		.7	3/4	/	✓		43694
14 9:45	SD		2.0	2/3	/	✓		43725
15 8:50	HF		1.1		/			43728
16 8:55	JW		0.8	2/3	/	✓		43730
17 9:15	SD		1.5	2/3	/	✓		43744
18 1:54	CMC		0.3	2/3	/			43752
19 8:15	BE		0.3		/			43755
20 9:20	SD		1.5	2/3	/	✓		43779
21 9:30	SD		1.5	2/3	/	✓		43783
22 9:10	HF		.9	2/3	/			43784
23					/			43784
24 9:10	SD		1.5	2/3	/	✓		43806
25 9:10	HF		1.1		/			43810
26 8:50	HF		.9		/			43811
27 9:15	SD		.7	2/3	/			43819
28 9:25	SD		1.0	1/2	/	✓		43824
29 9:30	CMC		1.0	1/2	/			43839
30 9:20	JW		1.2	1/3	/	✓		43844
31 9:30	SD			1/3	/	✓		43849