

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: Sept 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	0.01	—	—	0.01
2	—	0.01	—	—	—	0.01	0.01
3	—	—	—	—	—	—	—
4	0.02	—	0.02	0.02	—	—	0.02
5	—	—	—	—	0.01	—	0.01
6	—	—	—	0.01	—	0.01	0.01
7	—	—	—	0.01	—	—	0.01
8	0.01	—	—	—	0.01	—	0.01
9	—	—	0.01	—	—	—	0.01
10	0.01	—	—	—	0.01	—	0.01
11	—	—	0.01	—	—	—	0.01
12	—	0.01	—	—	—	0.01	0.01
13	—	—	—	0.01	—	0.01	0.01
14	—	—	—	0.01	—	—	0.01
15	—	0.01	—	—	—	0.01	0.01
16	—	—	—	0.01	—	—	0.01
17	—	—	—	0.01	—	—	0.01
18	—	—	0.01	—	—	0.01	0.01
19	—	—	—	—	0.01	—	0.01
20	—	—	0.01	0.01	—	—	0.01
21	0.01	—	—	0.01	—	—	0.01
22	—	—	—	0.01	—	—	0.01
23	—	0.01	—	—	—	0.01	0.01
24	—	—	—	0.015	—	—	0.015
25	—	0.015	—	—	—	—	0.015
26	0.015	—	—	—	—	—	0.015
27	—	—	0.04	—	—	0.015	0.015 ^{max} 0.04
28	—	—	—	0.015	—	—	0.015
29	—	0.015	—	—	—	0.02	0.02
30	—	—	—	0.01	—	—	0.01

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes No

All 4-hour turbidity readings \leq 1 NTU?

Yes No

All turbidity readings < IFE² triggers

Yes No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes No

All Cl2 residual at entry point
 \geq 0.2 mg/l?

Yes No

Notes:

PRINTED NAME:

SIGNATURE:

PHONE #:

DATE: 10-1-25

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Sept 2025

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
US 11/47	0.43	480	206.4	20.0	6.20	15	yes	98
US 20830	0.47		225.6	19.4	6.28	20	yes	
MM 3/11/31	0.46		220.8	18.9	6.31	20	yes	
RW 4/10/00	0.58		278.4	18.9	6.45	20	yes	
RW 5/9/00	0.72		345.6	18.9	6.37	20	yes	
MM 6/9/21	0.76		364.8	18.3	6.36	20	yes	
MM 7/9/11	0.79		379.2	18.3	6.29	20	yes	
RW 8/9/00	0.80		384	17.8	6.38	20	yes	
US 9/09/52	0.97		405.6	19.4	6.20	21	yes	
US 10/09/44	0.76		364.8	17.8	6.32	20	yes	
MM 11/9/11	0.57		273.6	18.3	6.40	20	yes	
MM 12/9/21	0.60		288	18.9	6.33	20	yes	
MM 13/9/05	0.55		264	18.9	6.38	20	yes	
MM 14/9/33	0.43		206.4	18.9	6.29	20	yes	
MM 15/9/50	0.36		172.8	19.4	6.27	20	yes	
US 16/11/21	1.75		840	17.2	6.16	23	yes	
MM 17/9/35	1.53		734.4	18.9	6.29	22	yes	
MM 18/9/15	1.46		700.8	18.9	6.25	22	yes	
MM 19/9/30	1.48		710.4	18.3	6.31	22	yes	
MM 20/9/27	1.34		643.2	18.3	6.28	22	yes	
MM 21/9/01	1.23		590.4	18.3	6.34	22	yes	
MM 22/9/10	1.20		576	17.8	6.26	21	yes	
MM 23/9/51	1.05		504	17.2	6.31	21	yes	
US 24/08/18	0.89		403.2	16.7	6.28	21	yes	
MM 25/9/22	0.55		264	17.8	6.26	20	yes	
LB 26/09/16	0.52		249.6	15.6	6.30	20	yes	
LB 27/09/20	0.53		254.4	18.9	6.29	20	yes	
DC 28/09/21	0.50		240.0	16.1	6.20	20	yes	
MM 29/9/10	0.42		201.6	15.6	6.24	20	yes	
MM 30/9/10	0.44		211.2	17.2	6.32	20	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

WELL LOG: MONTHLY WATER REPORT

MONTH:

September

YEAR:

25

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	CM	8:37a	.5	1		174222	29+	12.80	20.5	70	3	
2	LL	9:24a	.5	D2		174288	25+3	12.95	27.5	66	4	
3	BL	9:46	1.0	shop		174353	25+2	12.90	25.5	65	4	
4	CSM	8:45pm	1.5	10		174415	25+1	13.04	26	62	3.5	
5	CM	8:53a	.6	29		174545	24	13.50	27	30	2.5	
6	LL	4:48a				174551	20+3	12.12				
7	HF	6:34p	.8	D1		174619	20+2	13.11	27	68	3.5	
8	CM	9:46a	.7	75		174619	20+2	12.20	27	68	3.5	
9	BL	8:55a	.5	CRH		174684	20H	12.74		65		
10	CSM	9:30pm	.5	12		174749	20	12.82	26.5	60	4	
11	BL	10:12	1	2		174812	20	13.00	29	63	4	
12	CM	9:03a	.5	71		174876	19	13.18	26.5	64	3	
13	CM	8:51a	.6	17		174937	18	13.22	24.5	61	3	
14	LL	4:49a				174998	15+1	13.28	23	61	3.5	
15	LL	10:45	.3	D1		175062	15	13.38	28.5	64	3.5	
16	CSM	9:20A	.7	71		175137	10+3	12:23	29	75	3.5	
17	CSM	9:45A	.5	29		175204	10+2	12:52	23.5	67	4	
18	CM	8:49a	.6	10		175269	10+	12.94	29.5	65	4	
19	CM	8:50a	.6	21		175331	10+	13.07	28.5	62	4.5	
20												
21	LL	10:02a	.4	D1		175395	10	12.99	23	64	4	
22	CM	8:38a	.2	D2		175456	9	13.32	28.5	61	3.5	
23	BL	11:37	.5	shop		175527	5+2	13.45	29	71	4	
24	BL	11:14A	.3	2		175536	5+2	12.20				plant on
25	BL	9:15a	.5	DU		175594	5+1	12.43	28		3.5	
26	CM	10:07A	.5	D2		175658	45+1	12.68	29	64	4	
27	CM	8:40a	.6	75		175721	45+2	13.08	29	63	4	
28	CM	8:46a	.6	C pipe chase		175783	45+1	13.10	25	62	4	
29	CM	8:46a	.7	72		175845	45	13.42	30	62	3.5	
30	HF	8:40a	1.0	C loop		175845	45	12.23			4	
31												

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PSID # 41910

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: CETA HEAD STATE PARK

FLORENCE, OR 97439

MONTH/YEAR

SOURCE NAME: L

PHONE: 541-547-3416

September

2025

DATE/TIME	INI	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1			.5	1/3		✓		43857
2 9:50a	CM		.5	1/3		✓		43859
3 9:50	BE		1.0					43867
4			.5	1/3		✓		43869
5 9:55a	CM		.4	1/3		✓		43880
6 9:30a	LL		.3	1/3		✓		43882
7 9:45	SD		.5	1/3		✓		43897
8 9:25	SD		.5	1/3		✓		43904
9 9:45	SD		1.0	1/3		✓		43909
10 9:30	SD		1.0	1/4		✓		43911
11 9:40 (800)			1.0	1/4		✓		43919
12 9:10	HF		.7	1/4				43920
13 9:40a	LC		.5	1/5		✓		43941
14 9:15	SD		1.0	1/5		✓		43944
15 9:50	HF	1.0		1/5				43949
16 9:25	SD		1.5	1/5		✓		43948
17 9:50	BE		1.5					43959
18								43964
19 9am	LL		.5	1/8		✓		43972
20 9am	CC		.3	1/10		✓		43976
21 9:18 am	CM		.1	9/10		✓		43979
22 9:30			1.0	9/10		✓		43985
23 1:45	SD		1.0	9/10				43990
24 9:50	HF	2.0	.1	9/10				44000
25 9:35	SD		2.0	10/10				
26 9:40	HF		1.4	10/10		✓		
27 9:25a	LL		1.0	11/10		✓		
28 9:30a	LC		1.2	9/10		✓		
29 9:10a	LL		1.2	9/10		✓		
30 9:30	SD		1.5	9/10		✓		
31								

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of September, 2025

Water System Meter Readings								Girl Scout Water Usage		Water Plant Chemical Usage	
881358 142251 952763											
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	21460 Meter Cubic Ft	x748 Gallons Used	Alum Pounds	Chlorine Gallons
1	VB	1147		142607	44,600	953132	36,900	21463	2,244	2-8	0
2	VB	0830	881568		21,000	953273	14,100	21465	1,496	0	1
3	NH	1104	081707		13,900	953451	17800	21467	1,496	2-8	0
4	RV	1000	881875		16,800	953597	14,600	21469	1496	0	1
5	RV	900	882120		24,500	953753	15,600	21470	748	2-8	1
6	NH	8:51	082266		14,600	953929	17,600	21473	2244	0	0
7	NH	8:52	082553		28,700	954160	23,100	21475	1,496	1-4	0
8	RV	900	882844		19,100	954354	19,400	21486	8,228	0	0
9	VB	0952		142885	18,800	954519	16,500	21489	2,244	0	0
10	VB	0944		143060	17,500	954676	15,700	21491	1,496	2-8	0
11	NH	9:10		143183	12300	954819	14300	21493	1496	1-4	0
12	NH	9:12		143462	27900	954973	15400	21495	1,496	1-4	1
13	NH	8:51		143592	13600	955154	10100	21498	2,244	1-4	0
14	NH	9:31		143876	28400	955382	22800	21501	2,244	1-4	0
15	NH	9:23		144127	25,100	955540	15800	21502	748	1-4	1
16	VB	1129	882933		13,900	955712	17,200	21504	1496	0	1
17	NH	9:27	083097		16,400	955852	14000	21506	1,496	1-4	0
18	NH	9:06	083304		20700	955991	13,900	21508	1,496	1-4	1
19	NH	9:12	083443		13,900	956142	15,100	21510	1,496	1-4	0
20	NH	9:11	083612		16900	956320	17800	21511	748	1-4	0
21	NH	8:45	083860		24800	956509	18900	21512	748	1-4	1
22	NH	9:04	083984		12400	956665	15,600	21514	1,496	0	0
23	NH	8:43		144461	27,400	956815	15000	21517	2,244	1-4	0
24	VB	8:47		144525	12,400	956962	14,700	21519	1496	0	0
25	NH	9:13		144763	23,800	957116	15,400	21521	1496	1-4	0
26	VB	0948		144888	12,500	957270	15,400	21522	748	0	0
27	VB	0920		145125	23,700	957429	15,900	21524	1496	0	0
28	DC	0921		145274	14,900	957601	17,200	21527	2244	1-4	2
29	NH	8:49		145531	25,700	957751	15,000	21530	2244	0	0
30	NH	8:59	084099		11,500	957905	15,100	21534	2,992	1-4	0
31											

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of September, 20 25

[illegible]