

## OHA - Drinking Water Services -Turbidity Monitoring Report Form

## Conventional or Direct Filtration

County:

LANE

Month/Year:

Oct /2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	—	0.01	—	—	—	0.01	0.01
2	—	—	—	0.01	—	—	0.01
3	—	0.01	—	—	—	0.01	0.01
4	—	—	—	0.01	0.01	—	0.01
5	—	—	—	0.01	—	—	0.01
6	—	—	0.01	—	—	—	0.01
7	0.01	—	—	—	0.01	—	0.01
8	—	—	—	0.01	—	—	0.01
9	—	—	0.01	—	—	0.01	0.01
10	—	—	—	0.01	—	—	0.01
11	—	—	0.01	—	—	—	0.01
12	0.01	—	—	—	0.01	—	0.01
13	—	—	—	0.015	—	—	0.015
14	—	—	0.015	—	—	—	0.015
15	0.01	—	—	—	0.015	—	0.015
16	—	—	—	0.01	—	—	0.01
17	—	—	0.01	0.01	—	—	0.01
18	—	0.015	—	—	—	0.01	0.015
19	—	—	—	—	0.01	—	0.01
20	—	—	—	0.01	—	—	0.01
21	—	—	—	0.01	—	—	0.01
22	—	—	—	0.01	—	—	0.01
23	—	—	—	0.01	—	—	0.01
24	—	—	—	0.01	—	—	0.01
25	—	—	0.015	—	—	—	0.015
26	—	—	0.01	—	—	—	0.01
27	—	0.005	—	—	—	—	0.01
28	—	0.015	—	—	—	0.015	0.015
29	—	—	—	0.01	—	—	0.01
30	—	—	—	0.01	—	—	0.01
31	—	—	—	0.01	—	—	0.01

## Conventional or Direct Filtration

## Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings  $\leq$  0.3 NTU? Yes / NoCT's met everyday?  
(see back)All Cl2 residual at entry point  
 $\geq$  0.2 mg/l?All 4-hour turbidity readings  $\leq$  1 NTU? Yes / No Yes / No Yes / NoAll turbidity readings  $<$  IFE<sup>2</sup> triggers Yes / No

Notes:

PRINTED NAME:

SIGNATURE:

PHONE #: (541) 997-3851

DATE: 11/3/25

CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Oct/2025

WTP :-  
Disinfection Giardia  
Log Inactive:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
Mh 1 10:16	0.66	480	316.8	15.0	6.30	20	yes	98
Mh 2 10:02	0.63		398.4	16.7	6.25	20	yes	
Mh 3 9:15	0.95		456	16.1	6.34	21	yes	
PD 4 12:53	1.03		494.4	16.1	6.21	21	yes	
DD 5 1:07	0.97		465.6	17.2	6.22	21	yes	
Mh 6 9:05	0.97		465.6	16.7	6.35	21	yes	
Mh 7 9:04	0.93		446.4	17.2	6.30	21	yes	
Mh 8 9:07	0.04		403.2	16.1	6.41	21	yes	
CS 9 11:00	0.75		3600	16.7	6.28	20	yes	
HE 10 09:35	0.71		340.8	15.6	6.19	20	yes	
PD 11 12:25	0.57		273.6	16.1	6.23	20	yes	
PD 12 1:30	0.50		240	15.6	6.30	20	yes	
HE 13 09:40	0.48		230.4	16.1	6.23	20	yes	
Mh 14 9:28	0.56		260.8	15.6	6.43	20	yes	
Mh 15 9:31	0.58		278.4	15.0	6.20	20	yes	
Mh 16 9:07	0.60		200	15.6	6.35	20	yes	
Mh 17 9:22	0.66		316.8	16.1	6.41	20	yes	
HE 18 11:54	0.74		364.8	14.4	6.20	31	yes	
PD 19 12:45	0.82		393.6	14.4	6.23	31	yes	
Mh 20 9:31	0.92		445.1	15.0	6.33	20	yes	
Mh 21 9:10	0.78		374.4	13.9	6.29	31	yes	
Mh 22 9:23	0.69		331.2	14.4	6.41	30	yes	
Mh 23 8:59	0.55		267.3	13.3	6.21	30	yes	
Mh 24 9:31	0.62		293.7	13.9	6.36	30	yes	
DC 25 9:08	0.46		220.8	15.0	6.18	30	YES	
DC 26 9:16	0.38		182.4	15.0	6.26	29	YES	
LB 27 10:20	0.38		182.4	12.2	6.28	29	yes	
Mh 28 9:20	0.35		168	12.8	6.31	29	yes	
Mh 29 9:30	0.46		220.8	15.0	6.66	24	yes	
Mh 30 9:16	0.78		344.4	14.4	6.47	31	yes	
Mh 31 9:21	0.79		379.2	13.9	6.39	31	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

# Raw Turbidity

Month/Year

October 2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.62		X
2	0.67		X
3	0.65		X
4	0.44		X
5	0.60	✓	
6	0.54	X	
7	0.60		X
8	0.62		X
9	0.45		X
10	0.59		X
11	0.50		X
12	0.69		X
13	0.51	X	
14	0.65		X
15	0.57		X
16	0.62		X
17	0.45	X	
18	0.49		X
19	0.50		X
20	0.79		X
21	0.66		X
22	0.47	X	
23	0.68		X
24	0.52	X	
25	0.59	X	
26	0.56	X	
27	0.66		X
28	0.64		X
29	0.66		X
30	1.08		X
31	1.07		X

## WELL LOG: MONTHLY WATER REPORT

MONTH: OCTOBER							YEAR: 2025					
	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	6C	10:30A	.1	Shop		175909	40 <sup>3</sup>	12.65	36.5			
2	HF	9:17A	.1	D2		175969	40 <sup>2</sup>	13.20	28.5	60	4	
3	CSM	9:45	.5	D1		175998	40 <sup>2</sup>	12.68		31	4	
4	CSM	10AM	.5	29		176051	40 <sup>1</sup>	12.35		53	4	
5	CM	10:50A	.6	46		176103	40 <sup>1</sup>	12.59	28.5	52	4	
6	Be	11:57	1.0	20		176167	40	12.8130		45		
7	CSM	10AM	.5	03		176228	35 <sup>3</sup>	13:14	28.5	51	4	100% WASH
8	Be	12	10	18		176296	35 <sup>2</sup>	13.47	30.5	68	4	
9	HF	8:35A	.8	20		176296	35 <sup>2</sup>	12.45				
10	Be	9				176359	35 <sup>1</sup>	12.91	32.5		45	
11	CSM	10:02A	.5	20		176420	35	13.17	32	61	4	
12	CM	9:21A	.8	12		176420	35	12.07			4	
13	Be	10:45	1.0	2		176485	35	12.53	32		4	
14	AC	4pm	1	510 <sup>8</sup>		176546	30 <sup>3</sup>	12.64	33		45	
15	CSM	10A	2.7	RR		176575	30 <sup>3</sup>	12.65		29	4	
16	DC	11	1	2		176613	30 <sup>2</sup>	12.4		36.5	4	
17	CSM	10A	D.8	D.2		176681	30 <sup>1</sup>	12.86	32	68	4	
18	CM	8:31A	.7	16		176743	30	13.47	35.5	62	4	
19	CM	8:27A	.8	21		176743	30	12.04				
20	CM	8:44A	.5	29		176811	25 <sup>3</sup>	12.67	30	68	3.5	
21	CSM	9:45A	.5	D1		176872	25 <sup>2</sup>	13.11		61		
22	Be	11:01	.6	26		176937	25 <sup>1</sup>	13.43				
23	CSM	10:35A	.5	2		176937	25 <sup>1</sup>	12.36		13		
24	CSM	9 AM	.5	D2		1767000	25	13.35		63	4	
25	CSM	9:30A	.6	02		177038	25	12.91		38		
26	CM	8:53A	.6	08		177064	25	12.58		26	4	
27	CM	8:36A	.7	07		177176	20 <sup>3</sup>	13.14	36	62	4	
28	CM	10:30A	.6	20		177160	20 <sup>3</sup>	13.31		34	4	
29	CSM	9:35A	.8	D2		177189	20 <sup>2</sup>	12.55		29	4	
30	CSM	9:30A	.5	D2		177251	20 <sup>1</sup>	13.12	38	62	4.5	
31	CM	8:16A	.6	2		177355	20 <sup>1</sup>	12.10	36.5	64	4	

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between

readings is time at start of longest line to time at end of first drop.

PS ID # 4110

SYSTEM NAME: CETA HEAD STATE PARK  
SOURCE NAME: LHECETA HEAD STATE PARK  
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES  
ADDRESS: 93111 HWY 101 NFLORENCE, OR 97439  
PHONE: 541-547-3416MONTH/YEAR  
October  
2025

DATE/TIME	INIT	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT	TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	
1 8:40	HF			1.6	4/5		✓	44005
2 11:20	HF			1.3	4/5			44005
3 9:06a	Cm			1.6	3/5		✓	44005
4 9:29a	Cm			1.5	3/5		✓	44007
5 9am	JT			.5	same		✓	flushed at cxt 44011
6 8:25	HF			.2	4/5			44013
7 9:30	Be			.5	4/5			44014
8 8:50	HF			2	4/5		✓	44023
9 9:20	Be			1				44026
10 10:35	HF			1.3	4/5			44026
11 8:47a	Cm			2	4/5		✓	44027
12 9:30am	JT			1			✓ CXT	44030
13 —								
14 9am	JT			1	4/5		✓	44034
15 9:15	Be			0.5				44038
16 8:50a	HF			.8	4/5			44040
17 9:40	Be			0.7	4/5			44044
18 9:45a	Cm			1.6	4/5			44047
19 9am	JT			1	same		✓	44053
20 —								
21 9am	JT			1.5			✓	44060
22 9:30	Be			1.0				44065
23 9:44a	Cm			2.0	1/2		✓	44065
24 8:47a	Cm			.7	1/2		✓	44067
25 —								
26 9:30	JT			.5			✓ cxt	44069
27 9am	JT			1			✓ cxt	44075
28 8:45	HF			1.7				44075
29 8:30	HF			1.5				44076
30 9:15	Be			1.0				44077
31 8:35	HF			1.1	1/2			44078

# Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of October, 20 25

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	-	0.80	-	-	-	0.82	0.66	0.46	0.34
2	-	-	-	0.92	-	-	0.83	0.69	0.33
3	-	0.92	-	-	-	.90	0.95	0.72	0.27
4	-	-	-	.84	.80	-	1.03	.83	.30
5	-	-	-	0.86	-	-	0.97	0.97	0.16
6	-	-	-	0.80	-	-	0.97	0.81	0.48
7	0.82	-	-	-	0.88	-	0.93	0.96	0.62
8	-	-	-	0.90	-	-	0.84	0.88	0.65
9	-	-	0.78	-	-	0.84	0.75	0.75	0.77
10	-	-	-	-	-	-	0.71	0.69	0.86
11	-	-	-	-	-	-	0.55	0.57	0.87
12	0.80	-	-	-	0.79	-	0.50	0.55	0.76
13	-	-	-	1.20	-	-	0.48	0.42	0.76
14	-	-	1.20	-	-	-	0.56	0.43	0.63
15	1.16	-	-	-	1.40	-	0.58	0.51	0.55
16	-	-	-	1.30	-	-	0.60	0.46	0.48
17	-	-	1.14	1.21	-	-	0.66	0.49	0.50
18	-	1.18	-	-	1.40 <sup>PD</sup>	1.40	0.74	0.62	0.39
19	-	-	-	-	1.20	-	0.82	0.68	0.36
20	-	-	-	1.20	-	-	0.92	0.75	0.18
21	-	-	-	1.04	-	-	0.78	0.73	0.24
22	-	-	-	1.00	-	-	0.69	0.69	0.35
23	-	-	-	1.04	-	-	0.55	0.50	0.36
24	-	-	1.00	-	-	-	0.62	0.51	0.43
25	-	-	1.16	-	-	-	0.46	0.52	0.43
26	-	-	1.0	-	-	-	0.38	0.37	0.49
27	-	.90	-	-	-	-	0.38	0.36	0.63
28	-	1.20	-	-	-	1.24	0.35	0.31	0.55
29	-	-	-	1.50	-	-	0.46	0.31	0.51
30	-	-	-	1.40	-	-	0.70	0.36	0.49
31	-	-	-	1.20	-	-	0.79	0.54	0.40

# Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of October, 2025

Date	Initial	Time	Water System Meter Readings				Girl Scout Water Usage		Water Plant Chemical Usage	
			Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	Gallons Used	Alum Pounds
1	M	9:31	884324	145531	22500	958075	7000	21541	5,236	1-4
2	M	9:44	884472	1	14800	958255	8000	21546	5,236	0
3	M	9:02	884698		22600	958411	5600	21553	3,740	0
4	PD	17:52	884820		12,200	958601	14,000	21555	1496	0
5	PD	1:07	885021		12,100	958777	17,600	21560	3740	2-8
6	M	8:53	885207		18600	958907	13,000	21563	2244	0
7	M	8:57		145726	19500	959053	14,600	21565	1496	2-8
8	M	8:59		145862	13,600	959201	14,600	21567	1496	1-4
9	LB	11:00		1460966	20,400	959351	15,000	21569	1497	0
10	ME	09:35		146231	16,500	959499	14,800	21573	2,992	0
11	PD	12:25		146473	24,200	959661	16,200	21575	1496	2-8
12	PD	1:30		146581	11,800	959818	15,700	21577	1496	0
13	ME	10:40		146742	15,100	959940	12,200	21579	1496	0
14	M	9:23	885443	146745	23900	960078	13,800	21581	1496	2-8
15	M	9:22		146870	12,500	960221	14,300	21583	1496	0
16	M	8:57	885559		11,600	960355	13,400	21584	748	1-4
17	M	9:19	885709		15000	960495	14,000	21586	1496	0
18	ME	11:56	885952		24,300	960644	16,900	21588	1496	0
19	PD	12:49	886085		13,300	960807	14,300	21589	748	1-4
20	M	9:22	886216		13,100	960925	11,800	21591	1496	0
21	M	9:05		146948	7800	961036	11,00	21591	0	0
22	M	9:17		147111	16,300	961156	12,000	21591	0	1-4
23	M	8:46		147269	15800	961260	11,200	21591	0	0
24	M	9:27		147429	16,000	961397	12,900	21591	0	1-4
25	DC	9:09		147566	13,700	961511	11,400	21591	0	1
26	DC	9:16		147752	18,600	961622	11,100	21591	0	0
27	LB	10:20	886216	147978	22,600	961758	13,600	21593	1,496	0
28	M	9:13	886330		11400	961872	11400	21593	0	1-4
29	M	9:22	886445		11500	961997	12500	21593	0	0
30	M	9:07	886560		11500	962110	11300	21593	0	0
31	M	9:15	886678		11600	962234	12,400	21593	0	1-4