

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: Nov 2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	0.01	0.01	—	—	0.01
2	—	—	0.01	0.01	—	—	0.01
3	—	—	0.01	—	—	—	0.01
4	—	0.01	—	—	—	0.01	0.01
5	—	—	—	—	0.01	—	0.01
6	—	—	—	0.015	—	—	0.015
7	—	—	0.01	—	—	—	0.01
8	—	—	—	—	—	0.01	0.01
9	—	—	—	—	0.01	—	0.01
10	—	—	—	0.01	—	—	0.01
11	—	—	0.01	—	—	—	0.01
12	—	—	0.01	—	—	—	0.01
13	—	—	0.01	—	—	—	0.01
14	—	—	0.015	—	—	—	0.015
15	—	—	0.015	—	—	—	0.015
16	—	0.015	—	—	0.015	—	0.015
17	—	—	—	—	0.01	—	0.01
18	—	—	—	0.015	—	—	0.015
19	—	—	0.015	—	—	—	0.015
20	—	—	0.015	—	—	0.015	0.015
21	—	—	—	—	—	0.01	0.01
22	—	—	—	0.01	—	—	0.01
23	—	—	—	—	—	0.01	0.01
24	—	—	0.015	—	—	—	0.015
25	—	0.01	—	—	—	—	0.01
26	—	0.01	—	—	0.015	—	0.015
27	—	—	—	—	0.015	—	0.015
28	—	—	—	0.015	—	—	0.01
29	—	—	0.01	—	—	—	0.01
30	—	—	0.01	—	—	0.01	0.01
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME:

Nathan Micha

SIGNATURE:

Nathan Micha

DATE: 12-1-25

PHONE #:

(541) 999-5615

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year:

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
HE 09:25	0.61	460	292.8	14.4	6.26	31	yes	98
HE 209:24	0.90		432	14.4	6.19	31	yes	
MM 3 9:27	0.85		408	13.9	6.32	31	yes	
MM 4 9:15	0.97		465.6	14.4	6.30	31	yes	
VB 5 10:54	0.85		408	13.3	6.18	31	yes	
MM 6 9:11	0.68		326.4	12.8	6.24	31	yes	
MM 7 9:07	0.62		297.6	12.2	6.30	30	yes	
PD 8 11:44	.46		270.8	13.3	6.29	30	yes	
PD 9 11:22	.39		187.2	13.3	6.30	29	yes	
MM 10 9:15	0.39		187.2	13.9	6.41	29	yes	
MM 11 9:30	0.51		244.8	14.4	6.23	30	yes	
MM 12 9:11	0.58		278.4	13.4	6.31	30	yes	
MM 13 9:15	0.52		249.6	13.3	6.21	30	yes	
MM 14 9:09	0.83		398.4	13.3	6.36	31	yes	
DC 15 8:51	0.79		379.2	13.9	6.34	31	yes	
DC 16 8:59	0.88		422.4	13.3	6.26	31	yes	
MM 17 9:05	0.95		456	13.9	6.60	37	yes	
MM 18 9:05	0.85		408	12.8	6.45	31	yes	
MM 19 9:21	0.78		374.4	12.8	6.24	31	yes	
DC 20 9:54	0.67		321.6	14.4	6.27	31	yes	
MM 21 8:56	0.65		312	13.3	6.31	31	yes	
PD 22 11:35	.50		240	13.9	6.40	30	yes	
PD 23 11:49	.41		196.8	12.8	6.36	30	yes	
MM 24 8:56	0.44		211.2	12.2	6.27	29	yes	
LB 25 11:30	0.41		196.8	13.3	6.38	29	yes	
MM 26 9:07	0.45		219.7	12.8	6.42	30	yes	
MM 27 9:15	0.50		240	12.2	6.23	30	yes	
MM 28 9:05	0.52		249.6	11.7	6.36	30	yes	
HE 29 9:28	0.85		408	13.3	6.17	31	yes	
HE 30 9:30	0.99		475.2	13.9	6.39	31	yes	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of

November

20 25

Water System Meter Readings								Girl Scout Water Usage		Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	x 748 Gallons Used	Alum Pounds	Chlorine Gallons
1	HE	0930	886829	147978	15,100	962365	13,100	21593	0	0	0
2	HE	0926	887000		17,100	962496	13,100	21593	0	0	0
3	MM	9:05	887227		22,700	962634	13800	21593	0	2-8	1
4	MM	9:12		148124	14600	962753	11900	21593	0	0	0
5	CS	1056		148239	11,500	962883	13,000	21593	0	0	0
6	MM	9:06		148358	11,900	962992	10900	21593	0	0	0
7	MM	9:00		148519	16,100	963116	12400	21593	0	2-8	1
8	PD	11:00		148716	19,700	963253	13,700	21593	0	0	0
9	PD	11:22		148835	11,900	963389	13,600	21593	0	0	0
10	MM	9:09		148956	12,100	963506	11,700	21593	0	0	0
11	MM	9:22	887406		17,900	963643	13,700	21595	1496	2-8	1
12	MM	8:55	887526		12,000	963759	11,600	21595	0	0	0
13	MM	9:07	887669		14,300	963881	12,200	21595	0	2-8	1
14	MM	9:07	887792		12,300	963997	11,600	21595	0	0	0
15	DC	8:52	887991		19,900	964128	13,100	21595	0	0	1
16	DC	8:59	888134		14,300	964268	14,000	21597	1496	1-4	0
17	MM	8:58	888216		11,200	964387	11,900	21597	0	0	0
18	MM	8:59		149074	11,800	964499	11,200	21597	0	0	0
19	MM	9:30		149192	11,800	964618	11,600	21597	0	0	0
20	DC	954		149407	21,500	964738	12,000	21597	0	1-4	1
21	MM	8:53		149544	13,700	964852	11,400	21597	0	0	0
22	PD	11:35		149663	11,900	964990	13,800	21597	0	0	0
23	PD	11:49		149876	21,300	965122	13,200	21597	0	0	0
24	MM	8:50		149963	8,700	965229	10,700	21597	0	0	0
25	LB	11:30	888422		12,600	965373	14,400	21597	0	0	0
26	MM		888535		11,300	965481	10800	21597	0	1-4	0
27	MM	9:04	888655		12,000	965618	13,700	21597	0	0	1
28	MM	9:01	888775		12,000	965756	13800	21597	0	0	1
29	HE	9:28	888975		20,000	965906	15,000	21597	0	0	0
30	HE	9:30	889175		19,800	966050	14,400	21597	0	0	0
31											

2992

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of

November

2025

[illegible]

WELL LOG: MONTHLY WATER REPORT

MONTH: November 2025

YEAR:

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	CM	8:22a	.5	30	/	177316	20	12.71	26		4.5	
2	CM	8:24a	.6	2	/	177376	~20	13.24	37.5	60	4	
3	JT	9am	1	shop	/	177376		12.07				
4	HF	10:20	.6	D1	/	177440	15+3	12.6	35.5	64	4	
5	HF	9:35	.7	D2	/	177501	15+2	13.23	38.5	61	4	
6	HF	2:20	.7	D2	/							ON
7	BC	2:44p			/	plant off w/ no power			11/6 2:45pm - 11/7 7:45am			
8	CM	10:48a	.7	20	/	177604	15+1	12.77	-	-	4	
9	CM	9:09a	.6	29	/	177665	15	13.35	35.5	61	4	
10	HF	8:25a	.6	3	/	177665	15	12.5				
11	JT	9am	1	D.A.	/	177733	10+3	12.74				
12	JT	10am	1	29	/	177793	10+2	13.19				
13	JT	9am			/	177793	10+2	12.21				
14	BC	9:45	0.9	2	/	177856	10+1	12.81			4.5	
15	CM	9:25a	.8	46	/	177917	10	13.44	38	61	4	
16	HF	9:40	.6	D1	/	177917	10	12			3.5	ON
17	HF	9:35	.6	D1	/	177983	5+3	12.64	31	66	4	
18	BC	9:10	1	shop	/	178044	5+5	13.29	38	61	4	
19	BC	8:30	0.7	3	/	178044	5+2.5	12.36			4.5	
20	CM	9:39a	.7	D2	/	178105	5+2	12.48	33.5	61	4.5	
21	CM	8:45	.7	47	/	178107	5+2	12.64			4.5	ON
22	CM	8:21a	.7	2	/	178167	5+1	12.76	32	60	4.5	
23	CM	8:26a	.6	58	/	178228	5	13.32	37.5	61	4	
24	CM	4:55a	.6	3	/	178228	4.5	12.17	-	-	4	
25	BC	2pm	.9	46	/	178291	4.5	12.53				
26	BC	10am	.7	19	/	178352	4.5+	13.21				
27	BC	10am	.6	47	/			12.98				ON
28	BC	9:30	.5	57	/	178415	4.5-	12.76	23.5		4	
29	CM	8:28a	.6	29	/	178476	4.4	13.41	39	61	4	
30	CM	10:46	.6	3	/	-	-	12.03		-	4	oh
31					/							

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

ADDRESS: 93111 HWY 101 N

MONTH/YEAR

2025

Novem

DATE/TIME	INI	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
8:45	HZ	44082	.03		/			44082
9am	JT		1		/	✓	cxt	44084
8:58a	CM		1	1/2	/	✓		44086
11	Be		1.0		/			44088
911	Be		1.0		/			44091
930	De		1.0		/			44099
1:30	HF		1.6	1/2	/			44100
1000	De		1.0		/			44102
—					/			
9am	JT		1	1/2	/	✓	cxt	44105
					/			
900g	Be		1		/	✓		44114
900	De		1		/	✓		44117
9:15	HF		1.1		/			44117
930	Be		1.0		/			44119
9:09g	Am		.7		/	✓		44119
11:40	HF		.1		/			44119
					/			
1030	Be		0.5		/			44121
					/			
					/			44130
					/			44130
					/			
8:50	HF	1.2	0	1/2	/			44134
9am	JT	●	1	1/2	/			44138
9:20	HF	2.6	0	1/2	/			44142
1000	Be	LD	1.0	1/2	/			44143
1000	Be		0.5	1/2	/			44144
11:20	Gm	2.6	2.4	1/3	/			44152
					/			
					/			