

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: LANE

Conventional or Direct Filtration

Month/Year: Dec/2025

System Name: OPRD JM Honeyman Memorial State Park ID#: 41 : 91044

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	—	—	0.01	0.01
2	—	—	—	0.015	—	—	0.015
3	—	—	0.015	—	—	—	0.015
4	—	0.015	—	—	—	0.01	0.015
5	—	—	—	—	0.015	—	0.015
6	—	—	0.015	—	—	—	0.015
7	—	—	0.015	—	—	—	0.015
8	—	—	0.015	—	—	—	0.015
9	—	—	0.015	0.015	—	—	0.015
10	—	—	—	0.015	—	—	0.015
11	—	—	0.01	—	—	—	0.01
12	—	—	0.01	—	—	—	0.01
13	—	—	0.01	—	—	—	0.01
14	0.01	—	—	—	0.01	—	0.01
15	—	—	—	0.015	—	—	0.015
16	—	—	—	0.01	—	—	0.01
17	—	—	0.01	—	—	—	0.01
18	—	—	0.01	—	—	—	0.01
19	—	—	0.015	—	—	—	0.015
20	—	—	0.015	—	—	—	0.015
21	—	—	0.01	—	—	—	0.01
22	—	0.01	—	—	—	0.01	0.01
23	—	—	—	—	—	0.015	0.015
24	—	—	0.01	—	—	—	0.01
25	—	—	—	0.01	—	—	0.01
26	—	—	0.01	—	—	—	0.01
27	—	—	0.01	—	—	—	0.01
28	—	—	0.01	—	—	0.01	0.01
29	—	—	—	—	0.01	—	0.01
30	—	—	0.01	—	—	—	0.01
31	—	—	0.015	—	—	—	0.015

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		

Notes:

PRINTED NAME: Ryan Warren

SIGNATURE: *[Signature]* DATE: 1-2-2026

PHONE #: 541 997-3851 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year:

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
MM 11/25	0.98	460	470.4	12.2	6.25	31	YES	90
MM 2/41	0.89		427.4	12.8	6.37	31	YES	
MM 3/58	0.82		393.6	13.3	6.41	31	YES	
DC 4/146	0.72		345.6	13.9	6.41	31	YES	
MM 5/30	0.68		326.4	13.3	6.24	31	YES	
DC 6/39	0.73		350.4	14.4	6.23	31	YES	
DC 7/52	0.70		336.0	13.3	6.24	31	YES	
MM 8/45	0.65		312	13.7	6.36	31	YES	
MM 9/44	0.39		187.2	13.3	6.41	29	YES	
MM 10/47	0.35		168	12.8	6.21	29	YES	
MM 11/0/30	0.32		153.6	13.3	6.36	29	YES	
MM 12/21	0.55		264	11.7	6.45	30	YES	
HE 13/0/59	0.70		336	13.9	6.28	31	YES	
HE 14/55	0.74		355.2	15.0	6.30	20	YES	
HE 15/10/37	0.69		331.2	15.0	6.19	20	YES	
MM 16/42	0.67		321.6	13.9	6.24	31	YES	
MM 17/2/30	0.57		273.6	12.8	6.25	30	YES	
MM 18/40	0.43		206.4	13.3	6.40	29	YES	
MM 19/57	0.41		176.8	13.9	6.32	29	YES	
DC 20/9/38	0.36		172.8	13.3	6.21	29	YES	
DC 21/10/2	0.24		115.2	12.8	6.46	29	YES	
MM 22/9/33	0.22		105.6	12.2	6.33	29	YES	
MM 23/12	1.05		504	11.7	6.32	31	YES	
MM 24/7/1	1.01		484.8	11.7	6.40	31	YES	
HE 25/11/3	1.16		556.8	13.3	6.55	38	YES	
MM 26/9/24	1.12		537.6	12.2	6.49	32	YES	
HE 27/10/0	1.08		518.4	11.7	6.47	32	YES	
HE 28/10/10	1.37		657.6	11.7	6.29	33	YES	
MM 29/9/51	1.00		480	11.1	6.33	31	YES	
MM 30/9/28	0.85		408	10.6	6.40	31	YES	
MM 31/4/6	0.72		345.6	10.0	6.21	31	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of December, 2025

Water System Meter Readings										Girl Scout Water Usage	Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	X-740 Gallons Used	Alum Pounds	Chlorine Gallons	
1	NM	11:11	009327	14963	15,400	966100	13000	21597	0	3.12	1	
2	NM	9:37		150082	11900	966300	11200	21597	0	0	0	
3	NM	9:52		150274	19200	966435	13500	21599	1496	0	0	
4	DC	1146		150437	16300	966577	14200	21599	0	0	1	
5	NM	9:25		150556	11900	966694	11700	21599	0	0	0	
6	DC	9:37		150674	11900	966811	11700	21599	0	1-4	0	
7	DC	9:52		150840	16600	966936	12900	21599	0	1-4	0	
8	NM	9:36		151006	16,600	967055	11,900	21599	0	0	0	
9	NM	9:34	009407		16,000	967176	12,100	21599	0	0	0	
10	NM	9:37	009557		7000	967292	11,600	21599	0	0	0	
11	NM	10:10	009703		14,600	967417	12,500	21599	0	2-8	1	
12	NM	9:16	009854		15,100	967535	11,900	21599	0	0	0	
13	HE	9:59	090061		20,400	967672	13,700	21599	0	0	0	
14	HE	9:55	090079		11,400	967810	13,000	21599	0	0	0	
15	HE	10:39	090291		11,600	967937	12,700	21599	0	0	0	
16	NM	9:40		151136	13000	968054	11700	21599	0	0	0	
17	NM	11:10		151375	23,900	968186	13,200	21599	0	0	0	
18	NM	9:26		151497	12,200	968302	11,600	21599	0	3-12	1	
19	NM	9:50		151497	0	968414	11,200	21599	0	0	0	
20	DC	9:39		151680	18,300	968531	11,700	21599	0	0	0	
21	DC	10:02		151894	21,400	968659	12,800	21599	0	1-4	1	
22	NM	9:26		152073	17,900	968786	12,700	21599	0	0	0	
23	NM	9:07	090429		13,000	968926	14,000	21600	748	0	0	
24	NM	9:14	090545		11,600	969052	12,600	21600	0	0	0	
25	HE	11:07	090662		11,700	969188	13,600	21600	0	0	0	
26	NM	9:15	090700		11,800	969304	11,600	21600	0	0	0	
27	HE	10:00	090993		21,300	969444	14,000	21600	0	0	0	
28	HE	10:10	091178		19,500	969581	13,700	21600	0	0	0	
29	NM	9:47	091328		15,000	969725	14,400	21600	0	2-8	2	
30	NM	9:23		152196	12,300	969874	14,900	21600	0	0	0	
31	NM	9:41		152471	2,750	970022	14,800	21600	0	0	0	

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of December, 2025

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	-	-	-	-	-	0.72	0.98	0.42	0.24
2	-	-	-	0.68	-	-	0.69	0.39	0.08
3	-	-	0.70	-	-	-	0.82	0.77	0.26
4	-	0.58	-	-	-	0.60	0.72	0.75	0.35
5	-	-	-	-	0.58	-	0.68	0.69	0.55
6	-	-	0.60	-	-	-	0.73	0.63	0.78
7	-	-	0.50	-	-	-	0.70	0.64	0.77
8	-	-	0.60	-	-	-	0.65	0.65	0.76
9	-	-	0.80	0.84	-	-	0.39	0.60	0.74
10	-	-	-	0.68	-	-	0.35	0.56	0.60
11	-	-	0.92	-	-	-	0.32	0.53	0.57
12	-	-	0.70	-	-	-	0.55	0.40	0.42
13	-	-	1.1	-	-	-	0.70	0.31	0.46
14	1.18	-	-	-	1.18	-	0.74	0.37	0.51
15	-	-	-	0.96	-	-	0.69	0.43	0.44
16	-	-	-	0.72	-	-	0.67	0.35	0.23
17	-	-	0.78	-	-	-	0.57	0.33	0.20
18	-	-	0.72	-	-	-	0.43	0.43	0.34
19	-	-	0.79	-	-	-	0.41	0.32	0.51
20	-	-	0.59	-	-	-	0.36	0.28	0.37
21	-	-	0.52	-	-	-	0.24	0.23	0.50
22	-	0.60	-	-	-	1.20	0.72	0.21	0.48
23	-	-	-	-	-	1.20	1.05	0.37	0.45
24	-	-	-	1.1	-	-	1.01	0.49	0.33
25	-	-	-	1.04	-	-	1.16	0.51	0.28
26	-	-	1.01	-	-	-	1.12	0.45	0.41
27	-	-	0.93	-	-	-	1.08	0.42	0.20
28	-	-	0.82	-	-	1.02	1.37	0.34	0.14
29	-	-	-	-	0.82	-	1.00	0.40	0.98
30	-	-	0.72	-	-	-	0.85	0.57	0.98
31	-	-	0.62	-	-	-	0.72	0.56	0.94

Raw Turbidity

Month/Year

Dec/2025

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.85		X
2	0.87		X
3	0.41	X	
4	0.46		X
5	0.66		X
6	0.50		X
7	0.51	X	
8	0.44	X	
9	0.49	X	
10	0.60	X	
11	0.42	X	
12	0.34	X	
13	0.37		X
14	0.48		X
15	0.43		X
16	0.44	X	
17	0.46		X
18	0.44		X
19	0.63	X	
20	0.58	X	
21	0.55	X	
22	0.53		X
23	0.91		X
24	0.71		X
25	0.51	X	
26	0.42	X	
27	0.43	X	
28	0.48	X	
29	0.85		X
30	0.55		X
31	0.64		X

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT PUBLIC WATER SUPPLIES

12/31 44218
.75 CL2 ft

PS ID # 419 SA

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

MONTH/YEAR

SOURCE NAME: WELL

PHONE: 541-547-3416

2025

December

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 8:45a	Am		2.4	1/3	/	✓		44152
2 10:45a	Be		2.0		/			44156
3 9:10a	HF		2.4	1/2	/			44156
4 8:45a	Be		2.0		/			44158
5 8:55a	Be		1.7		/			44159
6 9:15	Be		1.7	1/2	/	✓		44165
7					/			
8 9:44a	Am		2.3	1/2	/	✓		44173
9 8:25a	HF		2.1	1/2	/			44174
10 8:50a	HF		2.3	2/5	/			44175
11 9am	JT		1.5	2/5	/	✓		44177
12 9:15	Be		1.0		/			44179
13 11:16a	Am		.5	2/5	/			44179
14					/			
15 2 pm	JJ		.8	2/5	/	✓	ext	44182
16 9:10a	HF		.2	2/5	/			44183
17 9:45	Be		.5		/			44183
18 9:13a	Am		.3	1/3	/	✓		44186
19					/			
20	Be		.4		/			44186
21 8:50	HF	1.3	.3	1/3	/			44190
22 8:50	HF	1.3	.3	1/3	/			44190
23 9:00	Be		.4		/			44191
24 11:40	HF	1.5	.4	1/3	/			44198
25 10:01	Am		.5	1/3	/		30th 44206	44199
26					/		31st	
27 2:00 pm	Am		1.0	1/4	/		44205	
28 9:30a	Am		1.0	1/4	/		44206	
29					/			
30	Be		1.0		/			
31 9am	JT				/			

WELL LOG: MONTHLY WATER REPORT

MONTH: December 2023

YEAR: 2023

181
21

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	JA	9am	1	shop		178541	40+2	12.77				
2	JA	9am				178602	40+1	13.38				
3	DL	1040	0.5	23		178602	40+1	12.20	37	61		
4	JT	9am				178664	40	12.95		62		
5	HF	1:05p	.6	D2		178726	35+3	13.43	40.5	62		
6	CM	8:16a	.5	2		178726	35+3	12.60	-	-	4	
7	CM	8:17a	.5	5		178761	35+3	12.49		35		Power outage
8	JT	9am				178822	35+2	13.10				
9	JT	9a	1	D.u.		178822	35+2	12.03				
10	DL	1030	1	21		178884	35+1	12.67			4	
11	HF	9:20	.6	D2		178945	35+1	13.36	40.5	61	4	
12	CM	8:18a	.5	26		178945	35+1	12.76		4		
13	CM	8:26a	.5	D2		174008	35	12.98	35	63	4	
14	CM	12:52p	.8	26		179071	30+3	13.41	39	63	4.5	
15	CM	8:26a	.6	5		179071	-	12.60	-	-	4	
16	DL	1050	.7	48		179132	30+2	13.16	39.5		4	
17	JT	9am	1	30		179132	30+2	12.24				
18												
19												Power outage
20												↓
21												
22												
23	HF	9am	.7	D2		179206	30+1	8.22				
24	HF	8:20a	.7	2		179422	25+3	13.23		216		
25	CM	8:28	.7	20		179422	25+3	12.77		4		
26	CM	8:10a	.4	58		179484	25+2	12.88		62	4	
27	CM	8:07	.6	2		179545	25+1	13.32	35	61	4	
28	JT	9am	.8	shop		174554	25+1	12.99				running
29	CM	8:22am	.4	47		179612	25	12.53	28.5	58	4	
30	HF	10:50	.7	D2		179675	24+3	12.89	32.5	63	4	
31	DL	1145	1.0	2		179783	20+3	13.31				

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.