

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **LANE**

Conventional or Direct Filtration

Month/Year: **JAN 2020**

System Name: **OPRD JM Honeyman Memorial State Park** ID#: **41 : 91044**

WTP: **TP**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	0.015	—	—	0.01	—	—	0.015
2	—	—	0.015	—	—	—	0.015
3	—	0.02	—	—	.01	—	.02
4	—	—	—	0.015	—	—	0.015
5	—	—	0.025	0.01	—	—	0.025
6	—	—	0.015	—	—	—	0.015
7	—	—	0.015	—	—	—	0.015
8	0.02	—	—	—	0.02	—	0.02
9	—	—	—	0.01	—	—	0.01
10	—	—	0.01	—	—	—	0.01
11	—	—	0.01	—	—	—	0.01
12	—	0.01	—	—	—	0.025	0.025
13	—	—	0.03	—	—	—	0.03
14	0.03	—	—	0.025	—	—	0.03
15	—	—	0.025	—	—	—	0.025
16	—	0.02	0.01	—	—	—	0.02
17	0.01	0.01	—	—	—	0.01	0.01
18	—	—	0.01	—	—	—	0.01
19	—	—	0.01	—	—	—	0.01
20	—	0.02	—	—	—	—	0.02
21	0.02	—	—	—	—	0.02	0.02
22	—	—	—	—	—	0.015	0.015
23	—	—	—	.015	—	—	.015
24	—	—	.01	—	—	—	.01
25	—	—	.05	—	—	0.015	0.015
26	0.015	—	—	—	—	0.015	0.015
27	—	—	—	—	0.015	—	0.015
28	—	—	—	0.01	—	—	0.01
29	—	0.01	—	—	—	0.015	0.015
30	—	—	—	—	.01	—	.01
31	—	—	.015	—	—	.015	.015

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings $<$ IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: **Kati Baker**

SIGNATURE: *[Signature]* DATE: **2/2/20**

PHONE #: **(541) 997-3057** CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Jan 2016

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
DC 1 12:21	0.64	480	307.2	14.4	6.65	37	YES	98
NM 2 8:37	0.04		403.2	13.3	6.52	37	YES	
DC 3 9:45	0.75		360.0	13.3	6.48	31	YES	
PD 4 10:47	0.37		177.6	13.3	6.90	35	YES	
VB 5 10:45	0.25		120	11.1	6.39	29	yes	
HC 6 09:35	0.41		196.8	11.1	6.13	30	yes	
NM 7 10:30	0.52		244.6	12.8	6.25	30	yes	
NM 8 9:29	0.69		331.2	10.6	6.43	31	yes	
NM 9 9:35	1.02		409.6	10.0	6.31	31	yes	
HE 10 11:45	0.85		408	10.6	6.28	31	yes	
HE 11 11:21	1.11		532.8	10.6	6.16	32	yes	
HE 12 9:32	1.25		600	11.1	6.20	33	yes	
HE 13 9:55	1.17		561.6	10.6	6.20	32	yes	
NM 14 9:40	1.04		499.2	10.0	6.13	32	yes	
NM 15 9:32	0.08		422.4	9.4	6.58	50	yes	
NM 16 9:30	0.01		388.8	10.6	6.46	31	yes	
HE 17 11:0	0.81		388.8	12.8	6.33	31	yes	
VB 18 11:07	0.65		312	11.7	6.34	31	yes	
LB 19 15:40	0.54		259.2	10.6	6.20	31	yes	
NM 20 9:34	0.54		259.2	11.1	6.31	31	yes	
NM 21 9:59	0.59		283.2	10.6	6.34	30	yes	
NM 22 9:12	0.71		340.8	9.4	6.63	49	yes	
NM 23 9:23	0.69		331.2	9.4	6.45	41	yes	
PD 24 10:58	0.81		388.8	10.0	6.47	31	yes	
PD 25 10:49	0.88		427.4	9.4	6.40	42	yes	
VB 26 12:16	0.92		441.6	14.4	6.26	31	yes	
VB 27 11:28	0.91		426.8	11.7	6.22	31	yes	
NM 28 9:41	0.84		403.2	12.8	6.31	31	yes	
NM 29 9:27	0.88		422.4	13.3	6.58	37	yes	
NM 30 9:13	0.77		369.6	12.2	6.27	31	yes	
PD 31 10:49	0.71		340.8	10.6	6.32	31	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

# Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of JANUARY, 2026

			Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
Date	Initial	Time	Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	748 Gallons Used	Alum Pounds	Chlorine Gallons
1	DC	12:19	891328	152589	11,800	970183	16,100	21600	Ø	1-4	1
2	MM	9:39		152710	12,100	970310	12,700	21600	Ø	Ø	Ø
3	DC	9:45		152954	24,400	970468	15,800	21600	Ø	Ø	Ø
4	RD	10:47		153072	11,800	970610	14,200	21600	Ø	Ø	Ø
5	KB	10:45		153212	14,000	970741	13,100	21600	Ø	Ø	Ø
6	HE	Ø:35	891460		13,800	970963	12,200	21600	Ø	Ø	Ø
7	MM	10:35	891689		22300	970996	13300	21600	Ø	2-8	1
8	MM	9:25	891813		12400	971110	11400	21600	Ø	Ø	Ø
9	MM	9:30	891928		11500	971236	12600	21600	Ø	Ø	1
10	HE	11:45	892078		15,000	971392	15,600	21602	1496	Ø	Ø
11	HE	11:21	892271		19,300	971577	13,500	21602	Ø	Ø	Ø
12	HE	9:32	892441		17,000	971651	12,400	21602	Ø	3-12	1
13	HE	9:55		153349	13,700	971795	14,400	21602	Ø	Ø	Ø
14	MM	9:40		153501	15200	971923	12800	21602	Ø	2-8	1
15	MM	9:27		153621	12000	972057	13400	21602	Ø	Ø	Ø
16	MM	9:27		153822	20100	972198	14100	21602	Ø	2-8	Ø
17	HE	11:10		154016	19,400	972349	15,100	21602	Ø	Ø	Ø
18	HE	11:07		154139	12,300	972495	14,600	21602	Ø	Ø	Ø
19	LB	15:45		154348	20,900	972664	16,900	21602	Ø	Ø	Ø
20	MM	9:10	892589		14800	972735	9100	21602	Ø	2-8	1
21	MM	9:55	892706		11,700	972889	13,400	21602	Ø	Ø	Ø
22	MM	9:17	892940		23400	973019	13,000	21602	Ø	Ø	Ø
23	MM	9:15	892958		1,800	973152	13,300	21602	Ø	Ø	1
24	RD	10:49	893164		20,600	973292	14,000	21602	Ø	1-4	1
25	RD	10:45	893316		15,200	973425	13,300	21602	Ø	1-4	Ø
26	KB	12:16	893433		11,700	973574	14,900	21602	Ø	Ø	Ø
27	KB	11:28		154468	12,000	973698	12,400	21602	Ø	Ø	Ø
28	MM	9:23		154601	13,300	973815	11,700	21602	Ø	Ø	Ø
29	MM	9:17		154841	24000	973957	14,200	21604	1496	2-8	1
30	MM	9:07		154960	11900	974095	13000	21604	Ø	Ø	Ø
31	RD	10:45		155214	25400	974281	18,600	21604	Ø	Ø	Ø

# Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of JANUARY, 20 26

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	0.56	—	—	0.60	—	—	0.64	0.39	0.91
2	—	—	0.64	—	—	—	0.84	0.41	0.90
3	—	0.58	—	—	0.59	—	0.75	0.38	0.78
4	—	—	—	0.56	—	—	0.37	0.38	0.66
5	—	—	0.49	1.90	—	—	0.25	0.33	0.75
6	—	—	2.0	1.49	—	—	0.41	0.25	0.59
7	—	—	1.44	—	—	—	0.52	0.37	0.48
8	2.0	—	—	—	1.60	—	0.69	0.40	0.58
9	—	—	—	1.5	—	—	1.02	0.45	0.58
10	—	—	0.5	—	—	—	0.85	0.40	0.16
11	—	—	1.7	—	—	—	1.1	0.70	0.08
12	—	1.52	—	—	—	1.25	1.25	0.8	0.27
13	—	—	1.20	—	—	—	1.17	0.75	0.42
14	1.08	—	—	1.12	—	—	1.04	0.65	0.69
15	—	—	1.08	—	—	—	0.88	0.61	0.86
16	—	1.12	1.12	—	1.12	1.1	0.81	0.54	0.82
17	1.1	1.08	—	—	—	1.1	0.81	0.59	0.92
18	—	—	1.1	—	—	—	0.65	0.61	0.93
19	—	—	1.09	—	—	—	0.54	0.65	0.97
20	—	1.36	—	—	—	—	0.54	0.65	0.74
21	1.28	—	—	—	—	1.40	0.59	0.63	0.70
22	—	—	—	—	—	1.40	0.71	0.57	0.60
23	—	—	—	1.56	—	—	0.69	0.47	0.48
24	—	—	1.40	—	—	—	0.81	0.51	0.46
25	—	—	1.32	—	—	1.0	0.88	0.43	0.42
26	—	—	—	—	—	0.56	0.92	0.50	0.40
27	—	—	—	—	0.80	—	0.91	0.44	0.41
28	—	—	—	0.88	—	—	0.84	0.43	0.45
29	—	0.90	—	—	—	1.0	0.88	0.47	0.51
30	—	—	—	—	1.0	—	0.77	0.51	0.63
31	—	—	1.0	—	—	0.94	0.71	0.73	0.75

# Raw Turbidity

Month/Year JANUARY 2026

Date	Raw Turbidity Reading	Plant On	Plant Off
1	0.47		X
2	0.51	X	
3	0.45		X
4	.53		X
5	0.38	X	
6	0.41	X	
7	0.45		X
8	0.57		X
9	1.11		X
10	0.43	X	
11	0.50	X	
12	0.46		X
13	0.40		X
14	0.50		X
15	0.70		X
16	0.42	X	
17	0.45		X
18	0.47		X
19	0.41		X
20	0.43		X
21	0.72		X
22	0.76		X
23	0.96		X
24	.36	X	
25	.41		X
26	0.91		X
27	0.67		X
28	0.43	X	
29	0.44		X
30	0.74		X
31	.42		X

**WELL LOG: MONTHLY WATER REPORT**

MONTH: January

YEAR: 2026

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	CM	8:18a	.6	21	/	179738	20 <sup>+3</sup>	12.35	26	-	4	
2	CM	8:11a	.6	2	/	179801	20 <sup>+2</sup>	12.94	38	63	4	
3	CM	8:11a	.6	19	/	179862	20 <sup>+1</sup>	13.50	37.5	61	4	
4	CM	8:14a	.6	70	/	179862	20 <sup>+1</sup>	12.35	-	-	4	
5	JT	9am	.75	shop	/	179924	20	12.89	.			
6	JT	9am			/	179986	19 <sup>+</sup>	13.46		<del>62</del>		
7	HTF	10:50	.6	24	/	179986	15 <sup>+3</sup>	12.39			4	
8	JT	9am			/	180047	15 <sup>+2</sup>	13.06				
9	CM	8:17a	.4	D1	/	180047	15 <sup>+3</sup>	12.02			4	
10	CM	8:11a	.4	47	/	180111	15 <sup>+2</sup>	12.65	253	64	4	
11	CM	8:14a	.6	22	/	180172	15 <sup>+1</sup>	13.17	36	61	4	
12	JT	9am	.8	D.U.	/	180184	15 <sup>+1</sup>	12.26				running
13	BE	1145	.6	48	/	180239	15	12.46	36	55	3.5	
14	BE	1145	.7	2	/	180300	10 <sup>+3</sup>	12.93	36	61	4	
15	JT	9am			/	180325	10 <sup>+3</sup>	12.57				running
16	BE	930	.8	D2	/	180366	10 <sup>+2.5</sup>	12.35	35	41	3.5	
17	CM	8:25a	.4	D1	/	180429	10 <sup>+2</sup>	12.89	30	63	3.5	
18	CM	8:18a	.4	8	/	180492	10 <sup>+1</sup>	13.17	30	63	3.5	
19	JT	9am			/	180553	10	13.29				
20	JT	9am	1	shop	/	180591	5 <sup>+3</sup>	12.88				running
21	HTF	9:50a	.7	D2	/	180618	5 <sup>+3</sup>	12.37		27		
22	CM	8:36a	.5	2	/	180680	5 <sup>+2</sup>	12.98	34	62	3.5	
23	BE	930	.7	20	/	180743	5 <sup>+1.5</sup>	13.43	35	63	3.5	
24	CM	8:11a	.4	18	/	180743	45 <sup>+3</sup>	12.29	-	-	3	
25	CM	8:13a	.4	3	/	180814	45 <sup>+2</sup>	12.77	32	71	3.5	
26	JT	9am	1	D.U.	/	180877	45 <sup>+1</sup>	13.02	32.5	63	3.5	
27	BE	1040	.5	26	/	180941	45	13.5		64	3.5	
28	BE	1108	.4	56	/	180941	45		34.5		3.5	
29	HTF	10:30	.4	D1	/	181003	40 <sup>+3</sup>	12.84	35.5	62	3.5	
30	CM	8:19	.4	29	/	181066	40 <sup>+3</sup>	13.50	36	63	3.5	running
31	CM	8:22	.4	10	/	181066	40 <sup>+3</sup>	12.39				

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK  
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

SOURCE NAME: WELL

PHONE: 541-547-3416

MONTH/YEAR

Jan. 2026

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1								
2 8:45	HC		1.0					44228
3 8:45	HC		.75					44233
4 9am	JT		.75	1/3		✓ cxt		44237
5 8:50a	HF		1.3	1/3		✓		44242
6 170p	Be		1.0			✓		44245
7 9:11a	HF		1.1	1/3		✓		44250
8 9:30	Be		0.7					44251
9 9:30	Be		0.5					44252
10 9:55	Be		0.4	3/5				44255
11			<del>1.0</del>	3/5				
12 8:47	CM		1.0	3/5		✓		44260
13								
14 10:25a	HF		2.2	3/5		✓		44277
15 8:50a	Be		1.0					44279
16 9:10a	HF		1.5	3/5				44280
17 9:00	HC		1.0					44286
18 9am	JT		2.0			✓ cxt		44290
19 9:10a	CM		1.5	3/5		✓		44292
20 9:30	Be		1.0					44293
21								
22 9:15	Be		0.6					44295
23 8:50	HF		1.2	1/2				44296
24								
25 9am	JT		1	1/3 c		✓ cxt		44298
26 9:15a	HF		.4	1/2				44298
27 8:40a	HF		.2	1/2				44298
28 9:30	HF		.4	1/2				44301
29 9:15	Be		.5					44303
30 9:20	Be		.4	1/2				44304
31 9:00	HC		.75	1/2			Raw water at cxt	<del>44307</del> 44307