

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **LANE**

Conventional or Direct Filtration

Month/Year: **Feb 2026**

System Name: **OPRD JM Honeyman Memorial State Park** ID#: **41 : 91044**

WTP: **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	—	0.02	—	0.02
2	—	—	—	0.02	—	—	0.02
3	—	—	—	0.015	—	—	0.015
4	—	—	0.01	—	—	0.01	0.01
5	—	—	0.01	—	—	—	0.01
6	—	0.01	—	—	—	—	0.01
7	0.015	—	—	—	0.015	—	0.015
8	—	—	—	0.01	—	—	0.01
9	—	—	—	0.015	—	—	0.015
10	—	—	0.01	—	—	—	0.01
11	—	0.01	—	—	—	0.02	0.02
12	—	—	—	—	0.015	—	0.015
13	—	—	0.015	—	—	—	0.015
14	0.01	—	—	0.01	—	—	0.01
15	—	0.01	—	—	0.015	—	0.015
16	—	—	—	0.01	—	—	0.01
17	—	—	0.01	—	—	—	0.01
18	—	—	0.01	—	—	—	0.01
19	0.01	—	—	—	—	0.015	0.015
20	—	—	—	0.015	—	—	0.015
21	—	—	0.02	—	—	—	0.02
22	—	—	0.015	—	—	—	0.015
23	—	—	—	—	—	0.015	0.015
24	—	—	—	0.015	—	—	0.015
25	—	—	0.015	—	—	—	0.015
26	—	0.015	—	—	—	0.01	0.015
27	—	—	—	0.015	—	—	0.015
28	—	—	0.015	—	—	—	0.015
29	—	—	—	—	—	—	—
30	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
✓ 95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: 2/22-2/24 water turned off to sensors
 Readings not valid. NM

PRINTED NAME: **Ryan Warren**
 SIGNATURE: *[Signature]* DATE: **3-2-26**
 PHONE #: **(241) 997-3851** CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: Feb/2026

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
PD 1 11:30	0.64	480	307.2	11.1	6.33	31	Yes	98
LB 2 13:25	0.65		312	10.6	6.26	31	yes	
LB 3 10:03	0.67		321.4	10.6	6.18	31	yes	
NM 4 9:53	0.69		331.2	11.7	6.37	31	yes	
NM 5 14:20	0.58		278.4	12.8	6.41	30	yes	
NM 6 9:27	0.78		374.4	11.7	6.56	37	yes	
NM 7 9:43	0.91		436.8	11.1	6.26	31	yes	
NM 8 10:34	0.92		441.6	10.6	6.14	31	yes	
LB 9 10:00	0.89		427.2	11.1	6.16	31	yes	
LB 10 9:50	0.90		432	11.1	6.36	31	yes	
NM 11 10:31	0.87		417.6	10.6	6.25	31	yes	
NM 12 9:41	0.77		369.6	10.0	6.44	31	yes	
NM 13 9:40	0.74		355.2	11.1	6.26	31	yes	
NM 14 9:20	0.71		340.8	10.6	6.51	37	yes	
NM 15 9:12	0.66		316.8	10.0	6.26	31	yes	
PD 16 9:36	0.60		288	10.6	6.38	30	yes	
PD 17 9:25	0.74		355.2	10.0	6.20	31	yes	
UP 18 9:44	0.83		350.4	10.0	6.47	31 ⁴⁵	yes	
NM 19 9:25	0.84		403.2	10.0	6.19	31	yes	
NM 20 9:17	0.85		405.6	9.4	6.32	42	yes	
PD 21 9:40	0.86		417.8	10.0	6.42	31	yes	
PD 22 9:15	0.75		360	9.4	6.69	49	yes	
LB 23 10:15	0.87		417.6	15.0	6.56	25	yes	
LB 24 9:30	0.79		379.2	16.1	7.74	29	yes	
NM 25 9:36	0.92		441.6	10.0	7.08	45	yes	
NM 26 9:33	0.82		393.6	9.4	6.32	42	yes	
NM 27 9:41	0.77		369.6	10.0	6.42	31	yes	
NM 28 9:35	0.74		355.2	10.6	6.25	31	yes	
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Raw Turbidity

Month/Year Feb. 2026

Date	Raw Turbidity Reading	Plant On	Plant Off
1	.54		X
2	0.33	X	
3	0.30	X	
4	0.36	X	
5	0.67		X
6	0.48		X
7	0.71		X
8	0.49		X
9	0.50	✓	
10	0.34		X
11	0.53		X
12	0.73		X
13	0.37	X	
14	0.72		X
15	0.44		X
16	.34	X	
17	.36	X	
18	0.37		X
19	0.69		X
20	0.71		X
21	.31	X	
22	.44		X
23	.48		X
24	.60		X
25	0.53	X	
26	0.40		X
27	0.68		X
28	0.44	X	
29			
30			
31			

WELL LOG: MONTHLY WATER REPORT

MONTH: February

YEAR: 2026

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	CM	8:13	.4	2	/	181137	40 ⁺²	12.82	32.5	-	3.5	
2	CM	9:38 _a	.2	D1	/	181199	40 ^{tl}	13.12	32	62	3.5	
3	HT	12:35	.4	D2	/	181263	40	13.5	35	64	4	
4	DC	9:50	.5	47	/	181263	40	12.46			3.5	small dip
5	JT	9am	.8	shop	/	181327	40	12.81	32.5	64	4	shower
6	CM	1100	.1	51	/	181389	35 ⁺³	13.09	31	62	3.5	Issue st
7	CM	9:58 _a	.5	2	/	181409	35 ^{+2.5}	12.44		20	3.5	Running
8	CM	8:24 _a	.5	58	/	181457	35 ⁺²	12.58	31	68	3.5	not used for full fill
9	CM	8:28 _a	.2	D2	/	181520	35 ^{tl}	13.08	32	63	3.5	
10	CM	9:45 _A	.3	D2	/	181582	35	13.35	31.5	62	4	
11	JT	9:30 _a	.8	shop	/	181582	35	12.35	-			Same
12	CM	8:18 _a	.6	D1	/	181646	30 ^{+3.5}	12.93	34.5	64	3.5	
13	DC	10:30	.7	58	/	181708	30 ⁺³	13.26	34.5	62	3.5	running
14	CM	10:14 _a	.6	2	/	181712	30 ⁺³	12.10	-	-	-	running
15	CM	10:20 _a	.6	18	/	181773	30 ⁺²	12.41	30	65	3.5	gal used full run
16	JT	10am			/	181840	30 ^{tl}	12.77	31	67	3.5	
17	SM	9:40 _A	.6	D2	/	181890 ³	30	13.23	32	50	3.5	
18	JT	9am	1	22	/	181902	30	12.08	-	-	3.5	About to run
19	CM	9:33 _a	.6	3	/	181967	25 ⁺³	12.58	31.5	65	3.5	
20	SM	9:30 _A	.8	28	/	182029	25 ⁺³	13.04	34	62	3.5	
21	SM	9:45 _A	.5	54	/	182094	25 ⁺²	13.47		65	3.5	Full running
22	CM	10:01	.5	29	/	182095	25 ⁺²	12.27		-	3.5	
23	JT	9am	.8	shop	/	182159	25 ⁺¹	12.79	32.5	64	3	
24	JT	9am	1	30	/	18222	25 ⁺	13.33	32.5	63	3.5	
25	CM	10:30	D.2	D2	/	182259	25	12.74	30	34	3.5	Full Running
26	SM	9am	.5	02	/	182287	25-	12.5		?	3.5	About to run
27	SM	8:50 _A	.5	02	/	182354	20 ⁺³	12.87	30	67	4	
28	SM	10 _A	.5	02	/	182418	20 ⁺²	13.09	31	64	3.5	
29					/							
30					/							
31					/							

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

MONTH/YEAR

SOURCE NAME: WELL

PHONE: 541-547-3416

2026

2026 DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 Feb	JT		.8	1/2	/	✓ cxt		44311
2	JT		1.5		/	✓ cxt		44313
3 9:40	HF		1.4	1/2	/			44320
4 8:40	HF		1.3	1/2	/			44321
5 8:50	HF		1.1	1/2	/			44324
6 9:03	CM		1.3	1/2	/	✓ cxt		44327
7 9:15	De		1.0		/			44328
8 9am	JT		1		/	✓ cxt		44331
9 9am	JT		.8	2/5	/	✓ cxt		44334
10 8:45	HF		1.1	2/5	/			44334
11 8:35	HF		1.2		/			44337
12 9:10	CSM		1.0	2/5	/	✓		44337
13 9AM	CSM		1.0	2/5	/			44337
14					/			
15 C					/			
16 9:06a	CM		.8	2/5	/	✓		44 ³³ 313
17 9:25	Bc		.3		/			44343
18 9:30a	CSM		.3	2/5	/			44343
19 10:30	JT		.5	2/5	/	✓		44347
20 9:30	Be		.6	2/5	/			44348
21 8:41a	CM		.6		/	✓		44349
22 3pm	JT		.6	1/4	/	✓		44351
23 9:30	HF		.5		/			44353
24 9:15	CSM		.5	1/4	/	✓		44354
25 9am	JT		.7	1/4	/	✓		44357
26 8:45	CSM		.7	1/4	/	✓		44357
27 10AM	CSM		.5	1/4	/	✓		44357
28 8:45a	CM		.5	1/4	/	✓		44358
29					/			
30					/			
31					/			