

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: **LANE**

Conventional or Direct Filtration

Month/Year: **March 2026**

System Name: **OPRD JM Honeyman Memorial State Park** ID#: **41 : 91044**

WTP: **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	0.03	—	—	—	—	0.03
2	—	—	—	—	0.01	—	0.01
3	—	—	—	0.01	—	—	0.01
4	—	—	0.01	—	—	—	0.01
5	—	—	0.01	—	—	—	0.01
6	—	0.01	—	—	—	—	0.01 PD
7	—	—	—	0.015	—	—	0.015
8	—	—	0.015	0.01	—	—	0.015
9	—	—	0.01	—	—	—	0.01
10	0.01	—	—	—	0.015	—	0.015
11	—	—	0.03	—	—	—	0.03
12	—	0.03	—	—	—	—	0.03
13	0.015	—	—	—	0.03	—	0.03
14	—	—	0.025	—	—	—	0.025
15	0.03	—	—	—	—	—	0.03
16	—	—	0.02	—	—	—	0.02
17	—	0.01	—	—	0.01	—	0.01
18	—	—	0.015	—	—	—	0.015
19	—	—	0.015	—	—	—	0.015
20	—	0.01	—	—	—	0.01	0.01
21	—	—	—	0.01	—	—	0.01
22	0.01	—	—	—	0.01	—	0.01
23	—	—	—	0.015	—	—	0.015 GA
24	0.025	—	—	—	0.04	—	0.04
25	—	—	0.04	—	—	0.03	0.04
26	—	—	—	0.04	—	—	0.04
27	0.03	—	—	—	0.025	—	0.03
28	—	—	0.02	—	—	—	0.02
29	0.01	—	—	—	0.01	—	0.01
30	—	—	—	0.015	—	—	0.015
31	—	—	0.015	—	—	—	0.015

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: **Mathan Mishra**

SIGNATURE: *Mathan Mishra*

PHONE #: **(541) 999-5615**

DATE: **4/1/26**

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD JM Honeyman Memorial State Park ID#: 41:91044

Month/Year: March 2020

Disinfection Giardia Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
PD 11:41	.70	480	336	10.6	6.57	37	yes	98
PD 21:45	.68		326.4	11.1	6.36	31	yes	
VB 30956	0.66		316.8	12.2	6.28	31	yes	
MM 41003	0.68		326.4	11.1	6.41	31	yes	
MM 5 9:32	0.82		393.6	10.6	6.63	37	yes	
HE 60941	0.74		355.2	10.8	6.45	31	yes	
PD 711:40	.90		432	11.1	6.32	31	yes	
PD 811:24	.71		340.8	11.7	6.28	31	yes	
PD 911:45	.84		403.2	11.1	6.61	37	yes	
VE 100945	0.94		451.2	10.6	6.77	37	yes	
LB 110935	0.86		428	12.2	6.46	31	yes	
MM 1211:39	0.89		427.2	10.0	6.26	31	yes	
VB 131511	0.82		393.6	12.8	6.30	31	yes	
MM 1411:58	0.77		369.6	11.1	6.42	31	yes	
MM 1510:05	0.68		326.4	10.6	6.27	31	yes	
PD 1611:30	.63		302.4	11.1	6.56	30	yes	
HE 17 9:34	0.61		292.8	11.1	6.58	37	yes	
MM 18 9:45	0.66		316.8	10.6	6.43	31	yes	
MM 19 9:35	0.70		336	11.7	6.56	37	yes	
MM 20 9:50	0.66		316.8	10.6	6.41	31	yes	
MM 21 9:23	0.71		340.8	12.8	6.37	31	yes	
MM 22 9:46	0.70		336	11.1	6.99	37	yes	
GA 23 12:21	.80		384	12.8	6.50	31	yes	
GA 24 10:27	.61		292.8	12.8	6.73	37	yes	
HE 25 10:30pm	0.67		321.6	11.6	7.05	44	yes	
HE 26 11:57am	0.54		259.2	11.3	6.70	36	yes	
GA 27 9:54	.48		230.4	11.7	6.73	36	yes	
MM 28 9:43	0.45		216	11.1	6.38	30	yes	
MM 29 11:34	0.45		216	11.1	7.08	43	yes	
RW 30 12:00	.54		259.2	11.1	7.70	51	yes	
PD 31 11:30	.58		278.4	11.7	6.63	36	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

HECETA HEAD STATE PARK
MONTHLY TURBIDITY REPORT, PUBLIC WATER SUPPLIES

PS ID # 4191048A

ADDRESS: 93111 HWY 101 N

SYSTEM NAME: HECETA HEAD STATE PARK

FLORENCE, OR 97439

SOURCE NAME: WELL

PHONE: 541-547-3416

MONTH/YEAR

2026

March 2026

DATE/TIME	INITIALS	C/2 RESIDUAL		COMMENTS				METER READING X10
		CONTACT TANK	CXT	JUG LEVEL	MIXED CL2	FLUSHED LINE	OTHER	
1 3/1, 9am	JT		1	1/4	/	✓ cxt		44363
2 9am	JT		.7	1/4	/	✓ cxt		44367
3 9:10A	CSM		.5	1/4	/	✓		44368
4 9:25a	LZL		.8	1/4	/	✓ cxt		44375
5 9:30	BC		.8		/			44377
6 9:49a	CM		1.0	1/5	/	✓		44378
7 9:02a	LL		1.0	1/6	/	✓ cxt		44382
8 9:30am	JT		.8	1/6	/	✓ cxt		44386
9 9:20a	LL		1.02	refilled	/	✓ cxt		44391
10 10am	JT		1	Full	/	✓ cxt		44393
11 9:15A	CSM		.7	Full	/	✓		44395
12					/			
13 9:30	BC		.8	Full	/			44395
14 8:45a	LL		.4	fullish	/	✓ cxt		44398
15 8:37a	LL		.5	9/10	/	✓ cxt		44401
16 8:47a	LL		1.0	9/10	/	✓ cxt		44406
17 10:30	BC		0.8		/			44406
18 9:00	BC		0.5		/			44407
19					/			
20 12	LL		.7	9/10	/	✓ cxt		44413
21 9	LL		.9	9/10	/	✓ cxt		44416
22 10:45	LL		1.0	9/10	/	✓ cxt		44424
23 9:00am	JT		1.0		/	✓ cxt		44428
24 9:30	BC		0.8		/			44432
25 9:15A	CSM		1.0	9/10	/	✓		44438
26 9:45	BC		0.9		/			44438
27 9:45	LL		1.0	9/10	/	✓ cxt		44442
28 9:07a	CM		.8	8/10	/	✓ cxt		44446
29 9:02a	LL		1.0	8/10	/	✓ cxt		44450
30 9:23a	LL		1.5	7/10	/	✓ cxt		44459
31					/			

WELL LOG: MONTHLY WATER REPORT

MONTH: *MARCH*

YEAR: *2026*

	INT.	TIME	CL2	SITE	MIX	Meter	CL2 TANK	PLANT LEVEL	hr between full	Gallons Used	length of time between	notes
1	<i>CM</i>	<i>10:06a</i>	<i>.5</i>	<i>2</i>		<i>182481</i>	<i>20^H</i>	<i>13AS</i>	<i>30</i>	<i>-</i>	<i>3.5</i>	<i>Running</i>
2	<i>CM</i>	<i>8:22g</i>	<i>.4</i>	<i>20</i>		<i>182483</i>	<i>20^H</i>	<i>12.32</i>			<i>3.5</i>	
3	<i>A</i>	<i>9³⁰am</i>	<i>.8</i>	<i>58</i>		<i>182546</i>	<i>20</i>	<i>12.77</i>	<i>30</i>	<i>63</i>	<i>3.5</i>	
4	<i>SM</i>	<i>9:30 AM</i>	<i>.5</i>	<i>53</i>		<i>182608</i>	<i>15+3</i>	<i>13.12</i>	<i>28</i>	<i>62</i>	<i>3.5</i>	
5	<i>ZC</i>	<i>9am</i>	<i>.5</i>	<i>D1</i>		<i>182673</i>	<i>15+2^{1/2}</i>	<i>13.46</i>	<i>32</i>	<i>65</i>	<i>3.5</i>	
6	<i>CSM</i>	<i>8:55</i>	<i>.4</i>	<i>D2</i>		<i>182673</i>	<i>15+2</i>	<i>12.46</i>	<i>0</i>	<i>0</i>	<i>3</i>	
7	<i>CM</i>	<i>8:20a</i>	<i>.5</i>	<i>19</i>		<i>182736</i>	<i>15+2</i>	<i>12.90</i>	<i>32.5</i>	<i>63</i>	<i>3.5</i>	
8	<i>CM</i>	<i>9:49</i>	<i>.4</i>	<i>29</i>		<i>182798</i>	<i>15+1</i>	<i>12.95</i>	<i>28</i>	<i>62</i>	<i>3.5</i>	
9	<i>CM</i>	<i>9am</i>	<i>.8</i>	<i>shop</i>		<i>182860</i>	<i>15</i>	<i>13.39</i>	<i>29.5</i>	<i>62</i>	<i>3.5</i>	<i>3.75</i>
10	<i>Be</i>	<i>10:45</i>	<i>.5</i>	<i>26</i>		<i>182924</i>	<i>10^H</i>	<i>13.46</i>	<i>31</i>	<i>64</i>	<i>3.5</i>	
11	<i>JT</i>	<i>Noon</i>	<i>.7</i>	<i>D.U.</i>		<i>182924</i>	<i>10^H</i>	<i>12.26</i>			<i>3</i>	<i>About to run</i>
12	<i>CM</i>	<i>1:21 pm</i>	<i>.5</i>	<i>D1</i>		<i>182987</i>	<i>10^H</i>	<i>12.74</i>	<i>31.5</i>	<i>63</i>	<i>3.5</i>	
13	<i>LL</i>	<i>9:30a</i>	<i>.6</i>	<i>DV</i>		<i>183049</i>	<i>10^H</i>	<i>13.38</i>	<i>32</i>	<i>62</i>		<i>power went out</i>
14	<i>CM</i>	<i>8:24</i>	<i>.5</i>	<i>58</i>		<i>183049</i>	<i>10^H</i>	<i>12.16</i>	<i>-</i>	<i>-</i>	<i>-</i>	<i>↑</i>
15	<i>CM</i>	<i>11:39a</i>	<i>.5</i>	<i>2</i>		<i>183117</i>	<i>10</i>	<i>12.23</i>	<i>28</i>	<i>68</i>	<i>3</i>	
16	<i>CM</i>	<i>10:55a</i>	<i>.5</i>	<i>56</i>		<i>183244</i>						
17	<i>CSM</i>	<i>10:55a</i>	<i>.5</i>	<i>56</i>		<i>183244</i>	<i>5+3</i>	<i>12.96</i>	<i>32</i>	<i>127</i>	<i>3</i>	
18	<i>CSM</i>	<i>12:50p</i>	<i>.5</i>	<i>D1</i>		<i>183310</i>	<i>5+2</i>	<i>13.31</i>	<i>32</i>	<i>74</i>	<i>4</i>	
19	<i>CSM</i>	<i>9:46a</i>	<i>.5</i>	<i>03</i>		<i>183310</i>	<i>5+2</i>	<i>13.5</i>	<i>0</i>	<i>0</i>		
20	<i>CSM</i>	<i>10:40a</i>	<i>.5</i>	<i>D1</i>		<i>183375</i>	<i>5+1</i>	<i>13.35</i>	<i>31</i>	<i>105</i>	<i>3</i>	
21	<i>CSM</i>	<i>11:40a</i>	<i>.4</i>	<i>29</i>		<i>183440</i>	<i>5</i>	<i>12.71</i>	<i>30</i>	<i>65</i>	<i>3</i>	
22	<i>A</i>	<i>9:30a</i>	<i>.8</i>	<i>shop</i>		<i>183503</i>	<i>4+</i>	<i>13.03</i>	<i>26.5</i>	<i>63</i>	<i>3</i>	
23	<i>LL</i>	<i>10a</i>	<i>.6</i>	<i>D1</i>		<i>183565</i>	<i>4-</i>	<i>13.10</i>	<i>26</i>	<i>62</i>	<i>3.5</i>	<i>Added cl2, 43</i>
24	<i>CSM</i>	<i>9:50a</i>	<i>.5</i>	<i>29</i>		<i>183635</i>	<i>40^H</i>	<i>12.71</i>	<i>16.5</i>	<i>70</i>	<i>3</i>	
25	<i>10am</i>	<i>JT</i>	<i>.8</i>	<i>2</i>		<i>183701</i>	<i>40^H</i>	<i>12.95</i>	<i>27.5</i>	<i>66</i>	<i>3</i>	
26	<i>10:30</i>	<i>CSM</i>	<i>.5</i>	<i>D2</i>		<i>183766</i>	<i>40</i>	<i>12.80</i>	<i>26</i>	<i>65</i>	<i>2</i>	
27	<i>9:55g</i>	<i>CM</i>	<i>.5</i>	<i>18</i>		<i>183832</i>	<i>35^H</i>	<i>12.89</i>	<i>23</i>	<i>66</i>	<i>3</i>	
28	<i>9:30</i>	<i>Be</i>	<i>.6</i>	<i>71</i>		<i>183898</i>	<i>35+2</i>	<i>12.88</i>	<i>23</i>	<i>66</i>	<i>3</i>	
29	<i>8:26a</i>	<i>CM</i>	<i>.4</i>	<i>25</i>		<i>183965</i>	<i>35+1</i>	<i>12.95</i>	<i>24</i>	<i>67</i>	<i>3</i>	
30	<i>9am</i>	<i>A</i>	<i>.8</i>	<i>shop</i>		<i>184029</i>	<i>35+</i>	<i>12.48</i>	<i>25</i>	<i>64</i>	<i>3.5</i>	
31	<i>9:05am</i>	<i>L</i>	<i>.5</i>	<i>D1</i>		<i>184092</i>	<i>35</i>	<i>13.26</i>	<i>29</i>	<i>63</i>	<i>3</i>	

Dip in graph / flushed C-loop: 3/23

hr between full-time from 1 day full to next record on second full day, Gallons used is day 2 subtracted from day 1, length of time between readings is time at start of longest line to time at end of first drop.

Honeyman State Park Water System

ID # 41-91044

Water and Chemical Usage Totals for the Month of March, 2026

Date	Initial	Time	Water System Meter Readings					Girl Scout Water Usage		Water Plant Chemical Usage	
			Meter 1 Reading	Meter 2 Reading	Gallons Treated (Source)	Booster Pump Reading	Gallons Used Booster	Meter Cubic Ft	X 748 Gallons Used	Alum Pounds	Chlorine Gallons
1	PD	11:40		157777	23,100	978366	16,900	21606	0	0	0
2	PD	1:44	895485	157891	11,900	97854	14,800	21606	0	0	0
3	KB	09:56	895615		13,000	978626	11,200	21606	0	2-8	1
4	NM	9:57	895819		20,400	978776	15,000	21608	1,496	0	0
5	NM	9:25	896002		18,300	978905	12,900	21608	0	1-4	1
6	HE	09:44	896123		12,100	979042	13,700	21608	0	2-8	0
7	PD	11:40	896243		12,000	979208	16,600	21608	0	1-4	1
8	PD	11:24	896441		14,800	979355	14,700	21608	0	2-8	0
9	PD	11:41	896654	157891	21,300	979507	15,200	21608	0	0	0
10	HE	09:49		158014	12,300	979650	14,300	21610	1,496	0	0
11	LB	09:35		158133	11,900	979793	14,300	21611	748	0	1
12	NM	1:21		158407	27,400	979962	16,900	21612	748	0	0
13	KB	15:11		158525	11,800	980118	15,600	21612	0	3-12	0
14	NM	11:55		158798	27,300	980270	15,200	21615	2,244	0	1
15	NM	10:00		158916	12,000	980410	14,000	21615	0	0	0
16	PD	11:30	896654	159159	24,100	980583	17,300	21617	1,496	2-8	1
17	HE	9:55am	896771		11,200	980714	13,100	21617	0	0	0
18	NM	9:50	896886		11,500	980872	15,800	21619	1,496	0	0
19	NM	9:34	897059		17,300	981065	14,300	21619	0	0	0
20	NM	4:03	897283		22,400	981174	15,900	21621	1,496	2-8	1
21	NM	9:19	897405		12,200	981330	15,600	21621	0	0	0
22	NM	9:34	897649		24,400	981522	19,200	21624	2,244	2-8	1
23	GA	12:21	897801		15,200	981730	20,800	21626	1,496	0	0
24	GA	10:03		159416	25,700	981902	17,200	21628	1,496	0	1
25	HE	12:21pm		159675	25,900	982117	21,500	21631	2,244	0	0
26	HE	11:57am		159818	14,300	982304	18,700	21634	2,244	2-8	0
27	GA	9:49		160054	23,600	982479	17,500	21637	2,244	0	1
28	NM	9:32		160179	12,500	982657	17,800	21637	0	0	0
29	NM	11:24		160476	29,700	982870	21,300	21639	1,496	3-12	0
30	BW	12:00		160599	12,300	983025	15,500	21639	0	0	1
31	PD	11:22	898026		22,500	983167	14,200	21639	0	2-8	1

Honeyman State Park Water System

ID # 41-91044

Free Chlorine Residual in P.P.M. for the Month of March, 2016

DATE	Water Plant Effluent Chloride						Distribution System		
	12 a.m.	4 a.m.	8 a.m.	12 p.m.	4 p.m.	8 p.m.	H Sec	Cleawox	E Woahink
1	—	1.22	—	—	—	—	.70	.74	.70
2	—	—	—	—	1.44	—	.68	.28	.82
3	—	—	—	1.44	—	—	0.64	0.25	0.65
4	—	—	1.48	—	—	—	0.68	0.27	0.61
5	—	—	1.49	—	—	—	0.82	0.31	0.55
6	—	1.57	—	—	—	—	0.74	0.51	0.59
7	—	—	—	1.5 pp	—	—	.90	.48	.61
8	—	—	1.45 pp	1.52	—	—	.71	.48	.68
9	—	—	1.47	—	—	—	.84	.50	.71
10	1.3	—	—	—	1.3	—	0.94	0.68	0.88
11	—	—	1.30	—	—	—	0.86	0.82	0.63
12	—	1.25	—	—	—	—	0.89	0.71	0.63
13	1.28	—	—	—	1.28	—	0.82	0.79	0.67
14	—	—	1.04	—	—	—	0.79	0.79	0.72
15	1.00	—	—	—	—	—	0.68	0.69	0.71
16	—	—	1.2	—	—	—	.63	.63	.71
17	—	1.4	—	—	1.44	—	0.61	0.53	0.75
18	—	—	—	1.24	—	—	0.66	0.51	0.69
19	—	—	1.24	1.24	—	—	0.70	0.60	0.56
20	—	1.36	—	—	—	1.56	0.66	0.50	0.46
21	—	—	—	1.52	—	—	0.71	0.48	0.42
22	1.50	—	—	—	1.44	—	0.70	0.53	0.44
23	—	—	—	.80	—	—	.80	.57	.46
24	.76	—	—	0.80	0.68	—	.61	.76	.51
25	—	—	0.72	—	—	0.7	0.67	0.61	0.49
26	—	—	—	1.00	—	—	0.54	0.55	0.51
27	1.00	—	—	—	0.70	—	.48	.48	.54
28	—	—	0.80	—	—	—	0.45	0.44	0.44
29	0.78	1.76	—	—	.76	—	0.45	0.43	0.52
30	—	—	—	.98	—	—	.54		
31	—	—	1.00	—	—	—	.58	.29	.33