

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: OPRD BEVERLY BEACH STATE PARK **ID #:** 419105Z **WTP-:** **Month/Year:** JUNE 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.029	0.029	OFF	OFF	OFF	0.028	12AM, 0.400 / 0.029
2	0.028	0.028	OFF	0.030	OFF	OFF	1200 / 0.030
3	0.029	0.029	OFF	OFF	0.039	0.029	1200 / 0.059
4	0.027	OFF	OFF	0.028	OFF	OFF	1200 / 0.028
5	0.029	0.029	OFF	OFF	0.029	0.029	12AM, 0.400, 1600, 2000 / 0.029
6	0.029	0.029	OFF	OFF	OFF	0.029	12AM, 1.400, 2000 / 0.029
7	0.029	OFF	OFF	OFF	0.029	0.029	12AM, 1600, 2000 / 0.029
8	0.029	OFF	OFF	OFF	0.029	0.029	12AM, 1600, 2000 / 0.029
9	0.030	OFF	OFF	OFF	0.030	0.029	2400, 1600 / 0.030
10	0.030	0.030	OFF	0.029	OFF	OFF	12AM, 0.400 / 0.030
11	0.029	0.029	OFF	OFF	0.029	0.029	12AM, 0.400, 1600, 2000 / 0.029
12	OFF	OFF	0.030	0.039	0.030	0.029	1200 / 0.039
13	OFF	OFF	0.031	OFF	OFF	OFF	0.800 / 0.031
14	OFF	OFF	OFF	OFF	0.032	0.030	1600 / 0.032
15	0.030	0.030	0.030	0.030	0.030	0.030	All / 0.030
16	0.029	0.030	OFF	0.030	0.030	OFF	0.400, 1200, 1600 / 0.030
17	0.029	0.029	OFF	0.029	0.030	OFF	1600 / 0.030
18	0.029	0.029	OFF	0.029	0.029	OFF	12AM, 0.400, 1200, 1600 / 0.029
19	0.029	0.029	OFF	OFF	0.029	0.029	12AM, 0.400, 1600, 2000 / 0.029
20	0.029	0.029	OFF	0.030	0.030	0.029	1200, 1600 / 0.030
21	0.030	0.030	OFF	0.030	0.030	0.029	12AM, 0.400, 1200, 1600 / 0.029
22	0.029	OFF	OFF	OFF	0.030	0.029	1600 / 0.030
23	0.030	0.030	OFF	0.030	0.031	0.030	1600 / 0.031
24	0.029	0.030	OFF	0.030	0.030	OFF	4AM, 12PM, 4PM / 0.030
25	0.029	0.029	OFF	0.030	0.030	OFF	1200, 1600 / 0.030
26	0.029	0.029	OFF	OFF	0.029	0.029	All EXC 0.800, 1200 / 0.029
27	0.029	0.029	0.029	0.042	0.030	0.031	1200 / 0.042
28	0.030	0.030	OFF	0.033	0.030	0.030	1200 / 0.033
29	0.030	OFF	OFF	OFF	0.031	0.030	1600 / 0.031
30	0.032	OFF	OFF	0.032	0.031	0.031	12AM, 12PM / 0.032
31							

<p>Slow Sand/Membrane/DE Filtration/Unfiltered</p> <p style="text-align: center;">Monthly Summary</p> <p>95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No</p>	<p style="text-align: center;">Monthly Summary (Answer Yes or No)</p> <table style="width: 100%;"> <tr> <td style="width: 33%;"> CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No </td> <td style="width: 33%;"> All Cl₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No </td> <td style="width: 33%;"></td> </tr> </table>	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No		
CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No				
<p>Notes:</p>	<p>PRINTED NAME: JAMES PICCOLOTTI</p> <table style="width: 100%;"> <tr> <td style="width: 70%;"> SIGNATURE: </td> <td style="width: 30%;"> DATE: 7-3-21 </td> </tr> <tr> <td> PHONE #: (541) 2654560 </td> <td> CERT #: D-08535-1 T-08560-1 </td> </tr> </table>	SIGNATURE:	DATE: 7-3-21	PHONE #: (541) 2654560	CERT #: D-08535-1 T-08560-1
SIGNATURE:	DATE: 7-3-21				
PHONE #: (541) 2654560	CERT #: D-08535-1 T-08560-1				

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP-:

Month/Year: JUNE 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
1/6/21	0.74	1091	808	12.6	7.6	18	YES	28.0
2/6/21	0.71	952	676	12.5	7.6	18	YES	32.1
3/6/21	0.63	1166	735	13.3	7.6	18	YES	26.2
4/6/21	0.69	904	624	13.4	7.6	18	YES	33.8
5/6/21	0.64	840	537	13.6	7.7	18	YES	36.4
6/6/21	0.61	1080	659	13.2	7.6	18	YES	28.3
7/6/21	0.65	1080	702	13.5	7.6	18	YES	28.3
8/6/21	0.68	1005	684	13.4	7.7	18	YES	30.4
9/6/21	0.67	983	658	13.3	7.7	18	YES	31.1
10/6/21	0.65	1076	699	13.3	7.7	18	YES	28.4
11/6/21	0.71	1084	769	13.0	7.7	18	YES	28.2
12/6/21	0.62	842	522	13.4	7.7	18	YES	36.3
13/6/21	0.69	1119	772	13.8	7.7	18	YES	27.3
14/6/21	0.72	970	699	13.8	7.7	18	YES	31.5
15/6/21	0.71	847	601	13.9	7.7	18	YES	36.1
16/6/21	0.72	858	618	14.0	7.7	18	YES	35.6
17/6/21	0.69	815	562	13.9	7.7	18	YES	37.5
18/6/21	0.85	883	751	14.2	7.7	18	YES	34.6
19/6/21	0.96	663	636	14.5	7.7	18	YES	46.1
20/6/21	1.02	654	667	14.7	7.7	19	YES	46.7
21/6/21	1.11	849	942	15.1	7.7	14	YES	36.0
22/6/21	1.25	728	910	15.1	7.8	14	YES	42.0
23/6/21	1.35	716	966	15.1	7.8	14	YES	42.7
24/6/21	1.50	792	1188	15.0	7.7	15	YES	38.6
25/6/21	1.19	770	916	15.2	7.7	14	YES	39.7
26/6/21	1.28	584	748	15.4	7.8	14	YES	52.3
27/6/21	1.50	573	860	15.8	7.7	15	YES	53.3
28/6/21	1.53	690	1055	16.1	7.7	15	YES	44.3
29/6/21	1.31	679	890	16.0	7.7	14	YES	45.0
30/6/21	1.15	774	890	16.2	7.8	14	YES	39.5
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2011

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350