



**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

**System Name:** UPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP-:

**Month/Year:** NOVEMBER 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	0.051	0.049	OFF	OFF	0800/0.051
2	OFF	OFF	0.049	OFF	OFF	0.060	2000/0.060
3	0.048	OFF	OFF	OFF	0.049	OFF	1600/0.049
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	0.066	OFF	0.050	1200/0.066
8	0.050	0.049	0.049	0.050	0.049	0.049	1200/0.050
9	OFF	OFF	OFF	0.049	0.052	OFF	1600/0.052
10	OFF	OFF	0.057	0.048	OFF	OFF	0800/0.057
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.046	0.046	0.047	2000/0.047
17	0.047	0.047	0.047	0.067	0.047	0.047	1200/0.067
18	0.047	0.047	0.047	0.053	0.047	0.048	1200/0.053
19	0.048	0.048	0.048	OFF	0.049	OFF	1600/0.049
20	OFF	OFF	OFF	0.055	0.047	OFF	1200/0.055
21	OFF	OFF	0.053	0.047	OFF	OFF	0800/0.053
22	OFF	OFF	0.047	OFF	OFF	OFF	0800/0.047
23	OFF	0.050	0.053	OFF	0.048	OFF	0800/0.053
24	OFF	OFF	0.067	0.047	OFF	OFF	0800/0.067
25	OFF	0.047	OFF	OFF	0.047	OFF	0400/1600/0.047
26	OFF	OFF	OFF	0.047	OFF	OFF	1200/0.047
27	OFF	0.050	OFF	0.051	OFF	OFF	1200/0.051
28	OFF	OFF	OFF	OFF	OFF	0.047	2000/0.047
29	0.046	OFF	OFF	OFF	0.047	OFF	1600/0.047
30	OFF	OFF	OFF	0.050	0.046	OFF	1200/0.050
31							

**Slow Sand/Membrane/DE  
Filtration/Unfiltered**

**Monthly Summary**

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup> **Yes/No**  
 All daily turbidity readings  $\leq$  5 NTU? **Yes/No**

**Monthly Summary (Answer Yes or No)**

CT's met everyday?  
(see back)  
**Yes/No**

All Cl<sub>2</sub> residual at entry point  $\geq$  0.2 mg/l?  
**Yes/No**

**Notes:**

**PRINTED NAME:** James G Piccolotti

**SIGNATURE:**

**DATE:** 12-1-2021

**PHONE #:** ( 541 ) 2654560

**CERT #:** D-08535-1  
T-08520-1

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP:-

Month/Year: NOVEMBER  
2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / 1049	1.18	1727	2037	11.5	7.6	19	YES	17.7
2 / 1020	1.17	1661	1943	13.2	7.8	19	YES	18.4
3 / 1000	1.02	1886	1924	13.5	7.6	19	YES	16.2
4 / 1041	1.10	1600	1760	13.8	7.5	19	YES	19.1
5 / 1020	1.09	1543	1682	13.5	7.6	19	YES	19.8
6 / 1055	1.15	1395	1605	13.5	7.7	19	YES	21.9
7 / 1014	1.10	1462	1608	11.5	7.7	19	YES	20.9
8 / 1025	1.41	1528	2154	10.3	7.7	19	YES	20.0
9 / 1051	1.41	1617	2280	10.3	7.6	19	YES	18.9
10 / 1033	1.42	1707	2424	10.2	7.6	19	YES	17.9
11 / 1031	1.52	1528	2323	10.6	7.6	19	YES	20.0
12 / 1040	1.50	356	534	11.1	7.5	19	YES	85.8
13 / 1023	1.42	1136	1613	11.2	7.6	19	YES	26.9
14 / 1004	1.59	1567	2492	11.5	7.5	19	YES	19.5
15 / 1045	1.54	1808	2785	11.5	7.5	19	YES	16.9
16 / 1020	1.55	1922	2979	11.2	7.6	19	YES	15.9
17 / 1055	1.67	1698	2835	10.8	7.6	20	YES	18.0
18 / 1053	1.67	1643	2744	10.6	7.6	20	YES	18.6
19 / 1042	1.61	1626	2617	10.5	7.6	20	YES	18.8
20 / 1041	1.53	1402	2145	10.2	7.6	19	YES	21.8
21 / 1033	1.41	1455	2052	9.6	7.6	29	YES	21.0
22 / 1053	1.40	1124	1573	9.3	7.6	28	YES	27.2
23 / 1037	1.49	1421	2118	9.3	7.6	29	YES	21.5
24 / 1046	1.36	1421	1933	9.1	7.6	28	YES	21.5
25 / 1035	1.32	1415	1868	9.0	7.6	28	YES	21.6
26 / 1060	1.41	1346	1898	9.1	7.6	29	YES	22.7
27 / 1044	1.29	1442	1860	9.3	7.6	28	YES	21.2
28 / 1007	1.15	1448	1666	9.6	7.5	28	YES	21.1
29 / 1010	1.22	1808	2206	10.1	7.6	19	YES	16.9
30 / 1016	1.08	1626	1756	10.2	7.5	19	YES	18.8
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)Return by 10<sup>th</sup> of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350