

### OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

**System Name:** OPRD BEVERLY BEACH STATE PARK **ID #:** 4191052 **WTP-:** **Month/Year:** APRIL 2024

DAY	12 AM [NTU]	4 AM [NTU]	.8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	0.052	0.052	0.052	1200, 1600, 2000 / 0.052
2	0.052	0.053	0.054	0.052	0.052	0.052	0500 / 0.054
3	0.053	0.053	0.052	OFF	OFF	OFF	1200, 0400 / 0.053
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	0.048	0.090	0.050	1600, 2000 / 0.050
9	0.050	0.051	0.051	OFF	OFF	OFF	0400, 0900 / 0.051
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	0.052	0.052	OFF	1200, 1600 / 0.052
16	OFF	OFF	OFF	0.053	0.052	OFF	1200 / 0.053
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	0.054	OFF	1600 / 0.054
23	OFF	OFF	OFF	OFF	0.052	0.049	1600 / 0.052
24	0.050	0.049	0.049	OFF	OFF	OFF	1200 / 0.050
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	0.049	0.049	OFF	1200, 1600 / 0.049
31							

<p><b>Slow Sand/Membrane/DE Filtration/Unfiltered</b></p> <p style="text-align: center;"><b>Monthly Summary</b></p> <p>95% of daily turbidity readings ≤ 1 NTU? <span style="float: right;">Yes/No</span>                  All daily turbidity readings ≤ 5 NTU? <span style="float: right;">Yes/No</span></p>	<p style="text-align: center;"><b>Monthly Summary (Answer Yes or No)</b></p> <table style="width: 100%;"> <tr> <td style="width: 33%;">                     CT's met everyday? (see back)                      Yes/No                 </td> <td style="width: 33%;">                     All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?                      Yes/No                 </td> <td style="width: 33%;"></td> </tr> </table>	CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No	
CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No			
<p><b>Notes:</b></p>	<p><b>PRINTED NAME:</b> JAMES G. PICCOLO TCI</p> <p><b>SIGNATURE:</b> </p> <p><b>PHONE #:</b> (541) 2654560</p> <p><b>DATE:</b> 5-1-2024</p> <p><b>CERT #:</b> D 08535-1 T-08520-1</p>			

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only

## OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 419105Z WTP-:

Month/Year: APRIL  
2024

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 / 04/24	0.27	3394	917	9.5	7.1	39	YES	9.0
2 / 04/24	0.29	3118	904	9.6	7.1	39	YES	9.8
3 / 04/24	0.22	3473	764	9.5	7.1	39	YES	8.8
4 / 04/24	0.29	3358	974	9.8	7.1	39	YES	9.1
5 / 04/24	0.56	3286	1840	9.9	7.1	39	YES	9.3
6 / 04/24	0.69	3358	2317	9.8	7.1	39	YES	9.1
7 / 04/25	0.73	3183	2324	9.6	7.1	39	YES	9.4
8 / 10/05	0.64	3473	2223	9.5	7.2	39	YES	8.8
9 / 04/25	0.64	3286	2103	9.7	7.1	39	YES	9.3
10 / 04/25	0.59	5093	3005	9.7	7.1	39	YES	6.0
11 / 05/23	0.90	5556	5001	9.8	7.1	39	YES	5.5
12 / 04/24	0.94	5877	5524	10.1	7.1	39	YES	5.2
13 / 04/24	0.85	6112	5195	10.1	7.1	39	YES	5.0
14 / 04/24	0.78	5457	4257	10.1	7.1	39	YES	5.6
15 / 10/02	0.73	6237	4553	10.2	7.1	39	YES	4.9
16 / 04/25	0.91	6112	5562	10.2	7.1	39	YES	5.0
17 / 04/18	0.84	5766	4843	10.1	7.1	39	YES	5.3
18 / 04/24	1.00	6112	6112	10.8	7.1	39	YES	5.0
19 / 04/24	0.93	5877	5466	11.4	7.1	39	YES	5.2
20 / 04/24	0.88	6112	5379	10.3	7.1	39	YES	5.0
21 / 10/02	0.83	5877	4878	10.2	7.1	39	YES	5.2
22 / 04/14	0.82	5992	4914	10.1	7.1	39	YES	5.1
23 / 04/24	0.84	6367	5348	10.3	7.1	39	YES	4.8
24 / 04/25	0.80	5556	4445	10.5	7.1	39	YES	5.5
25 / 04/23	0.82	5492	4814	11.9	7.1	39	YES	5.1
26 / 04/17	0.82	6112	5012	12.0	7.1	39	YES	5.0
27 / 04/20	0.92	6112	5623	11.8	7.1	39	YES	5.0
28 / 04/23	1.02	2590	2642	10.6	7.1	39	YES	11.8
29 / 10/04	1.06	6237	6611	10.6	7.1	39	YES	4.9
30 / 04/26	1.06	2231	2364	10.7	7.1	39	YES	13.7
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.pdf)Return by 10<sup>th</sup> of following month by email, fax, or mail to:

Fax: 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350