


OHA - Drinking Water Services – Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4101052 WTP: Month/Year: MAY 2024

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	0.048	0.049	0.049	1600, 2000/0.049
14	0.050	0.051	0.051	0.051	0.051	0.051	ALLEX 12AM/0.051
15	0.052	0.052	0.053	OFF	OFF	OFF	0.050/0.053
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	0.057	0.057	0.056	1200, 1600/0.057
28	0.059	0.056	0.056	0.056	0.056	0.055	12AM/0.059
29	0.056	0.057	0.052	0.057	OFF	OFF	0.050/0.052
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
	95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Notes:	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
	PRINTED NAME: JAMES G. PICCOLOTTI	DATE: 6-1-2024
	SIGNATURE: 	CERT #: D-08535-1 T-08520-1
	PHONE #: (341) 265-4560	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP-:

Month/Year: MAY 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/0919	0.92	6112	5623	10.5	7.1	39	YES	5.0
2/0922	1.02	5992	6112	10.8	7.1	39	YES	5.1
3/0916	1.01	5659	5716	10.8	7.1	39	YES	5.4
4/0924	1.01	5556	5612	10.8	7.1	39	YES	5.5
5/0916	1.06	4929	5225	10.8	7.1	39	YES	6.2
6/0920	1.00	1852	1852	10.7	7.1	39	YES	16.5
7/1017	1.09	3918	4271	10.7	7.1	39	YES	7.8
8/0925	1.04	5010	5210	10.8	7.1	39	YES	6.1
9/0925	1.06	5093	5908	10.9	7.1	39	YES	6.0
10/0905	1.18	5269	6217	12.7	7.1	39	YES	5.8
11/0914	1.09	5180	5646	11.3	7.1	39	YES	5.9
12/0916	0.97	4021	3900	11.8	7.1	39	YES	7.6
13/1007	1.09	5180	5646	11.9	7.0	39	YES	5.9
14/0913	1.01	5093	5144	11.9	7.1	39	YES	6.0
15/0924	1.20	3868	4642	12.1	7.1	39	YES	7.9
16/0929	1.30	6237	8108	12.1	7.1	39	YES	4.9
17/10	1.31	5010	6563	11.8	7.1	39	YES	6.1
18/0919	0.96	4561	4379	12.3	7.1	39	YES	6.7
19/0913	1.20	4429	5315	12.2	7.1	39	YES	6.9
20/0916	1.26	4630	5834	12.1	7.1	39	YES	6.6
21/0920	1.32	4630	6112	12.3	7.1	39	YES	6.6
22/0925	1.17	5269	6165	12.2	7.1	39	YES	5.8
23/0925	1.52	5269	8009	12.3	7.1	39	YES	5.8
24/0920	1.50	5877	8815	12.3	7.1	39	YES	5.2
25/0924	1.12	5659	6338	12.2	7.1	39	YES	5.4
26/0904	1.42	5766	8188	12.1	7.1	39	YES	5.3
27/0920	1.44	5556	8001	12.2	7.1	39	YES	5.5
28/0922	1.33	38200	56806	12.3	7.1	39	YES	0.8
29/1015	1.63	19100	31133	12.7	7.1	39	YES	1.6
30/1026	1.45	4130	5958	13.1	7.1	39	YES	7.4
31/	1.68	1218	2045	13.4	7.1	39	YES	25.1

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350