


**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP-: \_\_\_\_\_ Month/Year: JUNE 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	0.055	0.055	0.056	2000/0.056
2	0.056	0.056	0.056	OFF	0.056	0.056	ALL EXC 1200/0.056
3	0.057	0.057	0.057	0.057	0.057	0.057	ALL/0.057
4	0.057	0.057	0.057	OFF	OFF	OFF	12AM, 0400, 0800/0.057
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	0.056	0.055	1600/0.056
9	0.055	0.055	0.054	0.131	0.056	OFF	12PM/0.131
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	0.054	0.053	OFF	1200/0.054
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.048	OFF	OFF	0.048
17	OFF	OFF	OFF	0.062	OFF	OFF	1200/0.062
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	0.056	0.054	OFF	1200/0.056
24	OFF	OFF	OFF	OFF	0.058	OFF	1600/0.058
25	OFF	OFF	OFF	OFF	0.060	OFF	1600/0.060
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	0.058	0.056	OFF	1200/0.058
30	OFF	OFF	OFF	0.057	0.057	OFF	1200, 1600/0.057
31							

Slow Sand/Membrane/DE Filtration/Unfiltered <b>Monthly Summary</b>	Monthly Summary (Answer Yes or No)	
	95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <u>JAMES G PICCOLOTTI</u>	
	SIGNATURE: 	DATE: <u>7-1-2024</u>
	PHONE #: <u>( 541 ) 265 4560</u>	CERT #: <u>D-08535-1</u> <u>T-05560-1</u>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services – Surface Water Quality Data Form**

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 411A1652 WTP-: \_\_\_\_\_ Month/Year: JUNE 2024

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[°C]		Use tables	Yes / No	[GPM]
1 / 1010	1.62	2996	4854	12.7	7.1	39	YES	10.2
2 / 0955	1.08	4561	4926	11.8	7.1	39	YES	6.7
3 / 0930	1.30	4304	5595	11.8	7.1	39	YES	7.1
4 / 0902	1.07	2804	3000	11.8	7.1	39	YES	10.9
5 / 0119	1.11	4929	5471	11.5	7.1	39	YES	6.2
6 / 1000	0.72	5610	3607	11.9	7.1	39	YES	6.1
7 / 0905	0.90	4561	4105	12.1	7.1	39	YES	6.7
8 / 0930	0.46	5010	2305	12.2	7.1	39	YES	6.1
9 / 0934	0.68	4630	3149	12.3	7.1	39	YES	6.6
10 / 1020	1.41	5093	7182	12.5	7.1	39	YES	6.0
11 / 0930	1.27	12224	15524	12.3	7.1	39	YES	2.5
12 / 0913	1.26	20373	25670	12.5	7.1	39	YES	10.5
13 / 1000	1.25	10914	13643	12.8	7.1	39	YES	2.8
14 / 0900	1.24	101867	126315	12.2	7.1	39	YES	0.3
15 / 0928	1.03	27782	28615	12.2	7.1	39	YES	1.1
16 / 0900	0.92	101867	93717	12.2	7.1	39	YES	0.3
17 / 0906	0.92	152800	140576	10.1	7.1	39	YES	0.2
18 / 0940	1.07	61120	65348	11.5	7.0	39	YES	0.5
19 / 0911	0.87	61120	53174	11.5	7.1	39	YES	0.5
20 / 0950	0.77	16978	13073	12.1	7.1	39	YES	1.8
21 / 0954	0.82	61120	50118	12.2	7.0	39	YES	0.5
22 / 0955	0.79	152800	120712	12.6	7.1	39	YES	0.2
23 / 0914	0.80	305600	244480	12.8	7.1	39	YES	0.1
24 / 0957	0.77	38200	29414	12.8	7.1	39	YES	0.8
25 / 0916	0.71	12224	8679	12.9	7.1	39	YES	2.5
26 / 0933	0.76	46657	33174	13.1	7.1	39	YES	0.7
27 / 0930	0.83	101867	87549	13.2	7.1	39	YES	0.3
28 / 0905	0.74	101867	75381	13.2	7.1	39	YES	0.3
29 / 0926	0.89	30560	27198	13.3	7.1	39	YES	1.0
30 / 0955	0.69	20373	14058	13.3	7.1	39	YES	1.5
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016  
 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)

Return by 10<sup>th</sup> of following month by email, fax, or mail to:  
 WSP: [prlog@ohw.org](mailto:prlog@ohw.org); 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350