

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP.: _____ Month/Year: DECEMBER 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.040	0.041	0.040	0.041	0.041	0.040	12AM, 12PM, 1600 / 0.041
2	0.039	0.040	0.040	0.040	OFF	0.041	2000 / 0.041
3	0.039	0.040	0.040	0.040	OFF	OFF	0400, 0800, 1200 / 0.040
4	0.049	OFF	OFF	OFF	OFF	OFF	12AM / 0.049
5	OFF	OFF	OFF	0.049	OFF	OFF	1200 / 0.049
6	OFF	OFF	OFF	0.049	OFF	OFF	1200 / 0.049
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	0.052	0.050	OFF	1200 / 0.052
10	OFF	OFF	OFF	0.050	0.050	OFF	1200, 1600 / 0.050
11	OFF	OFF	OFF	0.050	0.049	0.049	1200 / 0.050
12	0.048	0.049	0.048	OFF	OFF	OFF	0400 / 0.049
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	0.051	OFF	OFF	1200 / 0.051
15	OFF	OFF	OFF	0.053	OFF	OFF	1200 / 0.053
16	0.052	OFF	OFF	OFF	OFF	OFF	12AM / 0.052
17	OFF	OFF	0.052	OFF	OFF	OFF	0800 / 0.052
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes / ☐ No	Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
	Notes:	
PRINTED NAME: <u>JAMES G PICCOLOTTI</u>		
SIGNATURE: <u>[Signature]</u>		DATE: <u>1-1-2025</u>
PHONE #: <u>(541) 2654560</u>		CERT #: <u>D08535-1</u> <u>T08520-1</u>

¹ Including continuous turbidity data if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP-:

Month/Year: DECEMBER 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/0120	1.48	1984	2937	6.7	7.1	39	YES	15.4
2/0144	1.57	2264	3554	6.9	7.1	39	YES	13.5
3/1020	1.51	2729	4120	6.7	7.1	39	YES	11.2
4/0033	1.49	2704	4050	6.8	7.1	39	YES	11.3
5/0155	1.20	2704	3245	7.0	7.1	39	YES	11.3
6/0155	1.39	2505	3482	7.2	7.1	39	YES	12.2
7/0127	1.50	2351	3526	7.2	7.1	39	YES	13.0
8/0130	1.41	2612	3683	7.3	7.1	39	YES	11.7
9/0143	1.43	2388	3414	7.3	7.1	39	YES	12.8
10/0153	1.41	2657	3747	7.1	7.1	39	YES	11.5
11/0143	1.37	2824	3841	7.1	7.1	39	YES	10.9
12/015	1.27	2778	3528	7.1	7.3	39	YES	11.0
13/0153	1.23	2351	2891	7.5	7.1	39	YES	13.0
14/0144	1.22	2485	3031	7.4	7.1	39	YES	12.3
15/0118	1.14	2037	2323	7.3	7.1	39	YES	15.0
16/1337	1.15	3087	3550	7.7	7.1	39	YES	9.9
17/1056	0.95	3087	2933	7.9	7.1	39	YES	9.9
18/0119	0.93	2856	2656	8.2	7.1	39	YES	10.7
19/0125	0.89	2729	2428	8.4	7.1	39	YES	11.2
20/0112	0.47	2547	2470	8.6	7.1	39	YES	12.0
21/0104	0.86	2547	2190	9.0	7.1	39	YES	12.0
22/0136	0.75	2485	1863	9.1	7.1	39	YES	12.3
23/1000	0.66	2445	1614	9.1	7.1	39	YES	12.5
24/0101	0.57	2465	1405	9.3	7.1	39	YES	12.4
25/0117	0.61	2425	1479	9.3	7.1	39	YES	12.6
26/0126	0.64	2526	1616	9.3	6.8	39	YES	12.1
27/0154	0.67	2693	1402	9.3	7.1	39	YES	14.6
28/0128	0.59	2333	1376	9.3	7.1	39	YES	13.1
29/0145	0.54	2281	1232	9.3	7.1	39	YES	13.4
30/0157	0.48	1997	959	9.2	7.1	39	YES	15.3
31/0155	0.57	2264	1290	8.8	7.1	39	YES	13.5

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

Drinking Water Services, 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350