

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP-:

Month/Year: JANUARY/ 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.049	2000 / 0.049
2	0.049	0.050	0.050	0.051	OFF	OFF	1200 / 0.051
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	0.051	0.050	0.051	1200, 2000 / 0.051
10	0.050	0.051	0.051	0.054	0.053	OFF	1200 / 0.054
11	OFF	OFF	OFF	0.052	0.053	0.053	1000, 2000 / 0.053
12	0.052	0.054	0.054	0.053	0.053	0.054	2000, 2000, 2000 / 0.054
13	0.053	0.055	0.054	0.054	OFF	OFF	2000 / 0.055
14	0.059	OFF	OFF	OFF	OFF	0.059	1200, 2000 / 0.059
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	0.056	0.055	OFF	1200 / 0.056
18	OFF	OFF	OFF	0.054	0.054	OFF	1200, 1600 / 0.054
19	OFF	OFF	OFF	0.055	0.055	OFF	1200, 1600 / 0.055
20	OFF	OFF	OFF	0.071	0.058	0.055	1200 / 0.071
21	0.054	0.054	OFF	0.078	OFF	OFF	1200 / 0.078
22	OFF	OFF	OFF	0.055	OFF	OFF	1200 / 0.055
23	OFF	OFF	OFF	0.053	OFF	OFF	1200 / 0.053
24	OFF	OFF	OFF	0.058	OFF	OFF	1200 / 0.058
25	OFF	OFF	OFF	0.056	0.056	OFF	1200, 1600 / 0.056
26	OFF	OFF	OFF	0.054	0.054	OFF	1200, 1600 / 0.054
27	OFF	OFF	OFF	0.052	OFF	OFF	1200 / 0.052
28	OFF	OFF	OFF	0.071	OFF	OFF	1200 / 0.071
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	0.055	OFF	OFF	200 / 0.055
31	OFF	OFF	OFF	0.053	OFF	OFF	1200 / 0.053

Slow Sand/Membrane/DE
Filtration/Unfiltered

Monthly Summary


95% of daily turbidity readings ≤ 1 NTU?
All daily turbidity readings ≤ 5 NTU?Yes/No
Yes/No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)
Yes/NoAll Cl₂ residual at entry point ≥ 0.2 mg/l?
Yes/No

Notes:

PRINTED NAME: JAMES G PICCOLOTTI

SIGNATURE: 

DATE: 2-2-2025

PHONE #: (541) 2654560

CERT #: D-08535-1
T-08520-1

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum ² Filtered systems only

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK

ID #: 4191052 WTP-:

Month/Year: JANUARY
2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/06/23	0.51	2406	1227	8.5	7.1	39	YES	12.7
2/06/23	0.63	2185	1377	9.0	7.1	39	YES	12.3
3/06/23	0.67	2231	1495	9.3	7.1	39	YES	13.7
4/06/23	0.78	2231	1740	8.9	7.1	39	YES	13.7
5/06/23	0.76	2883	2191	9.2	7.1	39	YES	10.6
6/06/23	0.83	2938	2439	9.3	7.1	39	YES	10.4
7/06/23	0.84	2651	2252	9.2	7.1	39	YES	11.4
8/06/23	0.93	2830	2632	9.1	7.1	39	YES	10.8
9/06/23	0.87	2251	1984	8.9	7.1	39	YES	13.4
10/06/23	0.93	3153	2960	9.1	7.1	39	YES	9.6
11/06/23	1.13	2281	2577	8.7	7.1	39	YES	13.4
12/06/23	1.24	1997	2477	8.8	7.0	39	YES	15.3
13/06/23	1.24	2079	2578	8.3	7.0	39	YES	14.7
14/06/23	1.34	2505	3357	8.1	7.0	39	YES	12.2
15/06/23	1.41	2634	3715	8.1	7.1	39	YES	11.6
16/06/23	1.55	2568	3981	8.0	7.1	39	YES	11.9
17/06/23	1.40	1946	2725	7.7	7.1	39	YES	15.7
18/06/23	1.32	1252	1653	7.2	7.1	39	YES	24.4
19/06/23	1.16	1370	1590	6.6	7.0	39	YES	22.3
20/06/23	1.41	2167	3056	6.2	7.1	39	YES	14.1
21/06/23	1.34	2315	3102	6.1	7.0	39	YES	13.2
22/06/23	1.30	2369	3080	6.1	7.1	39	YES	12.7
23/06/23	1.30	2406	3128	6.2	7.1	39	YES	12.7
24/06/23	1.29	2037	2628	6.3	7.1	39	YES	15.0
25/06/23	1.20	1798	2157	5.7	7.1	39	YES	17.0
26/06/23	1.05	1972	2070	5.5	7.1	39	YES	15.5
27/06/23	1.20	2167	2601	5.5	7.1	39	YES	14.1
28/06/23	1.05	2012	2113	5.6	7.1	39	YES	11.7
29/06/23	1.03	2369	2440	5.6	7.1	39	YES	12.9
30/06/23	1.04	2445	2543	5.4	7.1	39	YES	12.5
31/06/23	1.30	2214	2879	5.4	7.1	39	YES	13.8

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

Capitol Building, Room 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350