


OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: OPRD BEVERLY BEACH STATE PARK ID #4191052 WTP:

Month/Year: FEBRUARY 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	0.047	0.048	OFF	1600/0.048
7	OFF	OFF	OFF	0.049	0.048	OFF	1200/0.049
8	OFF	OFF	OFF	0.049	0.049	OFF	1200, 1600/0.049
9	OFF	OFF	OFF	0.049	0.050	OFF	1600/0.050
10	OFF	OFF	OFF	0.050	0.051	OFF	1600/0.051
11	OFF	OFF	OFF	0.053	0.051	OFF	1200/0.053
12	OFF	OFF	OFF	OFF	0.050	OFF	1600/0.050
13	OFF	OFF	OFF	0.052	0.052	OFF	1200, 1600/0.052
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	0.054	0.053	OFF	1200/0.054
16	OFF	OFF	OFF	0.053	0.053	OFF	1200, 1600/0.053
17	OFF	OFF	OFF	OFF	0.056	OFF	1600/0.056
18	OFF	OFF	OFF	0.053	0.053	OFF	1200, 1600/0.053
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	0.079	0.069	1600/0.079
28	0.062	0.059	0.057	0.057	OFF	OFF	12AM/0.062
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes / ☐ No		CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No
Notes:		PRINTED NAME: JAMES PICCOLOTTI SIGNATURE:  PHONE #: (541) 2654560	
		DATE: 3-1-2025 CERT #: D-08535-1 T-08560-1	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum ² Filtered systems only

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP-:

Month/Year: FEBRUARY 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / 0846	1.18	2108	2487	5.8	7.1	39	YES	14.5
2 / 0944	1.18	2137	2522	5.7	7.1	39	YES	14.3
3 / 0951	1.27	2883	3661	5.8	7.1	39	YES	10.6
4 / 0920	1.06	2634	2793	5.6	7.1	39	YES	11.6
5 / 0954	1.02	2467	3026	5.3	7.1	39	YES	10.3
6 / 1014	1.04	2704	2948	5.4	7.1	39	YES	11.3
7 / 0957	1.21	2657	3215	5.7	7.1	39	YES	11.5
8 / 0914	1.00	2152	2152	5.2	7.1	39	YES	14.2
9 / 0932	0.98	2264	2218	4.9	7.1	39	YES	13.5
10 / 1000	0.96	2526	2425	4.6	7.1	39	YES	12.1
11 / 1023	0.94	2568	2414	4.8	7.1	39	YES	11.9
12 / 0934	0.93	2547	2368	4.6	7.1	39	YES	12.0
13 / 0910	1.10	2657	2923	4.5	7.1	39	YES	11.5
14 / 0924	0.96	2264	2173	4.8	7.1	39	YES	13.5
15 / 0935	0.96	1268	1217	4.4	7.1	39	YES	24.1
16 / 0943	0.89	1652	1470	4.6	7.1	39	YES	18.5
17 / 0922	0.98	2065	2024	5.0	7.1	39	YES	14.8
18 / 1008	0.96	2388	2292	5.3	7.1	39	YES	12.8
19 / 0938	1.04	2231	2320	5.6	7.1	39	YES	13.7
20 / 1045	0.96	2264	2173	6.0	7.1	39	YES	13.5
21 / 0948	1.16	1819	2110	6.2	7.1	39	YES	16.8
22 / 0910	0.99	1670	1653	6.5	7.1	39	YES	18.3
23 / 0917	1.04	1852	1926	7.1	7.1	39	YES	16.5
24 / 1143	0.96	2425	2328	7.5	7.1	39	YES	12.6
25 / 1038	0.93	2445	2274	7.8	7.1	39	YES	12.5
26 / 0923	1.00	2079	2079	7.8	7.1	39	YES	14.7
27 / 1025	0.97	2369	2298	8.2	7.1	39	YES	12.9
28 / 0944	0.87	1643	1429	7.8	7.0	39	YES	18.6
29 /								
30 /								
31 /								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

dwp.dms@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350