

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP: _____ Month/Year: APRIL 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.058	2000/0.058
2	OFF	OFF	OFF	OFF	0.059	OFF	1600/0.059
3	0.058	OFF	OFF	OFF	OFF	0.058	12AM, 2000/0.058
4	OFF	OFF	0.054	OFF	OFF	OFF	0800/0.059
5	0.060	OFF	OFF	OFF	OFF	0.058	2000/0.058
6	OFF	OFF	0.058	0.059	OFF	OFF	1200/0.059
7	OFF	0.058	OFF	OFF	OFF	OFF	0400/0.058
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	0.055	0.054	0.054	1200/0.055
13	0.056	0.056	0.056	0.073	0.056	0.056	1200/0.073
14	0.056	0.056	0.056	OFF	OFF	OFF	12AM, 0400, 0800/0.056
15	OFF	OFF	OFF	OFF	OFF	0.055	2000/0.055
16	0.057	OFF	OFF	OFF	OFF	0.059	2000/0.059
17	OFF	0.057	OFF	OFF	OFF	OFF	0400/0.057
18	0.057	0.057	OFF	OFF	OFF	OFF	12AM, 0400/0.057
19	0.071	OFF	OFF	0.062	OFF	OFF	12AM/0.071
20	OFF	OFF	OFF	0.057	0.055	0.055	1200/0.057
21	OFF	OFF	OFF	OFF	OFF	0.226	2000/0.226
22	0.058	OFF	OFF	OFF	OFF	OFF	12AM/0.058
23	0.059	OFF	0.058	OFF	OFF	OFF	12AM/0.059
24	0.054	OFF	OFF	OFF	OFF	OFF	12AM/0.054
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	0.056	0.060	0.056	1600/0.060
27	0.058	0.057	OFF	OFF	OFF	OFF	12AM/0.058
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	0.057	OFF	OFF	OFF	OFF	OFF	12AM/0.057
30	0.058	OFF	0.059	OFF	OFF	OFF	0800/0.059
31							

Slow Sand/Membrane/DE
Filtration/Unfiltered

Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? (Yes) No
 All daily turbidity readings ≤ 5 NTU? (Yes) No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)
(Yes) No

All Cl₂ residual at entry point ≥ 0.2 mg/l?
(Yes) No

Notes:

PRINTED NAME: JAMES G PICCOLOTTI

SIGNATURE: [Signature]

PHONE #: (541) 2654560

DATE: 5/3/25

CERT #: D-08535-1

T-08520-1

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings maximum. Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: OPRD BEVERLY BEACH STATE PARK ID #: 4191052 WTP-:

Month/Year: APRIL 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/10/2	1.28	1528	1956	9.2	7.1	39	YES	20.0
2/10/2	1.14	2214	2525	9.2	7.1	39	YES	15.8
3/10/2	1.27	1777	2256	9.1	7.1	39	YES	17.2
4/10/2	1.08	1707	1844	9.1	7.1	39	YES	17.9
5/10/2	1.24	1247	1547	9.1	7.1	39	YES	24.5
6/10/2	1.19	1886	2245	9.3	7.1	39	YES	16.2
7/10/2	1.03	1875	2119	9.6	7.1	39	YES	16.3
8/10/2	1.15	1149	1321	9.6	7.1	39	YES	26.6
9/10/2	1.10	1505	1656	9.7	7.1	39	YES	20.3
10/10/2	1.00	1608	1608	9.8	7.1	39	YES	19.0
11/10/2	1.15	1787	2055	9.9	7.1	39	YES	17.1
12/10/2	1.14	1491	1699	9.6	7.1	39	YES	20.5
13/10/2	1.17	1679	1965	9.4	7.1	39	YES	18.2
14/10/2	1.13	1626	1837	9.5	7.1	39	YES	18.8
15/10/2	1.06	1972	2090	9.9	7.1	39	YES	15.6
16/10/2	1.015	1997	2026	9.9	7.1	39	YES	15.3
17/10/2	1.05	1608	2541	9.8	7.1	39	YES	19.0
18/10/2	1.48	1626	2406	10.1	7.0	39	YES	18.8
19/10/2	1.80	1340	2413	10.2	7.1	39	YES	22.8
20/10/2	2.15	1346	2894	10.3	7.1	39	YES	22.7
21/10/2	1.83	1688	3090	10.2	7.1	39	YES	18.1
22/10/2	1.80	1997	3595	10.2	7.1	39	YES	15.3
23/10/2	1.88	1766	3321	10.2	7.1	39	YES	17.3
24/10/2	2.11	1513	3192	10.2	7.1	39	YES	20.2
25/10/2	2.12	1346	2854	10.3	7.1	39	YES	22.7
26/10/2	1.85	1358	2513	10.6	7.1	39	YES	22.5
27/10/2	1.93	1408	2718	10.7	7.1	39	YES	21.7
28/10/2	2.17	1863	4044	10.9	7.1	39	YES	16.4
29/10/2	1.99	1777	3536	10.9	7.1	39	YES	17.2
30/10/2	1.52	1756	2670	10.6	7.1	39	YES	17.4
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours

Revised September 2016

Download form at public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdfReturn by 10th of following month by email, fax, or mail to:

or FAX to: 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350