

OHA - DWS

Membrane Filter Monthly Operating Report

County: LINCOLNSystem Name: BEVERLY BEACH STATE PARKMonth/Year: OCTOBER 2025PWS ID#: 41 - 91052Minimum test pressure applied: 15.62 psiPlant ID: WTP - AMinimum test pressure req'd: 14.0 psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔


PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	PDR _{Max} [psi/min]	LRC [log removal]	DIT Daily
				0.390	4.00	
1	0.074	0.081		0.010	5.474	YES
2	0.080	0.080		0.052	4.805	YES
3	0.081	0.081		0.048	4.802	YES
4	0.084	0.086		0.079	4.622	YES
5	0.084	0.099		0.026	4.617	YES
6	0.084	0.086		0.037	5.191	YES
7	0.091	0.168		0.089	4.837	YES
8	0.083	0.104		0.045	4.827	YES
9	0.090	0.090		0.026	5.116	YES
10	0.085	0.085		0.065	4.945	YES
11	0.087	0.090		0.032	4.927	YES
12	0.087	0.097		0.038	5.010	YES
13	0.089	0.239		0.027	5.161	YES
14	0.089	0.089		0.030	5.235	YES
15	0.089	0.089		0.052	5.087	YES
16	0.088	0.089		0.020	5.044	YES
17	0.089	0.089		0.027	5.498	YES
18	0.089	0.089		0.018	5.363	YES
19	0.079	0.079		0.032	5.265	YES
20	0.078	0.084		0.039	5.128	YES
21	0.082	0.082		0.030	5.129	YES
22	0.083	0.083		0.187	4.495	YES
23	0.087	0.083		0.030	4.506	YES
24	OFF	OFF		OFF	OFF	OFF
25	OFF	OFF		OFF	OFF	OFF
26	OFF	OFF		OFF	OFF	OFF
27	OFF	OFF		OFF	OFF	OFF
28	0.091	0.095		0.031	5.266	YES
29	0.093	0.101		0.024	5.244	YES
30	0.104	0.147		0.031	5.241	YES
31	0.091	0.091		0.039	5.227	YES

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? <u>Y/N</u>	All turbidity readings ≤ 5 NTU? <u>Y/N</u>	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? <u>Y/N</u> (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily? <u>YES</u>
CT's met daily? (p. 2) <u>YES</u>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <u>YES</u>	PDR ≤ PDR _{Max} ? <u>YES</u>	LRV _{ambient} ≥ LRC? <u>YES</u>	

PRINTED NAME: JAMES PICCOLOTTISIGNATURE: 

Notes:

DATE: 11-1-2025WT CERT #: 08560-1PHONE #: 541-265-4560

p. 1 of 2

OHA-DWS

Disinfection Monthly Operating Report

System Name: BEVERLY BEACH STATE PARKPWS ID#: 41 - 91052Plant ID : WTP - A

4.00

Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.89	2612	2325	14.3	7.0	39	YES	11.7	
2	0.85	2264	1924	14.4	7.0	39	YES	13.5	
3	0.92	1469	1352	14.4	7.0	39	YES	20.8	
4	0.64	1766	1131	14.4	7.0	39	YES	17.3	
5	0.86	1670	1436	14.2	7.0	39	YES	18.3	
6	0.84	1567	1316	14.0	7.0	39	YES	19.5	
7	0.86	2037	1752	14.2	7.0	39	YES	15.0	
8	0.82	1852	1519	14.1	7.0	39	YES	16.5	
9	0.77	2037	1569	14.1	7.0	39	YES	15.0	
10	0.82	1717	1408	13.9	7.0	39	YES	17.8	
11	0.83	1575	1307	13.9	7.0	39	YES	19.4	
12	0.90	2037	1834	13.7	7.0	39	YES	15.0	
13	0.90	2264	2037	13.1	7.0	39	YES	13.5	
14	1.08	2167	2341	12.6	7.0	39	YES	14.1	
15	1.11	2093	2323	12.2	7.1	39	YES	14.6	
16	1.07	2485	2907	12.2	7.0	39	YES	12.3	
17	1.12	1798	2013	12.3	7.0	39	YES	17.0	
18	1.11	1679	1864	11.9	7.1	39	YES	18.2	
19	1.13	2315	2616	12.2	7.0	39	YES	13.2	
20	1.17	2406	2815	12.1	7.0	39	YES	12.7	
21	1.26	2505	3156	11.8	7.0	39	YES	12.2	
22	1.19	2231	2654	11.9	7.0	39	YES	13.7	
23	1.23	3642	4529	12.1	6.8	39	YES	8.3	
24	1.20	2505	3006	12.3	7.0	39	YES	12.2	
25	1.12	2214	2480	12.1	7.0	39	YES	13.8	
26	1.16	2388	2770	11.8	7.0	39	YES	12.8	
27	1.10	2753	3028	11.6	7.0	39	YES	11.1	
28	1.19	3553	4229	11.4	6.9	39	YES	8.6	
29	1.11	2830	3141	11.5	7.0	39	YES	10.8	
30	1.24	2856	3542	11.3	7.0	39	YES	10.7	
31	1.19	2096	3565	11.3	7.1	39	YES	10.2	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month bymail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350email: dwp.dmce@odhsoha.oregon.gov
fax: 971-673-0458

p. 2 of 2