

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: BAVERLY BEACH STATE PARK
 PWS ID#: 41 - 91052
 Plant ID: WTP - A
 (e.g., "A")

County: LINCOLN
 Month/Year: JANUARY 2026
 Minimum test pressure applied: 15.79 psi
 Minimum test pressure req'd: 14.0 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇨

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR _{Max} [^{psi} /min]	LRC [log removal]	DIT Daily
0.390	4.00	

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [^{psi} /min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.100	0.100		0.039	5.291	YES
2	0.388	0.388		0.024	5.306	YES
3	0.098	0.103		0.010	5.477	YES
4	0.095	0.095		0.026	5.385	YES
5	0.113	0.113		0.025	5.386	YES
6	OFF	OFF		OFF	OFF	OFF
7	OFF	OFF		OFF	OFF	OFF
8	OFF	OFF		OFF	OFF	OFF
9	OFF	OFF		OFF	OFF	OFF
10	OFF	OFF		OFF	OFF	OFF
11	OFF	OFF		OFF	OFF	OFF
12	OFF	OFF		OFF	OFF	OFF
13	0.088	0.264		0.022	5.458	YES
14	0.094	0.097		0.037	5.306	YES
15	OFF	OFF		OFF	OFF	OFF
16	0.094	0.558		0.028	5.326	YES
17	0.094	0.097		0.028	5.400	YES
18	0.092	0.095		0.030	5.394	YES
19	0.106	0.106		0.036	5.290	YES
20	0.193	0.193		0.032	5.316	YES
21	0.106	0.106		0.065	5.047	YES
22	OFF	OFF		OFF	OFF	OFF
23	0.100	0.100		0.019	5.051	YES
24	0.211	0.211		0.029	5.396	YES
25	0.187	0.187		0.040	5.243	YES
26	0.096	0.096		0.015	5.273	YES
27	0.100	0.111		0.011	5.707	YES
28	0.129	0.129		0.031	5.407	YES
29	0.095	0.095		0.018	5.404	YES
30	OFF	OFF		OFF	OFF	OFF
31	0.089	0.089		0.022	5.535	YES

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? (PDR ≤ PDR _{Max} , LRV ≥ LRC) [Y/N]	DIT Daily?
YES	YES	YES	YES	YES
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
YES	YES	YES	YES	

PRINTED NAME: NATHAN GERHARD DATE: 2-3-26
 SIGNATURE: [Signature] WT CERT #: 810245
 Notes: PHONE #: 541-265 4560

◆ Used for optimization purposes only.

OHA-DWS

Disinfection Monthly Operating Report

System Name: BEVERLY BEACH STATE PARK

PWS ID#: 41 - 91052

Plant ID : WTP - A

4.00

↔ Log Inactivation Required via Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [°C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.77	2231	3948	8.3	6.9	39	YES	13.7	
2	1.44	1997	2876	8.5	7.0	39	YES	15.3	
3	1.67	2333	3896	8.7	7.0	39	YES	13.1	
4	1.67	3322	5547	8.8	7.0	39	YES	9.2	
5	1.45	4075	5908	8.7	7.0	39	YES	7.5	
6	1.50	5556	8335	8.8	7.0	39	YES	5.5	PLANT OFF
7	1.68	4630	7779	8.9	7.0	39	YES	6.6	PLANT OFF
8	1.71	4851	8295	8.8	7.0	39	YES	6.3	PLANT OFF
9	1.45	3773	5471	8.8	6.9	39	YES	8.1	PLANT OFF
10	1.65	3434	5666	8.5	6.9	39	YES	8.9	PLANT OFF
11	1.61	3396	5468	8.5	7.0	39	YES	9.0	PLANT OFF
12	1.57	4186	6572	8.5	7.0	39	YES	7.3	PLANT OFF
13	1.48	3918	5799	8.6	7.0	39	YES	7.8	
14	1.38	4244	5857	8.5	6.9	39	YES	7.2	
15	1.53	3682	5633	8.2	6.9	39	YES	8.3	
16	1.63	2729	4448	8.3	6.9	39	YES	11.2	
17	1.53	1997	3056	8.2	7.0	39	YES	15.3	
18	1.44	1886	2716	7.9	6.9	39	YES	16.2	
19	1.60	2778	4445	7.9	6.9	39	YES	11.0	
20	1.34	3682	4934	8.2	6.9	39	YES	8.3	
21	1.42	3918	5563	8.0	6.9	39	YES	7.8	
22	1.43	4075	5827	7.8	6.9	39	YES	7.5	
23	1.58	3473	5487	8.0	7.0	39	YES	8.8	
24	1.34	2996	4015	7.2	6.9	39	YES	10.2	
25	1.35	3434	4636	7.1	6.9	39	YES	8.9	
26	1.37	2938	4026	7.3	6.9	39	YES	10.4	
27	1.33	4304	5725	7.4	6.9	39	YES	7.1	
28	1.42	2667	4213	7.6	6.8	39	YES	10.3	
29	1.35	3820	5157	8.0	6.9	39	YES	8.0	
30	1.33	3251	4324	8.2	7.1	39	YES	9.4	
31	1.41	2704	3811	8.4	7.0	39	YES	11.3	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
 PO Box 14350
 Portland, OR 97293-0350
 email: dwp.dmce@odhsoha.oregon.gov
 fax: 971-673-0458