

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: BEVERLY DENH STATE PARK
 PWS ID#: 41 - 01052
 Plant ID: WTP - A
(e.g., "A")

County: LINCOLN
 Month/Year: FEBRUARY 2026
 Minimum test pressure applied: 15.70 psi
 Minimum test pressure req'd: 14.0 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇨

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [^{PSI}/min]

0.390

LRC [log removal]

4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [^{PSI} /min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	OFF	OFF		OFF	OFF	OFF
2	0.024	0.024		0.067	4.948	YES
3	0.093	0.093		0.025	4.994	YES
4	0.092	0.092		0.015	5.489	YES
5	0.093	0.093		0.033	5.326	YES
6	0.092	0.092		0.043	5.158	YES
7	0.092	0.094		0.016	5.189	YES
8	OFF	OFF		OFF	OFF	OFF
9	OFF	OFF		OFF	OFF	OFF
10	OFF	OFF		OFF	OFF	OFF
11	OFF	OFF		OFF	OFF	OFF
12	0.087	0.087		0.045	5.155	YES
13	0.093	0.093		OFF	5.212	OFF
14	0.093	0.093		0.050	5.138	YES
15	0.096	0.106		0.046	5.152	YES
16	OFF	OFF		OFF	OFF	OFF
17	OFF	OFF		OFF	OFF	OFF
18	OFF	OFF		OFF	OFF	OFF
19	0.083	0.083		0.045	5.138	YES
20	OFF	OFF		OFF	OFF	OFF
21	0.224	0.343		0.010	5.200	YES
22	OFF	OFF		OFF	OFF	OFF
23	OFF	OFF		OFF	OFF	OFF
24	OFF	OFF		OFF	OFF	OFF
25	OFF	OFF		OFF	OFF	OFF
26	OFF	OFF		OFF	OFF	OFF
27	0.090	0.090		0.013	5.673	YES
28	0.093	0.094		0.031	5.303	YES
29						
30						
31						

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> [Y/N]	All turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? <input checked="" type="checkbox"/> [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily? <input checked="" type="checkbox"/> YES
CT's met daily? (p. 2) <input checked="" type="checkbox"/> YES	All Cl ₂ residual at EP ≥ 0.2 mg/L? <input checked="" type="checkbox"/> YES	PDR ≤ PDR _{Max} ? <input checked="" type="checkbox"/> YES	LRV _{ambient} ≥ LRC? <input checked="" type="checkbox"/> YES	

PRINTED NAME: NATHAN GERHARD

SIGNATURE: [Signature]

Notes:

DATE: 3-3-26

WT CERT #: 810245

PHONE #: 541-265-4560

OHA-DWS

Disinfection Monthly Operating Report

System Name: BEVERLY BEACH STATE PARK

PWS ID#: 41 - 91052

4.00

↳ Log Inactivation Required via Disinfection

Plant ID: WTP - A

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [°C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.25	3868	4835	8.8	7.0	39	YES	7.9	OFF
2	1.26	3638	4584	8.8	7.0	39	YES	8.4	
3	1.35	3286	4436	8.9	6.9	39	YES	9.3	
4	1.40	3513	4918	9.2	6.9	39	YES	8.7	
5	1.24	3118	3866	9.3	6.9	39	YES	9.8	
6	1.06	2729	2893	9.4	6.8	39	YES	11.2	
7	1.24	3358	4164	9.5	6.7	39	YES	9.1	
8	1.17	3434	4018	9.9	7.0	39	YES	8.9	OFF
9	1.14	3513	4004	9.9	6.9	39	YES	8.7	OFF
10	1.24	3434	4258	9.6	7.0	39	YES	8.9	OFF
11	1.11	3553	3944	9.4	7.0	39	YES	8.6	OFF
12	1.10	2996	3296	9.2	6.9	39	YES	10.2	
13	0.99	2612	2586	9.1	7.1	39	YES	11.7	
14	1.04	2281	2372	8.9	7.0	39	YES	13.4	
15	1.02	1910	1948	8.8	7.0	39	YES	16.0	OFF
16	1.06	3151	3340	8.8	6.7	39	YES	9.7	OFF
17	1.08	3026	3268	8.3	7.0	39	YES	10.1	OFF
18	0.99	3358	3324	8.1	7.0	39	YES	9.1	OFF
19	1.02	2938	2997	7.5	6.9	39	YES	10.4	
20	1.07	2505	2680	7.3	6.9	39	YES	12.2	OFF
21	1.02	2996	3056	6.9	6.7	39	YES	10.2	
22	1.02	3358	3425	7.3	6.9	39	YES	9.1	OFF
23	1.09	2657	2897	7.3	7.0	39	YES	11.5	OFF
24	1.03	3820	3935	7.6	7.1	39	YES	8.0	OFF
25	1.15	3358	3862	7.8	7.0	39	YES	9.1	OFF
26	1.08	2856	3085	7.9	6.9	39	YES	10.7	OFF
27	1.05	2281	2395	7.4	6.9	39	YES	13.4	
28	1.15	2099	2391	7.3	6.9	39	YES	14.7	
29									
30									
31									

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
 PO Box 14350
 Portland, OR 97293-0350
 email: dwp.dmce@odhsoha.oregon.gov
 fax: 971-673-0458