

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Marion
 Month/Year: Oct-21

Conventional or Direct Filtration

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	0.06	0.06	0.05	Off	0.06
3	Off	Off	Off	Off	Off	Off	OFF
4	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	0.06	0.06	0.06	Off	0.06
6	Off	Off	Off	Off	Off	Off	OFF
7	Off	Off	Off	Off	Off	Off	OFF
8	Off	Off	0.06	0.07	0.07	Off	0.07
9	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	Off	Off	Off	Off	OFF
11	Off	Off	0.07	0.07	0.06	Off	0.07
12	Off	Off	Off	Off	Off	Off	OFF
13	Off	Off	Off	Off	Off	Off	OFF
14	Off	Off	Off	Off	Off	Off	OFF
15	Off	Off	0.06	0.06	0.06	Off	0.06
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	Off	Off	Off	Off	OFF
18	Off	Off	0.05	0.05	0.05	Off	0.05
19	Off	Off	Off	Off	Off	Off	OFF
20	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	0.05	0.06	0.06	Off	0.06
22	Off	Off	Off	Off	Off	Off	OFF
23	Off	Off	Off	Off	Off	Off	OFF
24	Off	Off	0.06	0.07	0.07	Off	0.07
25	Off	Off	Off	Off	Off	Off	OFF
26	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	Off	Off	Off	Off	OFF
28	Off	Off	0.07	0.07	0.07	Off	0.07
29	Off	Off	Off	Off	Off	Off	OFF
30	Off	Off	Off	Off	Off	Off	OFF
31	Off	Off	Off	Off	Off	Off	OFF

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes		
All turbidity readings < IFE ² triggers Yes		

PRINTED NAME: Dan Faulkner
 SIGNATURE: *Dan Faulkner*
 PHONE #: (503) 854-3406
 11/1/2021
 CERT #: T6666

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: OPRD Detroit Lake State Park	ID#: 41	91059	Month/Year: Oct-21	Disinfection <i>Giardia</i> Log Inactiv: 1
---	---------	-------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.9	90	81.0	10.0	7.00	38.2	Yes	40
2	0.8	90	72.0	10.0	6.90	36.5	Yes	40
3	1	90	90.0	10.0	7.10	40.0	Yes	40
4	0.9	90	81.0	10.0	7.00	38.2	Yes	40
5	0.8	90	72.0	10.0	7.00	37.7	Yes	40
6	1	90	90.0	10.0	7.10	40.0	Yes	40
7	0.9	90	81.0	9.0	7.00	40.7	Yes	40
8	0.9	90	81.0	9.0	7.00	40.7	Yes	40
9	1.1	90	99.0	9.0	7.20	44.7	Yes	40
10	1	90	90.0	9.0	7.1	42.7	Yes	40
11	1	90	90.0	9.0	7.1	42.7	Yes	40
12	1.1	90	99.0	9.0	7.2	44.7	Yes	40
13	1	90	90.0	9.0	7.1	42.7	Yes	40
14	0.9	90	81.0	9.0	7	40.7	Yes	40
15	0.9	90	81.0	9.0	6.9	39.3	Yes	40
16	1.1	90	99.0	9.0	7.1	43.1	Yes	40
17	1	90	90.0	9.0	7.1	42.7	Yes	40
18	0.8	90	72.0	9.0	7	40.3	Yes	40
19	1.1	90	99.0	8.0	7.1	46.1	Yes	40
20	0.9	90	81.0	8.0	7	43.5	Yes	40
21	0.9	90	81.0	8.0	7	43.5	Yes	40
22	1	90	90.0	8.0	7.2	47.2	Yes	40
23	0.9	90	81.0	8.0	7.1	45.1	Yes	40
24	0.9	90	81.0	8.0	7	43.5	Yes	40
25	1	90	90.0	8.0	7.1	45.6	Yes	40
26	0.9	90	81.0	8.0	7.1	45.1	Yes	40
27	0.8	90	72.0	8.0	7	43.0	Yes	40
28	0.8	90	72.0	8.0	7	43.0	Yes	40
29	1.1	90	99.0	8.0	7.1	46.1	Yes	40
30	1	90	90.0	8.0	7.1	45.6	Yes	40
31	1	90	90.0	8.0	7	44.0	Yes	40

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012