

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: Marion  
 Month/Year: Feb-23  
 WTP : TP -

System Name: **OPRD Detroit Lake State Park** ID#: **41 91059**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	0.14	0.13	0.13	OFF	0.14
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	0.11	0.11	0.11	OFF	0.11
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	0.09	0.10	0.11	OFF	0.11
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	0.09	0.09	0.09	OFF	0.09
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	0.11	0.12	0.12	OFF	0.12
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	0.11	0.11	0.11	OFF	0.11
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	NA	NA	NA	NA	NA	NA	NA
30	NA	NA	NA	NA	NA	NA	NA
31	NA	NA	NA	NA	NA	NA	NA

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <span style="float: right;"><b>Yes</b></span>	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU? <span style="float: right;"><b>Yes</b></span>	<b>Yes</b>	<b>Yes</b>

<b>Notes: System was offline until February 3rd, 2023 after superchlorining tank and system and flushing to normal operating chlorine levels.</b>	Dan Faulkner	
	SIGNATURE:	DATE: 3/1/2023
	PHONE #: ( 503 ) 854-3406	CERT #: T-6666

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Feb-23

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
2	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
3	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
4	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
5	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
6	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
7	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
8	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
9	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
10	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
11	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
12	OFF	90	#VALUE!	OFF	OFF	#VALUE!	#VALUE!	OFF
13	0.8	90	72.0	6.0	7.10	50.9	YES	20
14	1.2	90	108.0	6.0	7.10	53.3	YES	20
15	1.1	90	99.0	5.0	7.00	54.3	YES	20
16	1.1	90	99.0	5.0	7.10	56.3	YES	20
17	1.2	90	108.0	5.0	7.20	59.1	YES	30
18	1.1	90	99.0	5.0	7.10	56.3	YES	30
19	1.1	90	99.0	5.0	7.00	54.3	YES	30
20	1	90	90.0	6.0	7.00	50.2	YES	20
21	1	90	90.0	6.0	7.10	52.1	YES	20
22	1	90	90.0	5.0	7.20	57.7	YES	20
23	1.1	90	99.0	5.0	7.10	56.3	YES	20
24	1	90	90.0	5.0	7.00	53.7	YES	30
25	1.3	90	117.0	5.0	7.00	55.6	YES	30
26	1.2	90	108.0	5.0	7.20	59.1	YES	30
27	1.1	90	99.0	5.0	7.10	56.3	YES	20
28	1.1	90	99.0	5.0	7.00	54.3	YES	20
29	NA	90	#VALUE!	NA	NA	#VALUE!	#VALUE!	NA
30	NA	90	#VALUE!	NA	NA	#VALUE!	#VALUE!	NA
31	NA	90	#VALUE!	NA	NA	#VALUE!	#VALUE!	NA

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350