

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Marion

Month/Year: Aug-24

System Name: OPRD Detroit Lake State Park ID#: 41 91059

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	0.07	0.07	0.06	Off	0.07
3	Off	Off	0.07	0.07	0.07	Off	0.07
4	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	Off	Off	Off	Off	OFF
6	Off	Off	0.08	0.09	0.09	Off	0.09
7	Off	Off	0.11	0.10	0.09	Off	0.11
8	Off	Off	0.12	0.11	0.10	Off	0.12
9	Off	Off	0.10	0.09	0.09	Off	0.10
10	Off	Off	0.10	0.10	0.09	Off	0.10
11	Off	Off	0.10	0.10	0.09	Off	0.10
12	Off	Off	0.09	0.09	0.10	Off	0.10
13	Off	Off	0.10	0.10	0.10	Off	0.10
14	Off	Off	0.09	0.09	0.09	Off	0.09
15	Off	Off	0.09	0.10	0.09	Off	0.10
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	0.16	0.11	0.09	Off	0.16
18	Off	Off	0.08	0.08	0.08	Off	0.08
19	Off	Off	Off	Off	Off	Off	OFF
20	Off	Off	0.08	0.07	0.07	Off	0.08
21	Off	Off	0.08	0.08	0.08	Off	0.08
22	Off	Off	0.08	0.08	0.08	Off	0.08
23	Off	Off	0.08	0.09	0.08	Off	0.09
24	Off	Off	0.09	0.08	0.07	Off	0.09
25	Off	Off	0.07	.07\	0.06	Off	0.07
26	Off	Off	0.06	0.06	0.06	Off	0.06
27	Off	Off	0.06	0.07	0.07	Off	0.07
28	Off	Off	0.08	0.08	0.07	Off	0.08
29	Off	Off	0.08	0.08	0.08	Off	0.08
30	Off	Off	0.09	0.09	0.08	Off	0.09
31	Off	Off	Off	Off	Off	Off	OFF

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	Yes
All daily turbidity readings ≤ 5 NTU?	Yes

<b>Monthly Summary (Answer Yes or No)</b>	
CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
Yes	Yes

**Notes:**

**Dan Faulkner**  
 SIGNATURE:   
 PHONE #: ( 503 )854-3406  
 DATE: 8/4/2024  
 CERT #: T-6666

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Aug-24

WTP: Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	143	128.7	13.0	7.90	42.9	YES	60
2	1	143	143.0	13.0	7.90	43.4	YES	60
3	1.2	143	171.6	13.0	7.80	42.8	YES	60
4	1.1	143	157.3	13.0	7.80	42.3	YES	60
5	1.1	143	157.3	13.0	7.70	40.8	YES	60
6	1	143	143.0	13.0	7.70	40.3	YES	60
7	1.1	143	157.3	13.0	7.80	42.3	YES	60
8	1.3	143	185.9	13.0	7.90	44.9	YES	60
9	1.3	143	185.9	13.0	7.90	44.9	YES	60
10	1.1	143	157.3	13.0	7.90	43.9	YES	60
11	1	143	143.0	13.0	7.80	41.8	YES	60
12	1	143	143.0	12.0	7.80	44.8	YES	60
13	0.9	143	128.7	12.0	7.80	44.3	YES	60
14	0.8	143	114.4	12.0	7.80	43.8	YES	60
15	0.8	143	114.4	12.0	7.90	45.3	YES	60
16	0.8	143	114.4	12.0	7.80	43.8	YES	60
17	0.9	143	128.7	12.0	7.70	42.7	YES	60
18	1	143	143.0	12.0	7.80	44.8	YES	60
19	0.9	143	128.7	12.0	7.90	45.8	YES	60
20	0.8	143	114.4	12.0	7.80	43.8	YES	60
21	0.8	143	114.4	12.0	7.90	45.3	YES	60
22	0.9	143	128.7	11.0	7.80	47.3	YES	60
23	0.8	143	114.4	11.0	7.70	45.1	YES	60
24	0.9	143	128.7	11.0	7.80	47.3	YES	60
25	1	143	143.0	11.0	7.80	47.8	YES	60
26	0.9	143	128.7	11.0	7.90	49.0	YES	60
27	0.9	143	128.7	11.0	7.90	49.0	YES	60
28	0.8	143	114.4	11.0	7.80	46.8	YES	60
29	1	143	143.0	11.0	7.8	47.8	YES	60
30	1	143	143.0	12.0	7.9	46.4	YES	60
31	1	143	143.0	12.0	7.9	46.4	YES	60

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350