

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: **Marion**

Month/Year: **Mar-25**

System Name: **OPRD Detroit Lake State Park ID#: 41 91059**

WTP : **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	Off	Off	Off	Off	OFF
3	Off	Off	Off	Off	Off	Off	OFF
4	Off	Off	0.08	0.08	0.08	Off	0.08
5	Off	Off	Off	Off	Off	Off	OFF
6	Off	Off	Off	Off	Off	Off	OFF
7	Off	Off	0.07	0.08	Off	Off	0.08
8	Off	Off	0.08	0.09	Off	Off	0.09
9	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	Off	Off	Off	Off	OFF
11	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	0.08	0.07	0.08	Off	0.08
13	Off	Off	Off	Off	Off	Off	OFF
14	Off	Off	Off	Off	Off	Off	OFF
15	Off	Off	0.08	0.08	0.08	Off	0.08
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	Off	Off	Off	Off	OFF
18	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	0.07	0.08	Off	Off	0.08
20	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	Off	Off	Off	Off	OFF
22	Off	Off	0.08	0.08	Off	Off	0.08
23	Off	Off	Off	Off	Off	Off	OFF
24	Off	Off	Off	Off	Off	Off	OFF
25	Off	Off	Off	Off	Off	Off	OFF
26	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	0.06	0.07	0.07	Off	0.07
28	Off	Off	Off	Off	Off	Off	OFF
29	Off	Off	0.07	0.08	Off	Off	0.08
30	Off	Off	Off	Off	Off	Off	OFF
31	Off	Off	0.08	Off	Off	Off	0.08

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings $\leq$ 1 NTU? ² Yes All daily turbidity readings $\leq$ 5 NTU? Yes with low water use many days are only ran for 4 hours to help keep Chlorine levels steady.		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point $\geq$ 0.2 mg/l? Yes	
Dan Faulkner SIGNATURE:  PHONE #: (503)854-3406		DATE: 4/7/2025 CERT #: T-6666	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Mar-25

Disinfection *Giardia* Log
Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.1	143	157.3	6.0	7.80	67.8	YES	30
2	1.1	143	157.3	6.0	7.90	70.3	YES	30
3	1	143	143.0	6.0	7.80	67.0	YES	30
4	1	143	143.0	6.0	7.90	69.5	YES	30
5	0.9	143	128.7	6.0	7.80	66.3	YES	30
6	1	143	143.0	6.0	7.80	67.0	YES	30
7	1	143	143.0	6.0	7.90	69.5	YES	30
8	1	143	143.0	6.0	8.00	72.1	YES	30
9	1	143	143.0	6.0	7.90	69.5	YES	30
10	1	143	143.0	6.0	7.80	67.0	YES	30
11	1	143	143.0	6.0	7.80	67.0	YES	30
12	1	143	143.0	6.0	7.90	69.5	YES	30
13	1.1	143	157.3	6.0	7.80	67.8	YES	30
14	1.1	143	157.3	6.0	7.80	67.8	YES	30
15	1	143	143.0	6.0	7.70	64.6	YES	40
16	1	143	143.0	6.0	7.70	64.6	YES	40
17	1	143	143.0	6.0	7.90	69.5	YES	40
18	0.9	143	128.7	6.0	7.90	68.7	YES	40
19	0.9	143	128.7	6.0	7.80	66.3	YES	40
20	1.1	143	157.3	7.0	7.90	65.7	YES	40
21	1.1	143	157.3	7.0	7.80	63.3	YES	40
22	1	143	143.0	7.0	7.80	62.6	YES	40
23	1	143	143.0	7.0	7.80	62.6	YES	40
24	1.1	143	157.3	7.0	7.90	65.7	YES	40
25	1	143	143.0	7.0	7.80	62.6	YES	40
26	1	143	143.0	7.0	7.80	62.6	YES	40
27	1	143	143.0	7.0	7.70	60.4	YES	40
28	1.1	143	157.3	7.0	7.80	63.3	YES	40
29	1.1	143	157.3	7.0	7.8	63.3	YES	40
30	1	143	143.0	7.0	7.9	64.9	YES	40
31	1	143	143.0	7.0	7.9	64.9	YES	40

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350