


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Marion**

Month/Year: **Sep-25**

System Name: **OPRD Detroit Lake State Park** ID#: **41 91059** WTP: **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off	Off	0.08	0.08	0.08	Off	0.08
2	Off	Off	0.09	0.09	0.08	0.00	0.09
3	Off	Off	0.08	0.09	0.08	Off	0.09
4	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	0.10	0.09	0.08	Off	0.10
6	Off	Off	0.08	0.08	0.08	Off	0.08
7	Off	Off	0.08	0.09	0.09	Off	0.09
8	Off	Off	0.09	0.09	0.08	Off	0.09
9	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	0.08	0.08	0.08	Off	0.08
11	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	0.10	0.09	0.09	Off	0.10
13	Off	Off	0.09	0.09	0.08	Off	0.09
14	Off	Off	0.09	0.09	0.09	Off	0.09
15	Off	Off	0.10	0.10	0.09	Off	0.10
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	0.09	0.09	0.08	Off	0.09
18	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	0.09	0.08	0.08	Off	0.09
20	Off	Off	0.09	0.09	0.08	Off	0.09
21	Off	Off	0.09	0.09	0.09	Off	0.09
22	Off	Off	Off	Off	Off	Off	OFF
23	Off	Off	0.09	0.08	0.08	Off	0.09
24	Off	Off	0.08	0.08	0.07	Off	0.08
25	Off	Off	0.07	0.07	0.07	Off	0.07
26	Off	Off	0.07	0.08	0.08	Off	0.08
27	Off	Off	0.09	0.10	0.09	Off	0.10
28	Off	Off	Off	Off	Off	Off	OFF
29	Off	Off	Off	Off	Off	Off	OFF
30	Off	Off	0.10	0.10	0.09	Off	0.10
31	NA	NA	NA	NA	NA	NA	NA

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes	Yes	Yes
with low water use many days are only ran for 4 hours to help keep Chlorine levels steady.		Dan Faulkner	
		SIGNATURE: 	DATE: 10/8/2025
		PHONE #: (503) 854-3406	CERT #: T-6666

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Sep-25

Disinfection *Giardia* Log

Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	143	143.0	12.0	7.70	43.2	YES	50
2	1	143	143.0	12.0	7.80	44.8	YES	50
3	1	143	143.0	12.0	7.80	44.8	YES	50
4	0.9	143	128.7	12.0	7.90	45.8	YES	50
5	0.9	143	128.7	13.0	7.70	39.9	YES	50
6	1	143	143.0	13.0	7.70	40.3	YES	50
7	0.9	143	128.7	12.0	7.80	44.3	YES	50
8	0.8	143	114.4	12.0	7.80	43.8	YES	50
9	1	143	143.0	12.0	7.80	44.8	YES	50
10	0.9	143	128.7	12.0	7.90	45.8	YES	50
11	1	143	143.0	11.0	7.90	49.6	YES	50
12	0.9	143	128.7	11.0	7.80	47.3	YES	50
13	1	143	143.0	11.0	7.80	47.8	YES	50
14	0.9	143	128.7	11.0	7.80	47.3	YES	50
15	0.9	143	128.7	11.0	7.90	49.0	YES	50
16	1.1	143	157.3	11.0	7.80	48.4	YES	50
17	1	143	143.0	11.0	7.80	47.8	YES	50
18	1.1	143	157.3	11.0	7.90	50.1	YES	50
19	1	143	143.0	11.0	7.80	47.8	YES	50
20	1	143	143.0	11.0	7.80	47.8	YES	50
21	1	143	143.0	11.0	7.80	47.8	YES	50
22	0.9	143	128.7	11.0	7.90	49.0	YES	50
23	0.9	143	128.7	11.0	7.80	47.3	YES	50
24	1	143	143.0	10.0	7.80	51.1	YES	50
25	1.1	143	157.3	10.0	7.80	51.7	YES	40
26	1.3	143	185.9	10.0	7.90	54.9	YES	40
27	1.1	143	157.3	10.0	7.90	53.6	YES	40
28	1	143	143.0	10.0	7.80	51.1	YES	40
29	1.2	143	171.6	10.0	7.7	50.5	YES	40
30	1	143	143.0	10.0	7.8	51.1	YES	40
31	NA	NA	#VALUE!	NA	NA	#VALUE!	#VALUE!	NA

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350