


## OHA - Drinking Water Services - Surface Water Quality Data Form

## Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Marion

Month/Year: Oct-25

System Name: OPRD Detroit Lake State Park		ID#: 41		91059		WTP : TP -		
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	Off	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	0.08	0.07	Off	Off	Off	0.07
3	Off	Off	Off	Off	7.00	Off	Off	OFF
4	Off	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	0.08	0.08	0.08	Off	Off	0.08
6	Off	Off	0.08	0.07	0.08	Off	Off	0.08
7	Off	Off	Off	Off	Off	Off	Off	OFF
8	Off	Off	Off	Off	Off	Off	Off	OFF
9	Off	Off	0.07	0.08	0.08	Off	Off	0.08
10	Off	Off	0.07	0.07	0.07	Off	Off	0.07
11	Off	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	0.12	0.11	0.10	Off	Off	0.12
13	Off	Off	0.10	0.09	0.09	Off	Off	0.10
14	Off	Off	Off	Off	Off	Off	Off	OFF
15	Off	Off	0.11	0.10	0.10	Off	Off	0.11
16	Off	Off	0.10	0.10	0.08	Off	Off	0.10
17	Off	Off	0.08	0.08	0.07	Off	Off	0.08
18	Off	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	0.07	0.07	0.07	Off	Off	0.07
20	Off	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	Off	Off	Off	Off	Off	OFF
22	Off	Off	0.08	0.07	0.08	Off	Off	0.08
23	Off	Off	Off	Off	Off	Off	Off	OFF
24	Off	Off	0.08	0.08	0.08	Off	Off	0.08
25	Off	Off	Off	Off	Off	Off	Off	OFF
26	Off	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	0.08	0.07	0.07	Off	Off	0.08
28	Off	Off	0.07	0.08	0.08	Off	Off	0.08
29	Off	Off	Off	Off	Off	Off	Off	OFF
30	Off	Off	Off	Off	Off	Off	Off	OFF
31	Off	Off	0.08	0.08	0.08	Off	Off	0.08
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>			Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?		
All daily turbidity readings $\leq$ 5 NTU?			Yes	Yes		Yes		
Notes: System was offline until February 3rd, 2023 after superchlorining tank and system and flushing to normal operating chlorine levels.				Dan Faulkner 				
				SIGNATURE: 		DATE: 11/5/2025		
				PHONE #: ( 503 )854-3406		CERT #: T-6666		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Oct-23							WTP- : Disinfection Giardia Log	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.1	143	157.3	10.0	7.70	49.9	YES	40
2	1	143	143.0	10.0	7.80	51.1	YES	40
3	1	143	143.0	10.0	7.80	51.1	YES	40
4	1	143	143.0	10.0	7.90	53.0	YES	40
5	0.9	143	128.7	10.0	7.90	52.4	YES	40
6	1	143	143.0	10.0	7.80	51.1	YES	40
7	1	143	143.0	9.0	7.80	54.7	YES	40
8	1	143	143.0	9.0	7.90	56.7	YES	40
9	0.9	143	128.7	9.0	7.90	56.0	YES	40
10	0.9	143	128.7	9.0	7.80	54.1	YES	40
11	0.9	143	128.7	9.0	7.80	54.1	YES	40
12	0.8	143	114.4	9.0	7.90	55.4	YES	40
13	0.8	143	114.4	9.0	7.90	55.4	YES	40
14	0.8	143	114.4	9.0	8.00	57.4	YES	40
15	0.8	143	114.4	8.0	8.00	61.4	YES	40
16	1	143	143.0	8.0	7.90	60.7	YES	40
17	1	143	143.0	8.0	7.90	60.7	YES	40
18	1.1	143	157.3	8.0	7.80	59.2	YES	40
19	1	143	143.0	8.0	7.80	58.5	YES	40
20	1	143	143.0	8.0	7.80	58.5	YES	40
21	1	143	143.0	8.0	7.90	60.7	YES	40
22	1	143	143.0	7.0	7.80	62.6	YES	30
23	0.9	143	128.7	7.0	7.70	59.7	YES	30
24	0.9	143	128.7	7.0	7.70	59.7	YES	30
25	1.1	143	157.3	7.0	7.80	63.3	YES	30
26	1	143	143.0	7.0	7.80	62.6	YES	30
27	0.9	143	128.7	7.0	7.80	61.9	YES	30
28	1.1	143	157.3	7.0	7.80	63.3	YES	30
29	1.1	143	157.3	7.0	7.9	65.7	YES	30
30	1.1	143	157.3	7.0	7.8	63.3	YES	20
31	1	143	143.0	7.0	7.9	64.9	YES	20

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@oha.oregon.gov](mailto:dwp.dmce@oha.oregon.gov); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350