


OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Marion

Month/Year: Nov-25

System Name: OPRD Detroit Lake State Park		ID#: 41		91059		WTP : TP -		
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	Off	Off	Off	Off	Off	OFF
3	Off	Off	0.07	0.06	0.06	Off	Off	0.07
4	Off	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	Off	Off	Off	Off	Off	OFF
6	Off	Off	Off	Off	Off	Off	Off	OFF
7	Off	Off	0.07	0.08	0.07	Off	Off	0.08
8	Off	Off	Off	Off	Off	Off	Off	OFF
9	Off	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	0.07	0.07	0.07	Off	Off	0.07
11	Off	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	Off	Off	Off	Off	Off	OFF
13	Off	Off	Off	Off	Off	Off	Off	OFF
14	Off	Off	0.08	0.08	0.08	Off	Off	0.08
15	Off	Off	Off	Off	Off	Off	Off	OFF
16	Off	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	Off	Off	Off	Off	Off	OFF
18	Off	Off	0.08	0.07	0.08	Off	Off	0.08
19	Off	Off	Off	Off	Off	Off	Off	OFF
20	Off	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	0.07	0.08	0.08	Off	Off	0.08
22	Off	Off	Off	Off	Off	Off	Off	OFF
23	Off	Off	Off	Off	Off	Off	Off	OFF
24	Off	Off	Off	Off	Off	Off	Off	OFF
25	Off	Off	0.17	0.08	0.07	Off	Off	0.17
26	Off	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	Off	Off	Off	Off	Off	OFF
28	Off	Off	Off	Off	Off	Off	Off	OFF
29	Off	Off	0.08	0.07	0.07	Off	Off	0.08
30	Off	Off	Off	Off	Off	Off	Off	OFF
31	NA	NA	NA	NA	NA	NA	NA	NA
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings \leq 1 NTU? ²			Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?		
All daily turbidity readings \leq 5 NTU?			Yes	Yes		Yes		
Notes: System was offline until February 3rd, 2023 after superchlorining tank and system and flushing to normal operating chlorine levels.					Dan Faulkner			
					SIGNATURE: 			
					DATE: 12/5/2025			
					PHONE #: (503)854-3406			
					CERT #: T-6666			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Nov-25							WTP- : Disinfection Giardia Log Inactiv:	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1	143	143.0	6.0	7.70	64.6	YES	30
2	1	143	143.0	6.0	7.70	64.6	YES	30
3	1	143	143.0	6.0	7.80	67.0	YES	20
4	1.1	143	157.3	6.0	7.80	67.8	YES	20
5	1	143	143.0	6.0	7.90	69.5	YES	20
6	0.9	143	128.7	6.0	7.80	66.3	YES	20
7	0.8	143	114.4	6.0	7.80	65.5	YES	30
8	0.9	143	128.7	6.0	7.90	68.7	YES	30
9	0.9	143	128.7	7.0	7.90	64.2	YES	30
10	0.9	143	128.7	7.0	7.80	61.9	YES	20
11	0.9	143	128.7	7.0	7.90	64.2	YES	20
12	0.9	143	128.7	6.0	7.80	66.3	YES	20
13	0.9	143	128.7	6.0	7.80	66.3	YES	20
14	0.8	143	114.4	6.0	7.80	65.5	YES	30
15	0.8	143	114.4	6.0	7.70	63.1	YES	30
16	0.8	143	114.4	6.0	7.90	67.9	YES	20
17	0.9	143	128.7	6.0	7.80	66.3	YES	20
18	0.8	143	114.4	6.0	7.90	67.9	YES	20
19	1.2	143	171.6	6.0	7.90	71.2	YES	20
20	1.2	143	171.6	6.0	7.80	68.6	YES	30
21	1.1	143	157.3	6.0	7.90	70.3	YES	30
22	1.1	143	157.3	6.0	7.80	67.8	YES	30
23	2	143	286.0	6.0	7.80	75.4	YES	30
24	1	143	143.0	6.0	7.80	67.0	YES	30
25	1	143	143.0	6.0	7.80	67.0	YES	30
26	1.1	143	157.3	6.0	7.70	65.4	YES	30
27	1	143	143.0	6.0	7.80	67.0	YES	40
28	1	143	143.0	7.0	7.80	62.6	YES	40
29	1	143	143.0	7.0	7.8	62.6	YES	30
30	1	143	143.0	7.0	7.8	62.6	YES	30
31	NA	NA	#VALUE!	NA	NA	#VALUE!	NA	NA

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350