

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Marion


Month/Year: Dec-25

System Name: **OPRD Detroit Lake State Park** ID#: **41 91059** WTP : **TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	Off	Off	Off	Off	OFF
3	Off	Off	Off	Off	Off	Off	OFF
4	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	0.09	0.08	0.08	Off	0.09
6	Off	Off	0.08	0.08	0.08	Off	0.08
7	Off	Off	Off	Off	Off	Off	OFF
8	Off	Off	Off	Off	Off	Off	OFF
9	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	Off	Off	Off	Off	OFF
11	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	0.08	0.09	0.09	Off	0.09
13	Off	Off	0.09	0.10	0.09	Off	0.10
14	Off	Off	Off	Off	Off	Off	OFF
15	Off	Off	0.09	0.09	0.09	Off	0.09
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	Off	Off	Off	Off	OFF
18	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	0.17	0.10	0.10	Off	0.17
20	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	Off	Off	Off	Off	OFF
22	Off	Off	Off	Off	Off	Off	OFF
23	Off	Off	0.10	0.10	0.09	Off	0.10
24	Off	Off	0.10	0.10	0.10	Off	0.10
25	Off	Off	Off	Off	Off	Off	OFF
26	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	Off	Off	Off	Off	OFF
28	Off	Off	0.10	0.09	0.10	Off	0.10
29	Off	Off	Off	Off	Off	Off	OFF
30	Off	Off	Off	Off	Off	Off	OFF
31	Off	Off	Off	Off	Off	Off	OFF

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU? Yes	Yes	Yes

Notes: System was offline until February 3rd, 2023 after superchlorining tank and system and flushing to normal operating chlorine levels.

Dan Faulkner
SIGNATURE: 
PHONE #: (503)854-3406 **DATE:1/5/2026**
CERT #:T-6666

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Dec-25

Disinfection *Giardia* Log
Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	143	143.0	6.0	7.90	69.5	YES	30
2	1	143	143.0	6.0	7.80	67.0	YES	30
3	1	143	143.0	6.0	7.80	67.0	YES	20
4	0.9	143	128.7	6.0	7.70	63.9	YES	20
5	0.9	143	128.7	6.0	7.80	66.3	YES	20
6	0.9	143	128.7	6.0	7.80	66.3	YES	20
7	0.9	143	128.7	6.0	7.80	66.3	YES	30
8	1	143	143.0	7.0	7.80	62.6	YES	30
9	1	143	143.0	7.0	7.70	60.4	YES	30
10	1	143	143.0	7.0	7.80	62.6	YES	20
11	1	143	143.0	7.0	7.80	62.6	YES	20
12	0.9	143	128.7	7.0	7.80	61.9	YES	20
13	1	143	143.0	7.0	7.80	62.6	YES	20
14	1.1	143	157.3	7.0	7.80	63.3	YES	30
15	1.1	143	157.3	7.0	7.70	61.1	YES	30
16	1.2	143	171.6	6.0	7.80	68.6	YES	20
17	1.1	143	157.3	6.0	7.80	67.8	YES	20
18	1	143	143.0	6.0	7.90	69.5	YES	20
19	1	143	143.0	7.0	7.90	64.9	YES	20
20	1	143	143.0	7.0	7.80	62.6	YES	20
21	0.9	143	128.7	7.0	7.90	64.2	YES	20
22	1	143	143.0	7.0	7.80	62.6	YES	20
23	1	143	143.0	7.0	7.90	64.9	YES	20
24	1.2	143	171.6	7.0	8.00	68.9	YES	20
25	1.1	143	157.3	7.0	7.90	65.7	YES	20
26	1	143	143.0	7.0	7.80	62.6	YES	20
27	0.9	143	128.7	7.0	7.80	61.9	YES	20
28	0.9	143	128.7	7.0	7.80	61.9	YES	20
29	0.9	143	128.7	6.0	7.9	68.7	YES	20
30	0.9	143	128.7	6.0	7.9	68.7	YES	20
31	0.8	143	114.4	6.0	7.9	67.9	YES	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350