

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Marion  
 Month/Year: Feb-25

System Name: OPRD Detroit Lake State Park		ID#: 41 91059		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	Off	Off	Off	Off	Off	Off	OFF
2	Off	Off	Off	Off	Off	Off	OFF
3	Off	Off	0.07	0.08	0.08	Off	0.08
4	Off	Off	Off	Off	Off	Off	OFF
5	Off	Off	Off	Off	Off	Off	OFF
6	Off	Off	Off	Off	Off	Off	OFF
7	Off	Off	0.08	0.08	0.07	Off	0.08
8	Off	Off	Off	Off	Off	Off	OFF
9	Off	Off	Off	Off	Off	Off	OFF
10	Off	Off	Off	Off	Off	Off	OFF
11	Off	Off	Off	Off	Off	Off	OFF
12	Off	Off	0.07	0.07	0.07	Off	0.07
13	Off	Off	Off	Off	Off	Off	OFF
14	Off	Off	Off	Off	Off	Off	OFF
15	Off	Off	0.07	0.08	0.08	Off	0.08
16	Off	Off	Off	Off	Off	Off	OFF
17	Off	Off	Off	Off	Off	Off	OFF
18	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	0.07	0.08	0.08	Off	0.08
20	Off	Off	Off	Off	Off	Off	OFF
21	Off	Off	Off	Off	Off	Off	OFF
22	Off	Off	Off	Off	Off	Off	OFF
23	Off	Off	0.06	0.06	0.07	Off	0.07
24	Off	Off	Off	Off	Off	Off	OFF
25	Off	Off	Off	Off	Off	Off	OFF
26	Off	Off	Off	Off	Off	Off	OFF
27	Off	Off	0.10	0.09	0.08	Off	0.10
28	Off	Off	Off	Off	Off	Off	OFF
29	NA	NA	NA	NA	NA	NA	NA
30	NA	NA	NA	NA	NA	NA	NA
31	NA	NA	NA	NA	NA	NA	NA

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings $\leq$ 5 NTU? <b>Yes</b>		

<b>Notes: System was offline until February 3rd, 2023 after superchlorinating tank and system and flushing to normal operating chlorine levels.</b>	Dan Faulkner	
	SIGNATURE:	DATE: 3/6/2026
	PHONE #: ( 503 ) 854-3406	CERT #: T-6666

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: OPRD Detroit Lake State Park ID#: 41 91059 Month/Year: Feb-26 Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	143	143.0	9.0	7.80	54.7	YES	20
2	1	143	143.0	6.0	7.80	67.0	YES	20
3	0.9	143	128.7	6.0	7.80	66.3	YES	20
4	1.1	143	157.3	6.0	7.80	67.8	YES	20
5	1	143	143.0	6.0	7.98	71.6	YES	20
6	1	143	143.0	6.0	7.70	64.6	YES	20
7	0.9	143	128.7	6.0	7.70	63.9	YES	30
8	1	143	143.0	6.0	7.80	67.0	YES	30
9	0.9	143	128.7	6.0	7.80	66.3	YES	20
10	0.9	143	128.7	6.0	7.80	66.3	YES	20
11	0.9	143	128.7	6.0	7.90	68.7	YES	20
12	0.8	143	114.4	5.0	7.90	72.7	YES	20
13	1	143	143.0	6.0	7.80	67.0	YES	20
14	0.9	143	128.7	6.0	7.80	66.3	YES	30
15	0.8	143	114.4	6.0	7.70	63.1	YES	30
16	0.8	143	114.4	6.0	7.80	65.5	YES	20
17	0.8	143	114.4	6.0	7.80	65.5	YES	20
18	0.8	143	114.4	6.0	7.90	67.9	YES	20
19	0.8	143	114.4	5.0	7.80	70.1	YES	20
20	1.1	143	157.3	5.0	7.90	75.4	YES	20
21	1	143	143.0	5.0	7.80	71.8	YES	30
22	0.9	143	128.7	6.0	7.80	66.3	YES	30
23	0.9	143	128.7	6.0	7.90	68.7	YES	20
24	0.9	143	128.7	7.0	7.80	61.9	YES	20
25	0.9	143	128.7	7.0	7.80	61.9	YES	20
26	0.8	143	114.4	7.0	7.80	61.2	YES	20
27	0.8	143	114.4	7.0	7.90	63.4	YES	20
28	1.2	143	171.6	7.0	7.90	66.5	YES	30
NA	NA	143	#VALUE!	6.0	7.9	#VALUE!	#VALUE!	NA
NA	NA	143	#VALUE!	6.0	7.9	#VALUE!	#VALUE!	NA
NA	NA	143	#VALUE!	6.0	7.9	#VALUE!	#VALUE!	NA

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350