

OHA - Drinking Water Program - Turbidity

County: Hood River

System Name: **Mt Hood Meadows Spring** ID#: **4191167** Month/Year: **Nov - 2025**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1						PLANT OFF
2						PLANT OFF
3	38.0	34.0	4.0	25	0.23	0.23
4	38.0	36.0	2.0	25	0.17	0.17
5	38.0	36.5	1.5	25	0.18	0.18
6	38.0	36.0	1.0	25	0.18	0.18
7						PLANT OFF
8						PLANT OFF
9						PLANT OFF
10	36.5	33.0	3.0	25	0.19	0.19
11	38.0	36.0	1.5	25	0.21	0.21
12	38.0	37.0	1.5	25	0.17	0.17
13	38.0	37.0	1.5	25	0.22	0.22
14						PLANT OFF
15						PLANT OFF
16						PLANT OFF
17	38.0	36.0	1.5	25	0.19	0.19
18	38.0	37.0	1.0	25	0.21	0.21
19	37.0	34.0	1.5	25	0.20	0.20
20	37.0	34.0	2.0	25	0.17	0.17
21						PLANT OFF
22						PLANT OFF
23						PLANT OFF
24	33.0	29.0	3.5	25	0.26	0.26
25	38.0	37.0	1.0	25	0.20	0.20
26	38.0	37.0	1.0	25	0.20	0.20
27	38.5	37.0	1.5	25	0.18	0.18
28	38.0	37.0	1.0	25	0.18	0.18
29	38.0	37.0	1.0	25	0.19	0.19
30	37.0	34.0	2.5	25	0.22	0.22

<b>Cartridge &amp; Bag Filtration</b> 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications		PRINTED NAME: <u>Patricio Ramos</u> SIGNATURE: <u>[Signature]</u> DATE: 12/08/25 PHONE #: (503) 337-2222 CERT #: 6903	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: **Mt. Hood Meadows Spring**

ID#: **4191167-A** Month-Year: **Nov-2025**

Disinfection  
Giardia Log  
Inactiv:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 13:00	0.57	9554	5446	8.8	7.73	51.4	Yes	3.1
2 / 10:00	0.60	6303	3782	8.3	7.68	52.4	Yes	4.8
3 / 11:00	0.61	1136	693	7.5	7.69	55.6	Yes	26.4
4 / 11:00	0.58	3109	1803	8.1	7.65	52.5	Yes	9.7
5 / 12:00	0.59	3755	2215	7.8	7.67	54.0	Yes	8.0
6 / 14:00	0.64	3911	2503	7.3	7.68	56.3	Yes	7.7
7 / 10:00	0.59	3896	2299	7.1	7.69	57.0	Yes	7.7
8 / 15:00	0.58	2355	1366	7.6	7.68	54.8	Yes	12.7
9 / 14:00	0.59	6438	3798	7.5	7.63	54.3	Yes	4.7
10 / 13:30	0.60	4098	2459	7.0	7.61	55.8	Yes	7.3
11 / 10:55	0.60	3846	2308	7.8	7.65	53.6	Yes	7.8
12 / 9:05	0.60	2725	1635	7.3	7.63	55.1	Yes	11.0
13 / 15:00	0.58	2650	1537	7.8	7.64	53.3	Yes	11.3
14 / 11:30	0.56	2629	1472	7.1	7.71	57.2	Yes	11.4
15 / 10:10	0.60	2070	1242	7.4	7.69	55.9	Yes	14.5
16 / 11:25	0.63	2297	1447	7.9	7.69	54.2	Yes	13.1
17 / 9:00	0.67	4354	2917	7.8	7.63	53.7	Yes	6.9
18 / 8:25	0.60	5102	3061	7.6	7.64	54.2	Yes	5.9
19 / 11:00	0.62	3793	2351	5.9	7.69	62.0	Yes	7.9
20 / 9:00	0.56	4386	2456	7.0	7.70	57.4	Yes	6.8
21 / 7:35	0.61	4076	2486	6.8	7.71	58.7	Yes	7.4
22 / 16:30	0.67	4754	3185	7.8	7.63	53.7	Yes	6.3
23 / 13:15	0.63	5703	3593	7.6	7.65	54.6	Yes	5.3
24 / 8:50	0.63	2752	1734	6.9	7.65	57.2	Yes	10.9
25 / 9:00	0.67	4104	2750	7.6	7.69	55.6	Yes	7.3
26 / 9:35	0.59	3774	2226	6.0	7.64	60.3	Yes	8.0
27 / 8:20	0.58	7712	4473	6.3	7.80	62.5	Yes	3.9
28 / 9:16	0.65	6410	4167	6.7	7.80	61.4	Yes	4.7
29 / 11:20	0.66	1889	1247	5.8	7.80	65.3	Yes	15.9
30 / 11:00	0.62	602	374	5.4	7.80	66.8	Yes	49.8

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012