

OHA - Drinking Water Program - Turbidity

County: **Hood River**

System Name: **Mt Hood Meadows Spring** ID#: **4191167** Month/Year: **Jan-2026**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	38.0	34.0	3.5	25	0.17	0.17
2	38.0	37.0	1.5	25	0.17	0.17
3						Plant Off
4	37.0	34.0	2.5	25	0.20	0.20
5	38.0	37.0	1.0	25	0.22	0.22
6	38.0	35.0	3.0	25	0.19	0.19
7	38.0	36.0	2.0	25	0.18	0.18
8	37.0	34.0	2.5	25	0.18	0.18
9	38.0	37.0	1.0	25	0.19	0.19
10	38.0	35.0	2.5	25	0.22	0.22
11	37.0	34.0	3.0	25	0.21	0.21
12	38.0	35.0	2.0	25	0.20	0.20
13	37.0	35.0	1.5	25	0.17	0.17
14	38.0	36.0	1.5	25	0.16	0.16
15	38.0	37.0	1.0	25	0.20	0.20
16	38.0	36.0	1.5	25	0.19	0.19
17	37.0	34.0	3.0	25	0.19	0.19
18	36.0	32.0	3.5	25	0.23	0.23
19	38.0	37.0	1.0	25	0.22	0.22
20	37.0	35.0	1.5	25	0.19	0.19
21	38.0	36.0	2.0	25	0.21	0.21
22	38.5	37.5	1.0	25	0.20	0.20
23	37.0	36.0	1.0	25	0.18	0.18
24	38.0	37.0	1.0	25	0.18	0.18
25	37.0	35.0	1.5	25	0.18	0.18
26	36.0	33.0	3.0	25	0.18	0.18
27	38.0	37.0	1.0	25	0.20	0.20
28	38.0	37.0	1.5	25	0.19	0.19
29	38.5	37.0	1.5	25	0.19	0.19
30	38.0	37.0	1.5	25	0.18	0.18
31	38.0	36.0	2.5	25	0.18	0.18

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No	Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No	Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications

PRINTED NAME: **Patricio Ramos**

SIGNATURE: *Patricio Ramos* DATE: **02/06/26**

PHONE #: **(503)337-2222** CERT #: **6903**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name: **Mt. Hood Meadows Spring**

ID#: **4191167-A** Month-Year: **Jan-2026**

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 8:45	0.61	1187	724	3.3	7.32	64.7	Yes	25.3
2 / 8:50	0.54	4027	2174	3.8	7.36	62.9	Yes	7.5
3 / 10:45	0.58	5660	3283	3.9	7.42	64.2	Yes	5.3
4 / 10:00	0.58	1111	644	3.2	7.39	66.6	Yes	27.0
5 / 11:00	0.55	1555	855	3.3	7.29	63.5	Yes	19.3
6 / 7:52	0.58	1487	863	3.8	7.32	62.3	Yes	20.2
7 / 9:17	0.55	1219	670	3.1	7.33	65.3	Yes	24.6
8 / 12:30	0.52	1101	572	3.3	7.35	64.7	Yes	27.3
9 / 8:40	0.60	752	451	2.9	7.40	68.3	Yes	39.9
10 / 14:15	0.55	524	288	2.8	7.46	69.9	Yes	57.3
11 / 8:15	0.59	543	321	2.8	7.38	68.2	Yes	55.2
12 / 7:36	0.60	1307	784	3.2	7.36	66.0	Yes	23.0
13 / 7:29	0.59	1393	822	3.1	7.30	64.9	Yes	21.5
14 / 7:41	0.60	1320	792	3.0	7.33	66.2	Yes	22.7
15 / 9:00	0.58	1452	842	2.6	7.36	68.6	Yes	20.7
16 / 10:50	0.59	1130	667	2.9	7.30	65.8	Yes	26.6
17 / 11:15	0.52	573	298	2.8	7.32	66.2	Yes	52.3
18 / 7:38	0.58	581	337	2.6	7.36	68.6	Yes	51.6
19 / 8:09	0.54	815	440	2.3	7.34	69.2	Yes	36.8
20 / 8:37	0.51	1818	927	2.8	7.36	67.1	Yes	16.5
21 / 8:09	0.54	1255	678	2.9	7.46	69.4	Yes	23.9
22 / 8:40	0.55	1706	938	2.1	7.33	70.0	Yes	17.6
23 / 9:45	0.54	1166	630	2.3	7.33	68.9	Yes	25.7
24 / 11:00	0.52	673	350	2.8	7.31	66.0	Yes	44.6
25 / 8:03	0.61	664	405	2.1	7.34	70.7	Yes	45.2
26 / 8:11	0.60	1226	736	2.3	7.37	70.4	Yes	24.5
27 / 8:10	0.58	1477	857	2.3	7.36	70.0	Yes	20.3
28 / 8:06	0.61	1357	828	2.1	7.36	71.2	Yes	22.1
29 / 8:50	0.58	1522	883	1.9	7.34	71.4	Yes	19.7
30 / 7:55	0.60	1171	703	2.1	7.36	71.2	Yes	25.6
31 / 11:00	0.60	564	338	3.2	7.33	65.3	Yes	53.2

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.