

OHA - Drinking Water Program - Turbidity

County: **Hood River**

System Name: **Mt Hood Meadows Spring** ID#: **4191167** Month/Year: **March-2026**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	37.0	33.0	3.5	25.0	0.19	0.19
2	37.0	32.0	4.0	25.0	0.18	0.18
3	38.0	36.0	1.5	25.0	0.18	0.18
4	38.0	35.0	1.5	25.0	0.18	0.18
5	38.0	35.0	1.5	25.0	0.19	0.19
6	36.0	32.0	3.0	25.0	0.19	0.19
7	38.0	35.0	1.5	25.0	0.20	0.20
8	38.0	36.0	1.0	25.0	0.19	0.19
9	38.0	34.0	3.0	25.0	0.17	0.17
10	38.0	36.0	1.5	25.0	0.20	0.20
11	38.0	36.0	1.0	25.0	0.20	0.20
12	37.5	34.5	3.5	25.0	0.19	0.19
13	38.0	37.0	1.0	25.0	0.19	0.19
14	38.0	36.0	1.5	25.0	0.21	0.21
15	37.0	33.0	3.0	25.0	0.18	0.18
16	38.0	37.0	1.0	25.0	0.20	0.20
17	38.0	36.0	1.5	25.0	0.21	0.21
18	37.0	35.0	1.5	25.0	0.20	0.20
19	38.0	35.0	2.5	25.0	0.18	0.18
20	38.0	37.0	1.0	25.0	0.20	0.20
21	37.0	33.0	3.5	25.0	0.18	0.18
22	38.0	37.0	1.0	25.0	0.22	0.19
23	37.0	34.0	3.0	25.0	0.19	0.19
24	38.0	36.0	1.5	25.0	0.18	0.18
25	38.0	35.0	3.0	25.0	0.21	0.21
26	38.0	37.0	1.0	25.0	0.18	0.18
27	37.0	34.5	2.0	25.0	0.18	0.18
28	36.0	31.0	4.5	25.0	0.17	0.17
29	37.0	33.0	3.0	25.0	0.20	0.20
30	38.0	37.0	1.0	25.0	0.19	0.19
31	38.0	36.0	1.5	25.0	0.19	0.19

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input checked="" type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input checked="" type="radio"/> No
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input checked="" type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input checked="" type="radio"/> No
Notes: PSI = pounds per square inch		PRINTED NAME: Patricio Ramos	DATE: 04/04/26
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE: <i>[Signature]</i>	PHONE #: (503) 337-2222
PSID When to Change Filter = look in manual for manufacturer's specifications		CERT #: 6903	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name: **Mt. Hood Meadows Spring**

ID#: **4191167-A** Month-Year: **Mar-2026**

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 7:31	0.68	500	340	3.2	7.34	66.1	Yes	60.0
2 / 7:29	0.70	1008	706	3.8	7.37	64.3	Yes	29.8
3 / 7:39	0.68	1735	1180	3.4	7.38	66.2	Yes	17.3
4 / 8:10	0.61	1265	772	3.5	7.36	64.7	Yes	23.7
5 / 8:30	0.60	806	483	3.2	7.40	67.0	Yes	37.2
6 / 8:15	0.69	653	451	3.1	7.41	68.4	Yes	45.9
7 / 14:30	0.57	626	357	3.8	7.39	63.8	Yes	47.9
8 / 7:26	0.65	984	639	3.2	7.34	65.9	Yes	30.5
9 / 7:23	0.65	1259	818	3.6	7.40	65.5	Yes	23.8
10 / 7:12	0.57	1065	607	4.2	7.44	63.2	Yes	28.2
11 / 8:00	0.62	1007	624	3.1	7.34	66.1	Yes	29.8
12 / 8:50	0.68	1025	697	3.2	7.38	67.1	Yes	29.3
13 / 8:30	0.64	1146	734	3.3	7.37	66.1	Yes	26.2
14 / 8:15	0.64	630	403	2.9	7.40	68.7	Yes	47.6
15 / 7:56	0.63	548	345	2.9	7.35	67.4	Yes	54.8
16 / 7:34	0.58	1242	720	3.3	7.36	65.4	Yes	24.2
17 / 12:02	0.57	1404	801	3.3	7.37	65.6	Yes	21.4
18 / 10:03	0.58	1205	699	3.1	7.32	65.3	Yes	24.9
19 / 9:30	0.57	1408	802	3.2	7.39	66.5	Yes	21.3
20 / 9:00	0.67	1255	841	2.9	7.36	67.9	Yes	23.9
21 / 9:30	0.62	762	472	3.3	7.43	67.4	Yes	39.4
22 / 10:57	0.57	765	436	3.8	7.41	64.3	Yes	39.2
23 / 11:05	0.61	1070	653	3.1	7.38	67.0	Yes	28.0
24 / 7:31	0.58	1614	936	3.0	7.36	66.7	Yes	18.6
25 / 9:10	0.65	981	637	2.1	7.45	74.0	Yes	30.6
26 / 9:15	0.63	793	500	3.2	7.49	69.4	Yes	37.8
27 / 9:20	0.65	735	478	3.2	7.51	70.1	Yes	40.8
28 / 7:52	0.65	814	529	3.1	7.52	70.9	Yes	36.9
29 / 7:16	0.63	897	565	3.7	7.53	68.3	Yes	33.4
30 / 7:21	0.64	1354	866	3.0	7.51	71.0	Yes	22.2
31 / 8:18	0.71	1647	1170	3.0	7.51	71.6	Yes	18.2

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012