

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **4/2021**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4							
5				0.77			
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16				0.82			
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 4/2021

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						0.5
2		49						1
3		49						1.2
4		49						1.2
5/10.06am	2.2	49	107.8	8.7	8.50	82.9	Yes	1.5
6		49						1.3
7		49						data lost
8		49						data lost
9		49						data lost
10		49						data lost
11		49						data lost
12		49						data lost
13		49						data lost
14		49						data lost
15		49						data lost
16/11.36am	2.4	49	117.6	12.0	8.50	67.6	Yes	data lost
17		49						data lost
18		49						data lost
19		49						data lost
20		49						data lost
21		49						data lost
22		49						data lost
23		49						data lost
24		49						data lost
25		49						data lost
26		49						data lost
27		49						data lost
28		49						data lost
29		49						data lost
30		49						data lost
31		49						