

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **6/2022**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2				0.47			
3					0.36		
4							
5							
6				0.46			
7				0.64			
8				0.49			
9				0.45			
10							
11							
12							
13							
14							
15							
16							
17							
18				0.54			
19				0.59			
20							
21							
22			0.54				
23							
24			0.56				
25							
26							
27					0.66		
28				0.60			
29							
30				0.62			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 6/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						2
2/3.42pm	2.2	49	107.8	15.6	8.00	43.4	Yes	2.2
3/4.40pm	2.1	49	102.9	13.7	8.30	54.3	Yes	3.2
4		49						1
5		49						0.8
6/3.02pm	1.7	49	83.3	13.5	8.20	50.7	Yes	2.5
7/1.15pm	2.2	49	107.8	15.1	8.00	44.9	Yes	3.6
8/2.07pm	2.3	49	112.7	16.3	7.90	40.4	Yes	3
9/1.38pm	2.2	49	107.8	13.7	8.00	49.2	Yes	0.8
10		49						1.3
11		49						1
12		49						1.2
13		49						0.8
14		49						0.8
15		49						1.2
16		49						0.8
17		49						2
18/10.09am	2.1	49	102.9	13.4	8.10	51.5	Yes	1.8
19/10.44am	2.2	49	107.8	13.7	8.00	49.2	Yes	1.7
20		49						1.3
21		49						1.7
22/9.24am	2.6	49	127.4	14.0	8.00	50.5	Yes	3.2
23		49						4.5
24/7.32am	2.8	49	137.2	15.9	8.00	45.5	Yes	4.8
25		49						3
26		49						1
27/3.35pm	2.4	49	117.6	18.6	8.10	37.8	Yes	5.7
28/11.44am	2	49	98.0	15.0	8.10	45.8	Yes	6.1
29		49						7
30/10.16am	2	49	98.0	14.7	8.10	46.7	Yes	12.5
31		49						