

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **3/2023**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1						PO	
2						PO	
3						PO	
4			0.97				
5						PO	
6			0.86				
7						PO	
8						PO	
9				0.68			
10						PO	
11						PO	
12						PO	
13						PO	
14						PO	
15						PO	
16						PO	
17						PO	
18			0.28				
19						PO	
20						PO	
21					0.33		
22						PO	
23						PO	
24						PO	
25						PO	
26						PO	
27					0.36		
28						PO	
29					0.48		
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 3/2023

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		49						1.5
2		49						1.3
3		49						7.5
4/7.42am	1.4	49	68.6	9.1	7.40	49.3	Yes	off maint.
5		49						3.2
6/11.11am	2	49	98.0	7.3	7.50	61.8	Yes	off maint.
7		49						6.8
8		49						0.7
9/12.52pm	2	49	98.0	6.4	7.50	65.7	Yes	5.7
10		49						1
11		49						3.2
12		49						2.2
13		49						1.2
14		49						2.8
15		49						1.5
16		49						1.8
17		49						2
18/9.47am	2	49	98.0	7.2	7.50	62.2	Yes	7.6
19		49						1
20		49						0.5
21/2.18pm	2.2	49	107.8	11.0	7.80	54.9	Yes	8.3
22		49						1.2
23		49						2.3
24		49						4
25		49						4.7
26		49						0.3
27/3.51pm	2.2	49	107.8	8.5	7.70	62.7	Yes	1.5
28		49						1.3
29/3.14pm	2.2	49	107.8	10.2	7.60	53.9	Yes	2
30		49						0.5
31		49						2.3