

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **5/2023**

System Name: Camp Tapawingo		ID#: 41 91259		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10				0.42			
11							
12				0.38			
13							
14							
15				0.24			
16							
17							
18				0.26			
19			0.49				
20			0.38				
21							
22				0.32			
23				0.24			
24					0.26		
25				0.56			
26							
27					0.67		
28			0.39				
29			0.32				
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Brad Schmidt		
	PHONE #: (503) 787-3828		CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: May-23

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						0.7
2		49						1
3		49						1.2
4		49						0.7
5		49						1
6		49						3
7		49						2.5
8		49						0.8
9		49						2.8
10/1.46pm	2	49	98.0	9.2	7.50	54.4	Yes	0.8
11		49						5.8
12/1.32pm	2	49	98.0	9.8	7.50	52.2	Yes	8.8
13		49						0.8
14		49						0.5
15/12.52pm	2	49	98.0	14.9	7.50	37.0	Yes	1.5
16		49						3.3
17		49						6.8
18/10.21am	2	49	98.0	17.3	7.60	32.7	Yes	5.2
19/7.45am	2	49	98.0	15.0	7.70	39.5	Yes	3.5
20/7.44am	2	49	98.0	14.6	7.60	39.1	Yes	1.5
21		49						0.8
22/10.18am	2	49	98.0	15.2	7.60	37.6	Yes	1
23/12.17pm	2	49	98.0	15.6	7.60	36.6	Yes	3.2
24/2.47pm	2	49	98.0	18.2	7.60	30.8	Yes	4.5
25/12.39pm	1.8	49	88.2	15.8	7.60	35.3	Yes	6
26		49						5.5
27/3.47pm	2	49	98.0	16.3	7.60	35.0	Yes	6.5
28/7.47am	1.8	49	88.2	12.3	7.60	44.8	Yes	6.5
29/7.51am	2	49	98.0	13.0	7.60	43.5	Yes	4.5
30		49						7.6
31		49						4.2