

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **6/2023**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.25		
2							
3							
4					0.38		
5							
6							
7			0.35				
8							
9							
10							
11							
12				0.30			
13					0.34		
14							
15							
16							
17					0.36		
18							
19							
20				0.40			
21							
22							
23			0.20				
24			0.20				
25			0.21				
26			0.22				
27			0.19				
28			0.20				
29			0.18				
30				0.17			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		
Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 6/2023

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/3.42pm	2	49	98.0	16.5	7.60	34.5	Yes	5.3
2		49						5
3		49						9.3
4/2.11pm	2	49	98.0	16.7	7.60	34.0	Yes	1
5		49						5.8
6		49						1.2
7/7.43am	1.8	49	88.2	12.4	7.60	44.5	Yes	0.7
8		49						5.8
9		49						5.7
10		49						0.7
11		49						1
12/11.55am	2	49	98.0	16.6	7.70	35.6	Yes	4.9
13/5.57pm	22	49	1078.0	21.4	7.70	244.3	Yes	5.3
14		49						5.2
15		49						12.3
16		49						2.3
17/5.44pm	2	49	98.0	18.9	7.70	30.5	Yes	4.5
18		49						3
19		49						1.3
20/1.49pm	2	49	98.0	15.0	7.80	41.0	Yes	2.7
21		49						5.7
22		49						5.3
23/7.07am	2	49	98.0	15.2	7.80	40.5	Yes	5.2
24/8.32am	1.8	49	88.2	14.3	7.90	43.6	Yes	4.1
25/8.48am	2	49	98.0	14.4	7.90	44.3	Yes	2.8
26/7.38am	2	49	98.0	14.7	7.90	43.4	Yes	6.5
27/8.12am	1.8	49	88.2	14.6	7.90	42.7	Yes	6.8
28/7.35am	1.8	49	88.2	14.6	7.90	42.7	Yes	7.3
29/9.12am	1.8	49	88.2	15.8	7.90	39.5	Yes	8.1
30/10.37am	2	49	98.0	16.4	7.90	38.8	Yes	10.8
31		49						