

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **9/2023**

**System Name:** **Camp Tapawingo**      **ID#: 41**      **91259**      **WTP : TP -**      **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				0.27			
2				0.20			
3			0.25				
4						PO	
5						PO	
6				0.27			
7				0.18			
8						PO	
9						PO	
10						PO	
11					0.28		
12				0.26			
13						PO	
14			0.24				
15			0.28				
16				0.27			
17				0.25			
18			0.21				
19				0.18			
20				0.22			
21				0.14			
22			0.22				
23						PO	
24						PO	
25						PO	
26						PO	
27						PO	
28						PO	
29						PO	
30						PO	
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP - : A**

**System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 9/2023**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/11.48am	1.8	49	88.2	17.7	7.30	27.9	Yes	3.8
2/11.52am	1.8	49	88.2	18.7	7.40	27.0	Yes	3.8
3/9.19am	1.8	49	88.2	17.3	7.50	30.8	Yes	4
4		49						1.2
5		49						1
6/11.15am	1.8	49	88.2	17.8	7.40	28.7	Yes	4.7
7/11.25am	2	49	98.0	16.6	7.30	30.7	Yes	3.8
8		49						5.8
9		49						0.7
10		49						1
11/3.30pm	1.8	49	88.2	18.2	7.40	28.0	Yes	4.8
12/10.23am	1.8	49	88.2	16.9	7.40	30.5	Yes	2.5
13		49						3.2
14/8.44am	1.8	49	88.2	15.9	7.40	32.6	Yes	3.8
15/9.38am	1.8	49	88.2	16.2	7.40	31.9	Yes	0.8
16/10.58am	1.8	49	88.2	16.7	7.30	29.8	Yes	3.2
17/11.13am	1.8	49	88.2	16.9	7.40	30.5	Yes	4.2
18/9.27am	2	49	98.0	16.6	7.40	31.8	Yes	4.8
19/10.22am	2	49	98.0	14.1	7.30	36.2	Yes	2.3
20/10.18am	2	49	98.0	14.7	7.30	34.8	Yes	4.3
21/11.27am	2	49	98.0	15.3	7.40	34.7	Yes	3.2
22/8.12am	2	49	98.0	14.5	7.40	36.6	Yes	0.5
23		49						0.8
24		49						0.5
25		49						0.8
26		49						0.7
27		49						0.5
28		49						0.8
29		49						0.8
30		49						1
31		49						