

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **10/2023**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						PO	
2						PO	
3						PO	
4						PO	
5						PO	
6						PO	
7						PO	
8						PO	
9						PO	
10						PO	
11						PO	
12						PO	
13					0.38		
14					0.26		
15					0.26		
16			0.32				
17						PO	
18			0.49				
19				0.30			
20					0.26		
21						PO	
22						PO	
23				0.29			
24						PO	
25						PO	
26						PO	
27						PO	
28				0.21			
29			0.24				
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: Oct-23

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1		49						0.7
2		49						0.8
3		49						0.6
4		49						1
5		49						1.2
6		49						2.3
7		49						7
8		49						3.2
9		49						1.7
10		49						1
11		49						1
12		49						0.5
13/3.57pm	1.4	49	68.6	14.1	7.60	37.8	Yes	1.5
14/2.58pm	2	49	98.0	15.2	7.60	37.6	Yes	3.2
15/2.38pm	2	49	98.0	15.4	7.60	37.1	Yes	3.2
16/9.34am	2	49	98.0	14.0	7.30	36.5	Yes	5.2
17		49						5
18/9.13am	1.8	49	88.2	12.2	7.30	40.6	Yes	2.8
19/1.52pm	2	49	98.0	15.1	7.30	33.9	Yes	5.3
20/4.14pm	2	49	98.0	15.3	7.30	33.4	Yes	1.8
21		49						4.3
22		49						2.7
23/12.12pm	2	49	98.0	13.7	7.20	35.8	Yes	0.8
24		49						1.7
25		49						0.7
26		49						0.8
27		49						1.2
28/11.49am	2	49	98.0	13.1	7.30	38.7	Yes	2.2
29/9.26am	2	49	98.0	12.2	7.30	41.5	Yes	2.5
30		49						0.8
31		49						1.7