

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **11/2023**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						PO	
2						PO	
3						PO	
4						PO	
5						PO	
6						PO	
7						PO	
8					0.32		
9			0.27				
10				0.38			
11				0.23			
12				0.37			
13						PO	
14						PO	
15						PO	
16						PO	
17						PO	
18				0.29			
19			0.39				
20						PO	
21						PO	
22						PO	
23						PO	
24						PO	
25						PO	
26						PO	
27						PO	
28						PO	
29						PO	
30						PO	
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 11/2023

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1.2
2		49						1.5
3		49						2.2
4		49						2.5
5		49						0.3
6		49						0.7
7		49						0.7
8/5.13pm	2	49	98.0	12.7	7.40	41.2	Yes	5.8
9/8.20am	2	49	98.0	12.3	7.40	42.7	Yes	0.3
10/11.11am	1.6	49	78.4	10.8	7.20	42.0	Yes	6.2
11/12.08pm	1.6	49	78.4	11.1	7.20	41.2	Yes	2.7
12/12.41pm	1.6	49	78.4	11.5	7.30	41.5	Yes	2
13		49						0.5
14		49						1.5
15		49						0.5
16		49						0.8
17		49						0.5
18/10.19am	1.6	49	78.4	11.5	7.30	41.5	Yes	0.8
19/9.26am	1.6	49	78.4	11.7	7.30	41.0	Yes	0.7
20		49						1
21		49						1.3
22		49						0.7
23		49						0.8
24		49						0.8
25		49						1
26		49						0.3
27		49						0.5
28		49						0.5
29		49						0.5
30		49						0.2
31		49						