

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **12/2023**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			PO				
2			PO				
3			PO				
4			PO				
5			PO				
6			PO				
7			PO				
8					0.87		
9			PO				
10			PO				
11			PO				
12				0.58			
13			PO				
14			PO				
15			PO				
16					0.42		
17			PO				
18			PO				
19			PO				
20					0.56		
21			PO				
22			PO				
23			PO				
24			PO				
25			PO				
26			PO				
27			PO				
28			PO				
29			PO				
30			PO				
31					0.34		

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: Dec-23

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						0.5
2		49						7.5
3		49						6.7
4		49						Maint.
5		49						6.3
6		49						0.7
7		49						0.2
8/2.36pm	0.9	49	44.1	9.3	7.10	41.4	Yes	0.5
9		49						0.3
10		49						0.7
11		49						0.7
12/12.12pm	1.2	49	58.8	8.5	7.30	48.4	Yes	0.7
13		49						1.5
14		49						0.3
15		49						0.3
16/2.40pm	1.8	49	88.2	9.6	7.20	46.5	Yes	0.8
17		49						0.2
18		49						1.5
19		49						0.5
20/2.06pm	1.2	49	58.8	12.8	7.30	36.1	Yes	0.7
21		49						0.3
22		49						0.5
23		49						1
24		49						0.3
25		49						0.5
26		49						0.3
27		49						0.7
28		49						1
29		49						0.7
30		49						1.3
31/3.08pm	1.6	49	78.4	12.0	7.30	40.2	Yes	0.3